



**KẾT QUẢ TRẠM QUAN TRẮC NƯỚC THẢI ONLINE CỦA NHÀ MÁY XỬ LÝ
NƯỚC THẢI CÔNG SUẤT 2.900 M³/NGÀY ĐÊM TẠI KCN CHÂU SƠN –
THÁNG 06/2026**

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
00:00 01-06-2026	15,38	8,53	7,18	2,19	30,99	0	0,36
01:00 01-06-2026	15,6	8,28	7,18	2,25	30,85	0	0
02:00 01-06-2026	15,84	8,18	7,18	2,29	30,71	0	0
03:00 01-06-2026	16,01	8,03	7,19	2,33	30,58	0	0
04:00 01-06-2026	16,22	7,87	7,19	2,37	30,44	0	0
05:00 01-06-2026	16,42	7,79	7,18	2,4	30,28	0	0
06:00 01-06-2026	16,57	7,65	7,18	2,44	30,19	0	0
07:00 01-06-2026	16,82	7,74	7,21	2,41	30,34	0,4	56,31
08:00 01-06-2026	45,75	67,26	6,27	1,27	29,87	82,52	167,54
09:00 01-06-2026	111,62	194,89	6,41	22,87	29,44	103,24	89,38
10:00 01-06-2026	131,6	143,27	8,42	95,67	30,01	92,32	81,92
11:00 01-06-2026	213,91	345,99	6,94	46,34	30,53	95,57	137,9
12:00 01-06-2026	213,42	338,4	6,93	35,02	30,9	120,56	158,04
13:00 01-06-2026	57,7	138,09	7,1	40,22	30,56	127,67	93,72
14:00 01-06-2026	7,2	33,97	7,33	28,22	31,1	115,11	157,14
15:00 01-06-2026	8,44	20,21	7,45	1,39	32,11	133,43	134,23
16:00 01-06-2026	9,36	10,83	7,46	1,36	32,13	117,98	113,89
17:00 01-06-2026	9,44	1,78	7,51	1,38	32,16	126,67	160,97
18:00 01-06-2026	9,98	14,24	7,53	1,41	31,96	134,52	113,68
19:00 01-06-2026	10,86	21,06	7,49	1,41	31,73	136,07	67,94
20:00 01-06-2026	10,94	10,86	7,49	1,42	31,62	44,68	0
21:00 01-06-2026	10,99	3,9	7,51	1,44	31,51	5,47	0
22:00 01-06-2026	11,3	0,28	7,54	1,45	31,39	0,32	0
23:00 01-06-2026	11,78	0	7,57	1,47	31,27	0	0
00:00 02-06-2026	12,05	0	7,59	1,48	31,16	0	0
01:00 02-06-2026	12,46	0	7,61	1,5	31,04	0	0
02:00 02-06-2026	12,71	0	7,64	1,51	30,93	0	0
03:00 02-06-2026	13,22	0	7,66	1,52	30,82	0	0
04:00 02-06-2026	13,53	0	7,69	1,53	30,72	0	0,25
05:00 02-06-2026	13,87	2,98	7,72	1,54	30,62	0	0
06:00 02-06-2026	14,21	0	7,74	1,55	30,57	0	0
07:00 02-06-2026	14,78	0,11	7,74	1,55	30,69	0	28,46
08:00 02-06-2026	9,83	6,41	7,59	1,55	31	63,12	167,31
09:00 02-06-2026	6,76	13,61	7,6	1,54	31,44	118,93	123,7
10:00 02-06-2026	7,29	8,76	7,67	1,53	31,68	103,65	89,21
11:00 02-06-2026	7,52	12,75	7,7	1,53	31,89	109,39	124,65
12:00 02-06-2026	8,21	14,74	7,7	1,53	31,96	106,38	110,14



Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
13:00 02-06-2026	8,51	14,05	7,7	1,52	32,01	99,46	81,11
14:00 02-06-2026	8,87	12,87	7,7	1,53	32,07	100,51	157,72
15:00 02-06-2026	9,52	15,7	7,68	1,53	32	125,04	122,23
16:00 02-06-2026	9,72	15,86	7,67	1,53	31,92	123,49	95,81
17:00 02-06-2026	9,83	12,35	7,68	1,54	31,81	124,66	164,07
18:00 02-06-2026	10,87	21,83	7,65	1,54	31,66	138,93	129,35
19:00 02-06-2026	11,12	20,31	7,65	1,53	31,55	119,25	95,68
20:00 02-06-2026	10,75	11,18	7,68	1,52	31,3	103,36	41,04
21:00 02-06-2026	10,58	1,51	7,7	1,52	31,15	17,12	0
22:00 02-06-2026	10,35	0	7,74	1,53	31,01	1,11	0
23:00 02-06-2026	10,55	0	7,77	1,53	30,9	0	0
00:00 03-06-2026	10,62	0	7,8	1,54	30,8	0	0
01:00 03-06-2026	10,82	0	7,82	1,55	30,7	0	0,2
02:00 03-06-2026	11,01	0	7,84	1,56	30,61	0	0
03:00 03-06-2026	11,19	0	7,86	1,56	30,53	0	0
04:00 03-06-2026	11,33	0	7,88	1,57	30,44	0	0
05:00 03-06-2026	11,37	0	7,91	1,57	30,36	0	0
06:00 03-06-2026	11,48	0	7,92	1,58	30,36	0	0
07:00 03-06-2026	11,66	0,03	7,9	1,58	30,54	0	42,44
08:00 03-06-2026	12,88	2,96	7,63	1,58	30,97	72,94	118,61
09:00 03-06-2026	12,2	6,56	7,67	1,57	31,36	81,56	83,79
10:00 03-06-2026	12,35	7,88	7,7	1,58	31,62	93,02	146
11:00 03-06-2026	13,17	14,61	7,69	1,56	31,78	121,37	103,25
12:00 03-06-2026	13,65	16,68	7,69	1,57	32,03	99,72	116,05
13:00 03-06-2026	14	18,49	7,66	1,56	32,03	121,18	134,73
14:00 03-06-2026	14,21	18,59	7,63	1,55	31,99	115,42	80,83
15:00 03-06-2026	14,43	15,25	7,64	1,56	32,08	96,38	129,84
16:00 03-06-2026	15	15,91	7,62	1,56	31,99	123,19	135,44
17:00 03-06-2026	15,38	16,08	7,62	1,56	31,88	119,57	136,18
18:00 03-06-2026	16,02	18,73	7,61	1,56	31,7	134,88	142,74
19:00 03-06-2026	16,77	19,44	7,59	1,55	31,53	124,17	41,21
20:00 03-06-2026	16,57	9,9	7,61	1,54	31,1	29,84	0
21:00 03-06-2026	16,53	2,88	7,64	1,55	30,8	5,64	0
22:00 03-06-2026	16,66	0,17	7,67	1,56	30,59	0,35	0
23:00 03-06-2026	16,93	0	7,68	1,57	30,42	0	0
00:00 04-06-2026	17,18	0	7,69	1,58	30,25	0	0
01:00 04-06-2026	17,16	0	7,71	1,58	30,12	0	0
02:00 04-06-2026	17,2	0	7,72	1,59	29,98	0	0
03:00 04-06-2026	17,49	0	7,71	1,6	29,86	0	0
04:00 04-06-2026	17,73	0	7,71	1,6	29,76	0	0
05:00 04-06-2026	18,07	0	7,69	1,61	29,68	0	0
06:00 04-06-2026	18,26	0	7,69	1,61	29,67	0	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
07:00 04-06-2026	16,63	1,18	7,63	1,61	30,04	0	56,59
08:00 04-06-2026	10,55	4,89	7,51	1,6	30,95	82	167,14
09:00 04-06-2026	12,32	16,43	7,52	1,59	31,41	112,14	82,04
10:00 04-06-2026	12,94	12,46	7,54	1,58	31,71	113,87	164,2
11:00 04-06-2026	14,14	17,12	7,53	1,57	31,93	135,94	120,78
12:00 04-06-2026	15	19,1	7,51	1,56	32,12	124,8	154,22
13:00 04-06-2026	15,75	21,65	7,48	1,55	32,25	138,34	145,8
14:00 04-06-2026	16,72	23,06	7,46	1,55	32,3	121,74	77,38
15:00 04-06-2026	17,09	19,55	7,47	1,54	32,34	115,62	159,28
16:00 04-06-2026	17,94	21,25	7,48	1,55	32,3	133,54	158,7
17:00 04-06-2026	11,22	21,67	7,48	1,56	32,24	129,11	78,34
18:00 04-06-2026	8,09	36,75	7,49	1,57	32,17	106,28	140,94
19:00 04-06-2026	8,76	13,04	7,52	1,56	32,08	134,79	92,64
20:00 04-06-2026	9,15	8,15	7,52	1,54	31,95	60,31	0
21:00 04-06-2026	9,36	19,79	7,54	1,55	31,9	6,97	0
22:00 04-06-2026	9,62	44,28	7,56	1,56	31,79	3,94	0
23:00 04-06-2026	11,45	40,68	7,58	1,56	31,29	18,4	0,22
00:00 05-06-2026	12,36	14,7	7,57	1,55	30,82	5,31	0
01:00 05-06-2026	12,09	8,08	7,59	1,56	30,57	2,55	0
02:00 05-06-2026	12,11	1,62	7,61	1,57	30,34	1,9	0
03:00 05-06-2026	12,36	0,49	7,63	1,58	30,12	0,59	0
04:00 05-06-2026	12,57	0	7,64	1,59	29,94	0	0
05:00 05-06-2026	12,96	0	7,63	1,59	29,78	0	0,19
06:00 05-06-2026	13,2	0	7,61	1,59	29,64	0	0
07:00 05-06-2026	13,7	1,05	7,62	1,59	29,37	0	35,54
08:00 05-06-2026	14,77	9,98	7,55	1,61	30,76	85,13	170,01
09:00 05-06-2026	16,66	21,28	7,57	1,64	31,3	128,81	118,95
10:00 05-06-2026	17,18	21,79	7,56	1,64	31,47	111,75	119,5
11:00 05-06-2026	17,59	21,2	7,55	1,64	31,75	125,79	118,72
12:00 05-06-2026	18,51	24,84	7,51	1,64	31,98	125,35	145,83
13:00 05-06-2026	19,36	26,44	7,46	1,63	32,09	116,82	75,43
14:00 05-06-2026	12,86	21,28	7,44	1,62	32,2	104,75	150,3
15:00 05-06-2026	11,74	25,37	7,4	1,62	32,19	131,42	147,17
16:00 05-06-2026	12,91	25,22	7,36	1,62	32,16	125,96	79,97
17:00 05-06-2026	13,64	20,86	7,36	1,62	32,13	114,13	148,16
18:00 05-06-2026	14,72	19,13	7,37	1,62	32,02	130,11	107,86
19:00 05-06-2026	15,89	20,97	7,37	1,62	31,87	109,06	100,24
20:00 05-06-2026	16,87	11,78	7,34	1,6	31,74	76,31	0
21:00 05-06-2026	17,11	4,53	7,38	1,61	31,65	8,82	0
22:00 05-06-2026	17,26	0,52	7,41	1,62	31,55	0,23	0
23:00 05-06-2026	17,7	0	7,45	1,62	31,46	0	0
00:00 06-06-2026	17,99	0	7,48	1,63	31,37	0	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
01:00 06-06-2026	18,37	0	7,52	1,64	31,29	0	0
02:00 06-06-2026	18,9	0	7,55	1,64	31,2	0	0
03:00 06-06-2026	19,32	0	7,58	1,65	31,11	0	0
04:00 06-06-2026	19,92	0	7,61	1,65	31,01	0	0
05:00 06-06-2026	20,44	0	7,64	1,66	30,91	0	0
06:00 06-06-2026	20,91	0	7,66	1,66	30,85	0	0
07:00 06-06-2026	19,61	2,13	7,66	1,66	30,93	0	42,71
08:00 06-06-2026	10,52	5,61	7,46	1,66	31,27	81,79	168,37
09:00 06-06-2026	12,76	20,71	7,49	1,66	31,56	127,93	117,58
10:00 06-06-2026	13,7	18,8	7,51	1,67	31,68	127,36	158,92
11:00 06-06-2026	15,07	21,74	7,53	1,67	32	123,56	82,4
12:00 06-06-2026	16,24	20,14	7,54	1,67	32,3	97,27	109,14
13:00 06-06-2026	17,56	21,9	7,52	1,66	32,32	116	148,82
14:00 06-06-2026	18,75	24,49	7,5	1,66	32,32	118,41	79,37
15:00 06-06-2026	19,78	22,13	7,5	1,66	32,4	92,84	79,68
16:00 06-06-2026	20,93	19,81	7,5	1,66	32,4	103,29	163,13
17:00 06-06-2026	22,06	23,93	7,49	1,66	32,32	122,22	94,25
18:00 06-06-2026	22,88	21,01	7,49	1,66	32,26	102,2	129,54
19:00 06-06-2026	23,38	7,26	7,51	1,64	32,16	91,6	0
20:00 06-06-2026	23,73	1,93	7,54	1,65	32,13	8,01	0
21:00 06-06-2026	24,15	0	7,58	1,65	32,08	1,95	0,44
22:00 06-06-2026	24,7	0	7,62	1,66	32,03	0	0
23:00 06-06-2026	25,24	0	7,65	1,66	31,97	0	0
00:00 07-06-2026	25,92	0	7,68	1,67	31,86	0	0
01:00 07-06-2026	26,66	0	7,71	1,68	31,76	0	0
02:00 07-06-2026	27,28	0	7,74	1,68	31,68	0	0
03:00 07-06-2026	27,82	0	7,76	1,69	31,58	0	0
04:00 07-06-2026	28,57	0	7,79	1,7	31,47	0	0,39
05:00 07-06-2026	29,26	0	7,82	1,7	31,34	0	0
06:00 07-06-2026	29,92	0	7,84	1,71	31,22	0	0
07:00 07-06-2026	30,55	0	7,86	1,71	31,2	0	14,32
08:00 07-06-2026	22,09	20,32	7,54	1,7	31,3	62,9	167
09:00 07-06-2026	22,33	33,81	7,49	1,7	31,66	128,27	164,27
10:00 07-06-2026	23,06	36,84	7,5	1,7	31,86	132,29	96,12
11:00 07-06-2026	23,4	35,75	7,51	1,7	32,18	101,52	82,21
12:00 07-06-2026	24,04	30,18	7,52	1,69	32,52	93,66	136,12
13:00 07-06-2026	25,41	38,11	7,5	1,68	32,62	123,73	107,06
14:00 07-06-2026	26,33	40,2	7,49	1,68	32,65	110,91	148,3
15:00 07-06-2026	27,49	36,96	7,47	1,68	32,64	124,59	99,09
16:00 07-06-2026	28,01	41,17	7,47	1,68	32,64	117,61	160,31
17:00 07-06-2026	25,06	17,72	7,5	1,65	32,65	106,48	0
18:00 07-06-2026	25	12,95	7,53	1,66	32,81	8,75	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
19:00 07-06-2026	25,15	7,19	7,57	1,67	32,83	0,17	0
20:00 07-06-2026	25,67	3,39	7,6	1,67	32,81	0	0
21:00 07-06-2026	26,02	0,97	7,63	1,68	32,67	0	0
22:00 07-06-2026	26,58	0	7,66	1,69	32,55	0	0
23:00 07-06-2026	27,1	0	7,68	1,7	32,43	0	0
00:00 08-06-2026	27,56	0	7,68	1,71	32,3	0	0
01:00 08-06-2026	28,15	0,04	7,73	1,72	32,18	0	0,13
02:00 08-06-2026	28,72	0	7,74	1,73	32,02	0	0
03:00 08-06-2026	29,24	0	7,75	1,74	31,84	0	0
04:00 08-06-2026	29,89	0	7,74	1,74	31,69	0	0
05:00 08-06-2026	30,32	0	7,76	1,75	31,54	0	0
06:00 08-06-2026	31,02	0	7,79	1,76	31,44	0	0
07:00 08-06-2026	31,65	0	7,81	1,76	31,5	0	14,59
08:00 08-06-2026	21,59	11,47	7,54	1,73	31,45	52,91	167,5
09:00 08-06-2026	23,95	26,62	7,52	1,73	31,9	123,26	128,89
10:00 08-06-2026	24,52	26,52	7,54	1,73	32,19	114,35	122,76
11:00 08-06-2026	25,17	26,34	7,55	1,73	32,44	123,1	114,28
12:00 08-06-2026	26,11	32,81	7,56	1,72	32,58	122,18	161,86
13:00 08-06-2026	26,87	35,22	7,55	1,71	32,66	135,66	105,85
14:00 08-06-2026	23,97	32,33	7,55	1,71	32,81	101,07	132,92
15:00 08-06-2026	21,42	27,42	7,53	1,7	32,86	120,76	130,01
16:00 08-06-2026	22,58	30,71	7,48	1,68	32,68	114,32	78,27
17:00 08-06-2026	22,38	14,04	7,47	1,66	32,53	100,92	97,88
18:00 08-06-2026	22,79	11,72	7,52	1,68	32,19	100,49	120,98
19:00 08-06-2026	23,29	0,46	7,56	1,7	31,09	110,83	80,48
20:00 08-06-2026	23,85	0	7,6	1,71	30,47	72,3	0
21:00 08-06-2026	24,59	0	7,65	1,72	30,24	10,93	0
22:00 08-06-2026	25,11	0	7,68	1,72	29,94	3,38	0
23:00 08-06-2026	25,86	0	7,72	1,73	29,71	2,97	0,32
00:00 09-06-2026	26,36	0	7,75	1,74	29,49	0,59	0
01:00 09-06-2026	27,14	0	7,78	1,74	29,28	0	0
02:00 09-06-2026	27,82	0,38	7,81	1,74	29,07	1,36	0,29
03:00 09-06-2026	28,44	0	7,84	1,74	28,88	0,94	0
04:00 09-06-2026	29,13	0,88	7,87	1,75	28,73	0	0
05:00 09-06-2026	29,9	0	7,89	1,75	28,59	0	0
06:00 09-06-2026	30,54	0	7,92	1,76	28,49	0	0
07:00 09-06-2026	29,5	6,89	7,84	1,75	28,88	15,22	85,28
08:00 09-06-2026	22,8	1,9	7,58	1,72	30,75	106,04	147,42
09:00 09-06-2026	24,61	24,39	7,59	1,72	30,94	108,75	83,98
10:00 09-06-2026	24,86	22,52	7,58	1,71	30,99	93,01	83,8
11:00 09-06-2026	24,37	14,05	7,6	1,72	31,11	95,06	118,29
12:00 09-06-2026	24,38	7,08	7,58	1,72	31,18	102,32	138,51

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
13:00 09-06-2026	25,4	10,82	7,54	1,71	31,14	126,63	123,45
14:00 09-06-2026	26,1	13,74	7,52	1,71	31,2	111,7	109,64
15:00 09-06-2026	27,1	14,52	7,49	1,69	31,08	119,95	163,91
16:00 09-06-2026	22,32	20,28	7,46	1,66	31,02	133,58	94,96
17:00 09-06-2026	23,25	29,32	7,45	1,63	30,93	119,93	163,42
18:00 09-06-2026	25,16	34,78	7,43	1,6	30,86	138,96	148,48
19:00 09-06-2026	26,31	27,4	7,39	1,72	30,74	116,65	74,03
20:00 09-06-2026	26,2	22,55	7,44	1,7	30,4	77,68	0
21:00 09-06-2026	26,25	11,68	7,49	1,7	30,08	9,36	0
22:00 09-06-2026	26,46	4,39	7,54	1,71	29,84	0,58	0
23:00 09-06-2026	26,96	0,4	7,59	1,71	29,62	0	0
00:00 10-06-2026	27,34	0	7,64	1,71	29,4	0	0,14
01:00 10-06-2026	27,83	0	7,68	1,72	29,21	0	0,3
02:00 10-06-2026	28,47	0	7,72	1,73	29,03	0	0
03:00 10-06-2026	29,07	0	7,75	1,73	28,87	0	0
04:00 10-06-2026	29,79	0	7,78	1,73	28,72	0	0
05:00 10-06-2026	30,59	0	7,81	1,74	28,57	0	0,18
06:00 10-06-2026	31,36	0	7,84	1,74	28,46	0	0
07:00 10-06-2026	31,83	0	7,86	1,74	28,43	0	84,71
08:00 10-06-2026	22,31	12,84	7,46	1,73	29,87	87,27	167,14
09:00 10-06-2026	21,9	30,1	7,5	1,72	30,32	115,44	123,99
10:00 10-06-2026	21,65	15,96	7,53	1,73	30,66	117,58	157,32
11:00 10-06-2026	22,95	21,66	7,52	1,72	30,88	118,46	81,21
12:00 10-06-2026	23,76	23,45	7,51	1,73	31,07	124,22	142,92
13:00 10-06-2026	24,85	29,66	7,5	1,73	31,06	132,16	100,66
14:00 10-06-2026	24,89	24,7	7,51	1,74	31,06	110,98	135,67
15:00 10-06-2026	25,08	20,36	7,51	1,73	31,04	113,33	114,43
16:00 10-06-2026	25,42	18,73	7,52	1,74	31,01	104,48	155,78
17:00 10-06-2026	27,8	32,41	7,5	1,74	30,96	127,07	134,11
18:00 10-06-2026	26,66	40,76	7,5	1,73	30,87	117,69	80,01
19:00 10-06-2026	24,19	32,04	7,53	1,74	30,69	105,55	67,06
20:00 10-06-2026	26,19	23,7	7,55	1,73	30,6	68,22	0
21:00 10-06-2026	25,82	11,76	7,6	1,73	30,44	8,24	0
22:00 10-06-2026	25,71	3,3	7,66	1,74	30,29	0,41	0
23:00 10-06-2026	25,63	0	7,71	1,75	30,12	0	0
00:00 11-06-2026	25,57	0	7,75	1,75	29,98	0	0
01:00 11-06-2026	26	0	7,79	1,76	29,84	0	0
02:00 11-06-2026	26,34	0	7,82	1,76	29,69	0	0
03:00 11-06-2026	26,69	0	7,86	1,69	29,56	0	0
04:00 11-06-2026	26,99	0	7,89	1,69	29,43	0	0,22
05:00 11-06-2026	27,52	0	7,92	1,69	29,32	0	0
06:00 11-06-2026	27,86	0	7,94	1,7	29,28	0	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
07:00 11-06-2026	28	1,72	7,89	1,69	29,37	0	56,71
08:00 11-06-2026	23,68	6,83	7,52	1,65	30,11	84,38	153,71
09:00 11-06-2026	26,04	27,92	7,53	1,65	30,4	125,38	104,79
10:00 11-06-2026	26,06	28,91	7,53	1,66	30,45	121,2	104,28
11:00 11-06-2026	26,65	30,96	7,52	1,66	30,44	99,82	83,76
12:00 11-06-2026	25,94	16,8	7,54	1,65	30,56	104,97	159,85
13:00 11-06-2026	27,39	28,23	7,5	1,65	30,51	129,29	110,32
14:00 11-06-2026	28,03	32	7,49	1,65	30,5	110,26	97,22
15:00 11-06-2026	14,01	26,98	7,49	1,64	30,5	114,78	130,69
16:00 11-06-2026	4,46	24,9	7,48	1,64	30,5	113,76	130,67
17:00 11-06-2026	5,98	35,56	7,46	1,64	30,47	113,62	95,9
18:00 11-06-2026	6,86	38,38	7,46	1,64	30,43	98,43	123,43
19:00 11-06-2026	7,13	28,65	7,49	1,62	30,28	126,21	75,19
20:00 11-06-2026	6,93	14,29	7,54	1,62	30,04	50,87	0
21:00 11-06-2026	6,96	5,69	7,59	1,62	29,85	6,89	0
22:00 11-06-2026	7,28	0,42	7,64	1,63	29,68	0,22	0
23:00 11-06-2026	7,45	0	7,69	1,63	29,54	0	0
00:00 12-06-2026	7,94	0	7,73	1,64	29,37	0	0
01:00 12-06-2026	8,32	0	7,77	1,64	29,27	0	0
02:00 12-06-2026	8,76	0	7,8	1,64	29,16	0	0
03:00 12-06-2026	9,19	0	7,83	1,65	29,07	0	0,2
04:00 12-06-2026	9,69	0	7,85	1,65	28,99	0	0
05:00 12-06-2026	10,28	0	7,87	1,65	28,9	0	0
06:00 12-06-2026	10,7	0	7,89	1,66	28,86	0	0
07:00 12-06-2026	11,47	0,06	7,82	1,66	29,04	10,59	71,08
08:00 12-06-2026	13,14	2,13	7,42	1,64	30,04	102,24	167,16
09:00 12-06-2026	14,43	17,49	7,44	1,63	30,28	119,34	89,27
10:00 12-06-2026	14,52	16,06	7,46	1,64	30,41	111,97	151,62
11:00 12-06-2026	15,2	19,67	7,45	1,64	30,54	115,32	81,46
12:00 12-06-2026	15,25	13,32	7,46	1,64	30,92	100,48	136,36
13:00 12-06-2026	15,99	17,41	7,44	1,65	31,08	130,84	134,17
14:00 12-06-2026	16,5	20,53	7,43	1,66	31,13	115,02	79,91
15:00 12-06-2026	16,44	15,18	7,43	1,66	31,21	100,85	141,88
16:00 12-06-2026	17,07	16,61	7,42	1,66	31,2	116,79	93,46
17:00 12-06-2026	17,2	14,65	7,42	1,67	31,2	101,83	121,72
18:00 12-06-2026	17,15	10,85	7,43	1,67	31,15	123,75	134,71
19:00 12-06-2026	18,2	22,22	7,42	1,66	31,08	114,72	80,26
20:00 12-06-2026	18,52	14,83	7,47	1,67	31	70,23	6,73
21:00 12-06-2026	18,47	2,8	7,55	1,68	30,91	8,35	0
22:00 12-06-2026	18,55	0	7,62	1,67	30,82	0,19	0
23:00 12-06-2026	18,65	0	7,69	1,67	30,73	0	0
00:00 13-06-2026	18,89	0	7,74	1,67	30,63	0	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
01:00 13-06-2026	19,47	0	7,79	1,68	30,54	0	0
02:00 13-06-2026	19,85	0	7,84	1,69	30,46	0	0
03:00 13-06-2026	20,24	0	7,88	1,69	30,37	0	0
04:00 13-06-2026	20,8	0	7,91	1,7	30,26	0	0
05:00 13-06-2026	21,36	0	7,94	1,71	30,14	0	0
06:00 13-06-2026	21,85	0	7,96	1,72	30,06	0	0
07:00 13-06-2026	19,21	0,92	7,95	1,74	30,04	0	56,54
08:00 13-06-2026	7,27	17,28	7,43	1,68	30,64	83,45	166,57
09:00 13-06-2026	8,51	52,58	7,45	1,68	31,07	118,82	94,99
10:00 13-06-2026	9,16	37,98	7,47	1,68	31,29	91,52	94,2
11:00 13-06-2026	9,91	8,98	7,47	1,68	31,44	97,94	107,45
12:00 13-06-2026	11,06	13,33	7,45	1,68	31,58	94,82	134,7
13:00 13-06-2026	12,9	16,76	7,41	1,68	31,66	117,26	133,87
14:00 13-06-2026	11,57	19,07	7,38	1,67	31,76	126,32	153,05
15:00 13-06-2026	14,7	17,77	7,33	1,68	31,82	122,65	77,97
16:00 13-06-2026	14,92	19,57	7,29	1,64	31,93	106,42	119,84
17:00 13-06-2026	15,48	18,07	7,29	1,64	31,89	106,8	106,51
18:00 13-06-2026	15,67	13,6	7,3	1,63	31,82	113,51	113,43
19:00 13-06-2026	16,17	8,2	7,33	1,63	31,74	126,33	80,58
20:00 13-06-2026	16,83	1,88	7,45	1,64	31,77	39,72	0
21:00 13-06-2026	17,39	0	7,58	1,66	31,81	4,64	0,18
22:00 13-06-2026	18,12	0	7,68	1,67	31,83	0	0,43
23:00 13-06-2026	18,88	0	7,77	1,69	31,83	0	0
00:00 14-06-2026	19,7	0	7,84	1,7	31,8	0	0,49
01:00 14-06-2026	20,46	0	7,9	1,71	31,73	0	0
02:00 14-06-2026	21,18	0	7,95	1,73	31,68	0	0,23
03:00 14-06-2026	21,97	0	7,99	1,74	31,62	0	0
04:00 14-06-2026	22,77	0	8,02	1,76	31,56	0	0,22
05:00 14-06-2026	23,91	0	8,05	1,77	31,5	0	0
06:00 14-06-2026	24,66	0	8,07	1,78	31,47	0	0,21
07:00 14-06-2026	25,4	0	8,1	1,79	31,58	0	0,24
08:00 14-06-2026	16,33	0,64	7,6	1,69	31,23	27,02	151,98
09:00 14-06-2026	11,31	2,19	7,37	1,65	31,35	113,87	136,18
10:00 14-06-2026	12,63	13,38	7,38	1,67	31,5	124,87	135,25
11:00 14-06-2026	12,76	10,93	7,38	1,65	31,62	110,85	93,82
12:00 14-06-2026	13,22	8,86	7,38	1,64	31,7	114,26	161,89
13:00 14-06-2026	14,04	12,43	7,37	1,64	31,79	118,85	85,77
14:00 14-06-2026	15	11,6	7,38	1,64	31,78	116,2	160,42
15:00 14-06-2026	16,24	12,08	7,37	1,62	31,78	134,99	118,68
16:00 14-06-2026	17,86	11,02	7,37	1,64	31,8	111,4	39,22
17:00 14-06-2026	18,37	2,47	7,5	1,64	32,09	21,24	0
18:00 14-06-2026	19,07	0	7,61	1,65	32,28	0,8	0,81

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
19:00 14-06-2026	19,89	0	7,7	1,66	32,38	0	1,37
20:00 14-06-2026	20,68	0	7,78	1,67	32,41	0	0,33
21:00 14-06-2026	21,75	0	7,84	1,69	32,42	0	0,65
22:00 14-06-2026	22,5	0	7,88	1,7	32,4	0	0
23:00 14-06-2026	23,49	0	7,92	1,72	32,37	0	0
00:00 15-06-2026	24,46	0	7,96	1,73	32,33	0	0,49
01:00 15-06-2026	25,33	0	8	1,75	32,27	0	0,15
02:00 15-06-2026	26,28	0	8,02	1,76	32,21	0	0
03:00 15-06-2026	27,29	0	8,04	1,77	32,15	0	0
04:00 15-06-2026	28,25	0	8,06	1,78	32,08	0	0
05:00 15-06-2026	28,96	0	8,06	1,8	32,01	0	0
06:00 15-06-2026	29,89	0	8,08	1,78	31,98	0	0,35
07:00 15-06-2026	30,55	0	8,09	1,8	32,13	0	56,35
08:00 15-06-2026	10,53	1,68	7,33	1,68	31	85,65	165,49
09:00 15-06-2026	10,42	7,23	7,31	1,66	31,24	123,25	115,47
10:00 15-06-2026	13,45	7,1	7,34	1,67	31,51	106,72	129,55
11:00 15-06-2026	17,37	9,47	7,33	1,66	31,74	114,36	86,77
12:00 15-06-2026	20,76	9,11	7,34	1,66	31,86	97,61	121
13:00 15-06-2026	23,32	11,22	7,34	1,65	31,89	120,51	146,67
14:00 15-06-2026	25,6	13,16	7,34	1,65	31,91	112,85	78,54
15:00 15-06-2026	26,39	9,24	7,35	1,63	31,99	100,74	126,87
16:00 15-06-2026	26,78	11,07	7,33	1,64	31,95	118,45	160,18
17:00 15-06-2026	25,92	10,76	7,32	1,64	31,88	117,67	78,6
18:00 15-06-2026	24,61	7,36	7,31	1,64	31,81	108,24	154,34
19:00 15-06-2026	21,96	12	7,31	1,64	31,76	129,4	79,2
20:00 15-06-2026	20,23	4,58	7,4	1,64	31,85	65,99	0
21:00 15-06-2026	19,61	0	7,51	1,64	31,96	7,43	0,26
22:00 15-06-2026	19,25	0	7,63	1,64	32,05	0,17	0
23:00 15-06-2026	18,85	0	7,72	1,66	32,12	0	0
00:00 16-06-2026	18,65	0	7,8	1,67	32,17	0	0
01:00 16-06-2026	18,53	0	7,87	1,68	32,18	0	0,31
02:00 16-06-2026	18,25	0	7,93	1,69	32,13	0	0
03:00 16-06-2026	18,29	0	7,97	1,71	32,08	0	0
04:00 16-06-2026	18,22	0	8,01	1,72	32,01	0	0,29
05:00 16-06-2026	18,3	0	8,04	1,74	31,85	0	0,13
06:00 16-06-2026	18,14	0	8,06	1,75	31,72	0	0,19
07:00 16-06-2026	17,42	0	8,02	1,75	31,58	0,3	56,45
08:00 16-06-2026	11,46	0	7,25	1,67	31,02	80,16	166,94
09:00 16-06-2026	11,32	2,76	7,28	1,67	31,23	115,74	110,11
10:00 16-06-2026	11,72	13,53	7,29	1,7	31,3	126,76	129,8
11:00 16-06-2026	11,71	31,44	7,3	1,75	31,4	111,3	81,42
12:00 16-06-2026	12,61	91,4	7,3	2,05	31,43	105,53	156,65

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
13:00 16-06-2026	13,47	40,99	7,27	2,69	31,42	123,63	100,74
14:00 16-06-2026	14,17	0	7,28	2,89	31,4	116,08	148,68
15:00 16-06-2026	14,87	24,45	7,28	2,94	31,42	126,78	106,77
16:00 16-06-2026	15,6	27,98	7,28	2,63	31,42	123,89	133,47
17:00 16-06-2026	16,16	0,23	7,25	0,87	31,38	113,5	113,43
18:00 16-06-2026	16,95	8,04	7,22	0,54	31,34	122,93	132,67
19:00 16-06-2026	17,21	10,67	7,21	0,55	31,31	120,41	132,94
20:00 16-06-2026	17,65	7,29	7,23	0,56	31,28	114,64	0,4
21:00 16-06-2026	17,72	0,06	7,3	0,56	31,27	17,01	0
22:00 16-06-2026	18,08	0	7,36	0,56	31,27	0,68	0
23:00 16-06-2026	18,72	0	7,43	0,57	31,27	0	0
00:00 17-06-2026	19,25	0	7,49	0,57	31,26	0	0,38
01:00 17-06-2026	19,84	0	7,55	0,56	31,25	0	0,21
02:00 17-06-2026	20,49	0	7,6	0,56	31,23	0	0
03:00 17-06-2026	21,17	0	7,65	0,55	31,21	0	0
04:00 17-06-2026	21,9	0	7,71	0,54	31,21	0	0
05:00 17-06-2026	22,64	0	7,75	0,55	31,19	0	0
06:00 17-06-2026	23,26	0	7,78	0,56	31,18	0	0
07:00 17-06-2026	24,06	0	7,8	0,57	31,26	2,68	60,49
08:00 17-06-2026	11,82	0	7,15	0,4	30,95	93,58	165,69
09:00 17-06-2026	11,91	0	7,16	0,31	31,18	117,09	95,39
10:00 17-06-2026	11,86	0	7,18	0,25	31,38	108,06	143,76
11:00 17-06-2026	12,45	1,13	7,17	0,21	31,61	122,85	141,75
12:00 17-06-2026	13,19	0	7,15	0,2	31,69	123,07	98,74
13:00 17-06-2026	13,76	0	7,14	0,19	31,71	116,53	146,12
14:00 17-06-2026	14,58	0	7,13	0,19	31,75	117,29	105,85
15:00 17-06-2026	15,51	3,37	7,14	0,18	31,78	121,41	138,79
16:00 17-06-2026	16,67	0,61	7,13	0,17	31,78	116,81	111,8
17:00 17-06-2026	17,53	4,92	7,16	0,17	31,74	117,04	104,64
18:00 17-06-2026	19,29	13,23	7,18	0,17	31,67	103,33	126,39
19:00 17-06-2026	20,48	9,99	7,21	0,16	31,62	132,19	59,69
20:00 17-06-2026	21,68	0	7,28	0,16	31,57	43,38	1,37
21:00 17-06-2026	23,09	0	7,35	0,16	31,52	6,79	0
22:00 17-06-2026	24,48	0	7,42	0,16	31,45	0,37	0,21
23:00 17-06-2026	26,02	0	7,49	0,16	31,35	0	0
00:00 18-06-2026	27,74	0	7,56	0,18	31,25	0	0,45
01:00 18-06-2026	29,23	0	7,62	0,2	31,17	0	0,16
02:00 18-06-2026	30,95	0	7,67	0,2	31,07	0	0
03:00 18-06-2026	32,54	0	7,72	0,2	30,98	0	0,21
04:00 18-06-2026	34,16	0	7,77	0,2	30,9	0	0
05:00 18-06-2026	35,77	0	7,81	0,2	30,82	0	0
06:00 18-06-2026	37,26	0	7,85	0,2	30,76	0	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
07:00 18-06-2026	35,48	0	7,79	0,2	30,73	0	42,53
08:00 18-06-2026	19,31	0	7,26	0,2	30,73	61,47	166,82
09:00 18-06-2026	20,86	2,47	7,27	0,21	31,07	127,36	122,72
10:00 18-06-2026	21,47	1,85	7,27	0,2	31,22	117,53	122,47
11:00 18-06-2026	21,3	0,69	7,26	0,2	31,46	118,89	100,05
12:00 18-06-2026	21,68	0	7,26	0,2	31,74	100,39	105,89
13:00 18-06-2026	22,18	0	7,26	0,2	31,9	113,6	138,84
14:00 18-06-2026	23,09	0	7,25	0,2	31,93	112,65	97,54
15:00 18-06-2026	23,67	0	7,25	0,2	31,96	116,22	131,06
16:00 18-06-2026	24,46	1,7	7,25	0,2	31,95	117,73	117,42
17:00 18-06-2026	24,93	0,02	7,24	0,2	31,87	107,69	110,67
18:00 18-06-2026	26,44	6,53	7,25	0,19	31,79	110,75	90,49
19:00 18-06-2026	26,98	6,69	7,25	0,19	31,72	103,46	118,52
20:00 18-06-2026	27,59	0,66	7,25	0,19	31,69	96,89	0
21:00 18-06-2026	28,19	0,33	7,31	0,2	31,68	11,86	0
22:00 18-06-2026	29,1	0	7,37	0,19	31,64	0,29	0,37
23:00 18-06-2026	30,11	0	7,42	0,19	31,6	0	0
00:00 19-06-2026	31,37	0	7,48	0,19	31,55	0	0
01:00 19-06-2026	32,34	0	7,53	0,19	31,47	0	0
02:00 19-06-2026	33,53	0	7,59	0,2	31,38	0	0
03:00 19-06-2026	34,78	0	7,63	0,2	31,29	0	0,6
04:00 19-06-2026	35,83	0	7,67	0,2	31,19	0	0
05:00 19-06-2026	36,87	0	7,71	0,2	31,07	0	0,57
06:00 19-06-2026	38,18	0	7,74	0,2	30,98	0	0,28
07:00 19-06-2026	39,18	0	7,73	0,2	30,9	0	42,64
08:00 19-06-2026	20,67	0	7,31	0,19	30,72	64,98	167
09:00 19-06-2026	19,69	1,31	7,32	0,2	31,01	122,04	103,55
10:00 19-06-2026	20,32	1,86	7,32	0,2	31,18	118,91	151,55
11:00 19-06-2026	21,02	1,68	7,3	0,19	31,33	115,88	81,55
12:00 19-06-2026	21,14	0	7,3	0,19	31,3	96,68	95,15
13:00 19-06-2026	22,11	0	7,29	0,18	31,32	110,4	162,48
14:00 19-06-2026	22,86	0	7,3	0,18	31,4	119,26	79,58
15:00 19-06-2026	23,32	0	7,29	0,18	31,39	97,08	113,62
16:00 19-06-2026	24,43	0,28	7,28	0,18	31,38	119,47	139,98
17:00 19-06-2026	16,49	8,84	7,28	0,17	31,35	127,32	126,26
18:00 19-06-2026	18,4	11,12	7,29	0,17	31,31	117,87	105,87
19:00 19-06-2026	18,8	10,57	7,29	0,17	31,16	120,99	79,62
20:00 19-06-2026	18,87	8,9	7,32	0,17	30,94	55,09	0
21:00 19-06-2026	19,18	7,73	7,38	0,16	30,86	7,98	0
22:00 19-06-2026	19,52	7	7,44	0,16	30,78	0,25	0
23:00 19-06-2026	20,2	6,47	7,5	0,16	30,72	0	0
00:00 20-06-2026	20,85	6,07	7,55	0,16	30,66	0	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
01:00 20-06-2026	21,54	5,78	7,59	0,16	30,61	0	0
02:00 20-06-2026	22,23	5,55	7,63	0,16	30,56	0	0
03:00 20-06-2026	22,96	5,34	7,66	0,16	30,5	0	0,3
04:00 20-06-2026	23,84	5,21	7,7	0,16	30,43	0	0
05:00 20-06-2026	24,63	5,11	7,73	0,16	30,37	0	0
06:00 20-06-2026	25,42	5	7,75	0,16	30,34	0	0,17
07:00 20-06-2026	23,66	5,42	7,68	0,16	30,37	0	56,01
08:00 20-06-2026	15,9	8,14	7,34	0,19	30,49	85,87	166,2
09:00 20-06-2026	16,78	9,69	7,33	0,2	30,83	123,01	105,02
10:00 20-06-2026	16,9	9,25	7,33	0,2	30,97	104,79	116,79
11:00 20-06-2026	17,41	8,85	7,32	0,2	31,17	121,53	114,86
12:00 20-06-2026	18,27	9,12	7,32	0,19	31,45	117,26	160,17
13:00 20-06-2026	19,57	9,6	7,31	0,18	31,52	119,87	76,87
14:00 20-06-2026	20,03	9,2	7,3	0,17	31,67	106,9	157,81
15:00 20-06-2026	21,19	9,8	7,29	0,17	31,74	132,73	148,56
16:00 20-06-2026	22,34	10,41	7,28	0,17	31,75	124,83	74,99
17:00 20-06-2026	22,26	9,58	7,28	0,17	31,75	110,53	128,32
18:00 20-06-2026	23,5	10,16	7,28	0,17	31,66	105,69	121,85
19:00 20-06-2026	25,4	10,72	7,28	0,17	31,5	129,25	64,56
20:00 20-06-2026	25,55	9,03	7,3	0,17	31,33	42,11	0
21:00 20-06-2026	25,86	8,04	7,37	0,17	31,22	6,41	0,24
22:00 20-06-2026	26,47	7,38	7,42	0,16	31,09	0,23	0,31
23:00 20-06-2026	27,2	6,93	7,46	0,16	30,96	0	0,59
00:00 21-06-2026	27,91	6,51	7,51	0,16	30,82	0	0
01:00 21-06-2026	28,68	6,22	7,54	0,17	30,69	0	0
02:00 21-06-2026	29,57	6,01	7,58	0,17	30,58	0	0,19
03:00 21-06-2026	30,24	5,76	7,62	0,17	30,49	0	0
04:00 21-06-2026	31,18	5,64	7,66	0,17	30,38	0	0
05:00 21-06-2026	31,98	5,49	7,7	0,18	30,27	0	0,16
06:00 21-06-2026	32,61	5,37	7,73	0,18	30,21	7,26	47,11
07:00 21-06-2026	31,32	5,46	7,72	0,18	30,41	69,17	109,98
08:00 21-06-2026	22,05	7,86	7,29	0,2	31,17	110,9	146,86
09:00 21-06-2026	22,35	8,7	7,34	0,2	31,43	110,16	114,46
10:00 21-06-2026	23,14	8,76	7,35	0,21	31,69	119,08	111,12
11:00 21-06-2026	24,02	9,15	7,35	0,21	31,94	97,82	105,74
12:00 21-06-2026	24,93	9,04	7,35	0,2	32,26	108,15	89,77
13:00 21-06-2026	26,01	9,02	7,34	0,2	32,35	113,22	130,7
14:00 21-06-2026	27,35	9,48	7,32	0,18	32,34	101,63	70,04
15:00 21-06-2026	28,15	9,13	7,32	0,16	32,41	100,67	137,22
16:00 21-06-2026	23,5	9,72	7,32	0,16	32,43	113,82	127,62
17:00 21-06-2026	18,3	9,13	7,37	0,16	32,24	79,24	0
18:00 21-06-2026	18,97	8,23	7,45	0,16	31,7	7,76	0,72

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
19:00 21-06-2026	19,73	7,64	7,53	0,16	30,98	1,41	0,83
20:00 21-06-2026	20,59	7,22	7,6	0,16	30,22	0	1,17
21:00 21-06-2026	21,44	6,82	7,66	0,16	29,48	1,42	0,22
22:00 21-06-2026	22,48	6,55	7,72	0,16	28,89	0	0,4
23:00 21-06-2026	23,4	6,36	7,78	0,16	28,38	0	0,3
00:00 22-06-2026	24,47	6,26	7,82	0,16	27,95	0	0,69
01:00 22-06-2026	25,43	6,03	7,87	0,16	27,54	0,14	0,85
02:00 22-06-2026	26,36	5,95	7,9	0,17	27,16	0,99	0,15
03:00 22-06-2026	27,24	5,82	7,93	0,17	26,79	0,86	0
04:00 22-06-2026	28,27	5,75	7,96	0,18	26,4	0,3	0,37
05:00 22-06-2026	29,23	5,66	7,98	0,18	25,94	1,24	0
06:00 22-06-2026	30,26	5,58	8	0,18	25,55	1,74	0,2
07:00 22-06-2026	29,64	5,66	7,97	0,19	25,64	2,26	57,38
08:00 22-06-2026	22,92	8,26	7,39	0,21	31,05	104,08	154,5
09:00 22-06-2026	23,36	9,02	7,41	0,2	31,48	119,98	125,24
10:00 22-06-2026	25,3	10,96	7,4	0,2	31,7	116,16	96,12
11:00 22-06-2026	25,8	9,93	7,4	0,2	31,85	115,26	116,1
12:00 22-06-2026	26,98	10,04	7,38	0,21	31,95	117,87	161,75
13:00 22-06-2026	29	11,38	7,36	0,21	31,96	140,23	151,83
14:00 22-06-2026	23,96	10,68	7,35	0,2	32,03	111,12	124,65
15:00 22-06-2026	24,56	9,31	7,34	0,2	32,02	123,93	148,69
16:00 22-06-2026	26,65	10,09	7,32	0,2	31,96	122,93	81,41
17:00 22-06-2026	28,8	10,72	7,31	0,19	31,91	114,22	111,99
18:00 22-06-2026	31,21	12,38	7,3	0,18	31,81	110,02	94,59
19:00 22-06-2026	29,58	11,87	7,35	0,17	31,75	112,52	56,88
20:00 22-06-2026	28,98	10,57	7,44	0,16	31,66	27,29	0
21:00 22-06-2026	30,63	9,67	7,52	0,18	31,57	6,47	0,2
22:00 22-06-2026	32,67	8,99	7,6	0,17	31,47	0,25	0
23:00 22-06-2026	34,84	8,46	7,67	0,17	31,37	0	0
00:00 23-06-2026	37,2	8,09	7,72	0,17	31,26	0	0
01:00 23-06-2026	39,53	7,79	7,77	0,18	31,14	0	1,39
02:00 23-06-2026	41,94	7,54	7,81	0,17	31,01	0	0
03:00 23-06-2026	44,3	7,31	7,85	0,17	30,92	0	0
04:00 23-06-2026	46,6	7,2	7,89	0,17	30,83	0	0
05:00 23-06-2026	48,96	7,06	7,92	0,18	30,75	0	0
06:00 23-06-2026	51,25	6,87	7,95	0,18	30,68	0	0
07:00 23-06-2026	49,11	6,9	7,9	0,19	30,69	0	55,87
08:00 23-06-2026	5,31	9,72	7,26	0,2	30,89	52,89	157,74
09:00 23-06-2026	6,8	10,72	7,33	0,22	31,43	103,78	79,66
10:00 23-06-2026	8,29	11,01	7,39	0,26	31,77	106,32	147,16
11:00 23-06-2026	9,08	10,79	7,37	0,27	31,93	108,74	77,66
12:00 23-06-2026	9,41	10,09	7,32	0,25	32,25	99,86	145,35

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
13:00 23-06-2026	10,04	10,41	7,28	0,22	32,32	119,76	123,33
14:00 23-06-2026	10,73	10,77	7,27	0,2	32,4	123,36	108,83
15:00 23-06-2026	11,26	10,81	7,28	0,2	32,37	103,59	115,57
16:00 23-06-2026	11,9	10,5	7,3	0,2	32,38	117,34	153,89
17:00 23-06-2026	13,12	11,29	7,31	0,2	32,31	119,1	74,09
18:00 23-06-2026	13,42	11,19	7,33	0,2	32,2	109,54	133,94
19:00 23-06-2026	14,46	11,08	7,37	0,19	32,19	102,62	12,35
20:00 23-06-2026	14,9	9,38	7,44	0,19	32,2	10,74	0
21:00 23-06-2026	15,74	8,43	7,52	0,19	32,2	2,65	0
22:00 23-06-2026	16,64	7,94	7,59	0,19	32,17	0	0
23:00 23-06-2026	17,64	7,37	7,65	0,19	32,11	0	0
00:00 24-06-2026	18,56	6,97	7,71	0,19	32,02	0	0,16
01:00 24-06-2026	19,6	6,68	7,76	0,19	31,96	0	0
02:00 24-06-2026	20,69	6,4	7,82	0,2	31,86	0	0
03:00 24-06-2026	21,82	6,22	7,86	0,2	31,75	0	0
04:00 24-06-2026	22,83	6,06	7,9	0,2	31,64	0	0
05:00 24-06-2026	23,99	5,9	7,94	0,2	31,52	0	0
06:00 24-06-2026	25,02	5,78	7,97	0,2	31,52	0	0
07:00 24-06-2026	22,11	6,07	7,88	0,2	31,71	0,83	55,23
08:00 24-06-2026	2,86	8,54	7,34	0,19	31,33	69,37	163,89
09:00 24-06-2026	3,36	9,64	7,4	0,19	31,82	109,15	106,01
10:00 24-06-2026	3,92	9,78	7,42	0,19	32,15	93,37	77,53
11:00 24-06-2026	4,4	9,2	7,43	0,19	32,46	86,16	77,33
12:00 24-06-2026	5,06	8,91	7,42	0,2	32,79	76,68	90,88
13:00 24-06-2026	5,98	9,02	7,4	0,2	32,94	101,13	150,33
14:00 24-06-2026	7,26	9,63	7,36	0,19	32,87	110,5	75,24
15:00 24-06-2026	8,03	9,71	7,33	0,19	32,93	105,67	149,22
16:00 24-06-2026	9,11	9,94	7,3	0,19	32,89	124,28	113,62
17:00 24-06-2026	10,01	10,12	7,28	0,18	32,83	109,09	127,33
18:00 24-06-2026	10,62	9,7	7,28	0,18	32,72	115,92	92,92
19:00 24-06-2026	11,33	8,45	7,33	0,18	32,78	109,36	50,63
20:00 24-06-2026	12,18	7,73	7,42	0,18	32,89	15,2	0,2
21:00 24-06-2026	12,93	7,18	7,5	0,18	32,92	3,62	0,19
22:00 24-06-2026	13,93	6,76	7,57	0,18	32,92	0	0
23:00 24-06-2026	14,91	6,47	7,64	0,18	32,88	0	0
00:00 25-06-2026	15,82	6,29	7,7	0,18	32,85	0	0
01:00 25-06-2026	17,01	6,13	7,75	0,18	32,77	0	0
02:00 25-06-2026	17,88	5,99	7,8	0,18	32,65	0	0
03:00 25-06-2026	18,96	5,84	7,85	0,18	32,57	0	0,59
04:00 25-06-2026	20,02	5,72	7,89	0,18	32,46	0	0
05:00 25-06-2026	21,02	5,63	7,92	0,18	32,34	0	0
06:00 25-06-2026	21,98	5,59	7,95	0,18	32,32	0	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
07:00 25-06-2026	21,56	5,63	7,92	0,18	32,47	0	41,4
08:00 25-06-2026	7,1	7,73	7,29	0,18	31,92	62,2	162,9
09:00 25-06-2026	8,27	9,53	7,29	0,19	32,36	116,28	119,03
10:00 25-06-2026	8,47	9,38	7,3	0,19	32,6	101,76	105,22
11:00 25-06-2026	8,85	9	7,29	0,19	32,92	120,2	117,38
12:00 25-06-2026	9,48	9,16	7,26	0,19	33,11	99,46	76,28
13:00 25-06-2026	9,94	8,78	7,24	0,19	33,29	98,83	149,98
14:00 25-06-2026	10,92	9,24	7,2	0,18	33,16	111,61	88,69
15:00 25-06-2026	11,35	9,11	7,19	0,18	33,16	112,53	154,29
16:00 25-06-2026	12,18	9,78	7,17	0,18	33,15	125,94	93,24
17:00 25-06-2026	12,78	9,74	7,16	0,18	33,1	106	99,59
18:00 25-06-2026	13,15	9,42	7,16	0,18	33,02	91,84	86,5
19:00 25-06-2026	13,9	8,25	7,21	0,17	33,05	46,87	0,14
20:00 25-06-2026	14,67	7,61	7,29	0,17	33,18	4,96	0
21:00 25-06-2026	15,86	7,24	7,37	0,17	33,26	0,84	0
22:00 25-06-2026	17,06	6,88	7,44	0,17	33,28	0	0
23:00 25-06-2026	18,19	6,57	7,51	0,17	33,28	0	0
00:00 26-06-2026	19,49	6,33	7,57	0,17	33,23	0	0
01:00 26-06-2026	20,77	6,2	7,63	0,17	33,15	0	0
02:00 26-06-2026	22,12	6,03	7,68	0,17	33,05	0	0,22
03:00 26-06-2026	23,49	5,92	7,73	0,17	32,94	0	0,18
04:00 26-06-2026	24,88	5,84	7,77	0,17	32,83	0	0,2
05:00 26-06-2026	26,26	5,75	7,81	0,18	32,68	0	0
06:00 26-06-2026	27,48	5,66	7,84	0,18	32,57	0	0,22
07:00 26-06-2026	29,08	6,38	7,73	0,18	32,38	0,44	55,85
08:00 26-06-2026	30,04	8,4	7,2	0,2	31,85	84,81	144,61
09:00 26-06-2026	30,64	41,49	7,22	6,38	32,05	113,49	109,08
10:00 26-06-2026	30,42	50,52	7,23	16,61	32,16	110	108,05
11:00 26-06-2026	29,91	121,38	7,21	30,02	32,18	97,23	80,4
12:00 26-06-2026	29,74	132,78	7,2	40,88	32,23	93,32	127,86
13:00 26-06-2026	29,51	110,11	7,19	35,33	32,31	110,28	92,3
14:00 26-06-2026	29,52	17,93	7,18	0,76	32,26	104,55	119,48
15:00 26-06-2026	7,25	21,71	7,17	0,74	32,2	129,32	111,29
16:00 26-06-2026	6,02	21,76	7,17	0,74	32,15	104,69	110,78
17:00 26-06-2026	7,13	22,55	7,18	0,75	32,08	122,5	109,05
18:00 26-06-2026	8,29	23,87	7,18	0,76	32,01	111,09	127,96
19:00 26-06-2026	9,43	17,36	7,2	0,77	31,87	77,11	12,47
20:00 26-06-2026	10,44	13,71	7,27	0,78	31,67	9,47	0
21:00 26-06-2026	11,48	10,98	7,34	0,8	31,5	3,9	0,17
22:00 26-06-2026	12,47	8,69	7,4	0,8	31,32	0,15	0
23:00 26-06-2026	13,67	7,38	7,46	0,8	31,14	0	0
00:00 27-06-2026	15	5,69	7,51	0,81	30,97	0	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
01:00 27-06-2026	16,17	4,67	7,56	0,82	30,81	0	0
02:00 27-06-2026	17,56	4,03	7,61	0,83	30,64	0	0,42
03:00 27-06-2026	18,65	2,99	7,66	0,84	30,53	0	0
04:00 27-06-2026	20,01	3,54	7,7	0,84	30,42	0	0
05:00 27-06-2026	21,28	1,86	7,73	0,84	30,26	0	0
06:00 27-06-2026	22,54	1,22	7,77	0,84	30,09	0	0
07:00 27-06-2026	23,78	0,94	7,8	0,85	30,01	0	14,11
08:00 27-06-2026	13,01	13,07	7,29	0,85	31,11	59,63	157,89
09:00 27-06-2026	13,55	28,23	7,24	0,85	31,57	131,16	122,17
10:00 27-06-2026	14,21	25,98	7,14	0,88	31,72	111,99	108,57
11:00 27-06-2026	14,41	21,18	7,13	0,89	31,88	127,42	113,73
12:00 27-06-2026	15,31	21,54	7,11	0,92	31,99	120,05	112,24
13:00 27-06-2026	15,96	21,38	7,11	0,96	32,25	104,3	124,46
14:00 27-06-2026	17	23,98	7,09	0,99	32,2	102,5	110,16
15:00 27-06-2026	17,84	21,4	7,1	1,01	32,25	110,35	109,2
16:00 27-06-2026	19,11	22,97	7,11	1,04	32,28	101,3	109,7
17:00 27-06-2026	20,49	25,54	7,11	0,99	32,24	105,28	82,08
18:00 27-06-2026	17,68	22,92	7,11	0,89	32,1	86,24	70,24
19:00 27-06-2026	8,62	19,46	7,2	0,77	31,78	60,59	0
20:00 27-06-2026	9,94	16,43	7,29	0,69	31,67	7,75	0,39
21:00 27-06-2026	11,24	14,37	7,39	0,64	31,56	3,79	0,25
22:00 27-06-2026	12,78	12,68	7,47	0,61	31,43	0	0
23:00 27-06-2026	14,29	11,33	7,54	0,58	31,33	0	0
00:00 28-06-2026	15,95	10,14	7,61	0,56	31,25	0	0
01:00 28-06-2026	17,95	9,11	7,66	0,56	31,15	0	0
02:00 28-06-2026	19,58	8,22	7,72	0,56	31,04	0	0
03:00 28-06-2026	21,29	7,46	7,77	0,56	30,95	0	0
04:00 28-06-2026	23,1	6,78	7,81	0,57	30,88	0	0
05:00 28-06-2026	24,97	6,17	7,85	0,58	30,8	0	0
06:00 28-06-2026	26,42	5,63	7,89	0,59	30,75	0	0
07:00 28-06-2026	27,98	5,14	7,91	0,6	30,79	0	28,11
08:00 28-06-2026	23,88	16,58	7,14	0,56	31,29	67,24	166,35
09:00 28-06-2026	22,97	24,66	7,14	0,75	31,8	128,54	108,5
10:00 28-06-2026	23,14	23,97	7,19	0,84	32,02	110,32	141,95
11:00 28-06-2026	23,87	22,49	7,2	0,84	32,31	101,34	78,81
12:00 28-06-2026	24,4	20,24	7,2	0,77	32,38	84,35	112,21
13:00 28-06-2026	25,09	20,73	7,21	0,72	32,23	116,79	159,31
14:00 28-06-2026	25,69	21,65	7,19	0,7	32,16	128,5	85,89
15:00 28-06-2026	27,05	26,73	7,18	0,72	32,1	110,67	147,22
16:00 28-06-2026	28	26,98	7,18	0,71	32,06	132,84	79,84
17:00 28-06-2026	28,84	21,82	7,24	0,68	31,77	67,85	0,37
18:00 28-06-2026	29,8	17,11	7,36	0,67	31,7	7,63	0

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
19:00 28-06-2026	30,89	13,71	7,39	0,66	31,63	1,37	0
20:00 28-06-2026	31,91	11,1	7,49	0,66	31,51	0	0
21:00 28-06-2026	33,03	8,96	7,58	0,65	31,37	0,14	0
22:00 28-06-2026	34,3	7,31	7,65	0,65	31,23	0	0
23:00 28-06-2026	35,48	5,91	7,72	0,65	31,11	0	0,17
00:00 29-06-2026	36,69	4,78	7,77	0,66	30,98	0	0,46
01:00 29-06-2026	38	3,85	7,82	0,66	30,85	0	0
02:00 29-06-2026	39,48	3,08	7,86	0,67	30,75	0	0
03:00 29-06-2026	40,71	2,39	7,9	0,67	30,64	0	0
04:00 29-06-2026	41,94	1,81	7,93	0,68	30,53	0	0,2
05:00 29-06-2026	43,24	1,28	7,96	0,68	30,42	0	0
06:00 29-06-2026	44,62	0,83	7,98	0,69	30,31	0	0
07:00 29-06-2026	38,89	4,39	7,82	0,71	30,32	0	56,76
08:00 29-06-2026	3,69	16,61	7,16	0,84	31,01	101,85	160,33
09:00 29-06-2026	4,37	21,2	7,19	0,83	31,34	114,88	96,58
10:00 29-06-2026	5,94	27,88	7,21	0,83	31,47	129,37	164,38
11:00 29-06-2026	7,67	27,5	7,23	0,82	31,49	126,3	80,69
12:00 29-06-2026	8,08	18,47	7,32	0,82	31,35	101,96	135,84
13:00 29-06-2026	8,88	13,22	7,42	0,82	31,38	116,77	119,2
14:00 29-06-2026	9,85	9,5	7,49	0,83	31,47	93,55	113,62
15:00 29-06-2026	11,84	16,6	7,34	0,84	31,79	111,46	99,1
16:00 29-06-2026	13,58	26,05	7,13	0,85	32,06	107,64	133,13
17:00 29-06-2026	14,74	27,51	7,12	0,86	32,03	108,49	99,37
18:00 29-06-2026	15,91	29,83	7,13	0,87	31,94	109,48	99,11
19:00 29-06-2026	17,06	31,75	7,14	0,88	31,88	110,5	146,43
20:00 29-06-2026	12,99	27	7,2	0,87	31,79	128,66	26,46
21:00 29-06-2026	13,2	19,28	7,29	0,88	31,71	25,84	0
22:00 29-06-2026	13,66	14,2	7,38	0,88	31,63	1,8	0
23:00 29-06-2026	14,6	10,64	7,47	0,89	31,56	0	0
00:00 30-06-2026	15,75	7,96	7,55	0,9	31,44	0	0
01:00 30-06-2026	17,01	5,95	7,62	0,9	31,26	0	0
02:00 30-06-2026	18,25	4,31	7,68	0,9	31,09	0,44	0
03:00 30-06-2026	19,58	2,95	7,73	0,91	30,92	0	0
04:00 30-06-2026	20,83	1,89	7,78	0,91	30,71	0	0
05:00 30-06-2026	22,14	1,04	7,82	0,91	30,48	0	0,15
06:00 30-06-2026	23,49	0,34	7,85	0,91	30,24	0	0
07:00 30-06-2026	21,65	4,62	7,76	0,91	30,18	0	42,57
08:00 30-06-2026	12,89	17,23	7,24	0,88	31,02	94,61	125,64
09:00 30-06-2026	13,08	20,09	7,3	0,87	31,26	109,87	138,66
10:00 30-06-2026	14,8	33,28	7,35	0,86	31,35	141,46	150,34
11:00 30-06-2026	15,83	34,44	7,36	0,86	31,41	120,73	81,11
12:00 30-06-2026	15,8	22,39	7,43	0,85	31,25	99,74	135,92

Thông số	COD (mg/L)	TSS (mg/L)	pH	Amoni (mg/L)	Nhiệt độ (°C)	Lưu lượng ra (m ³ /h)	Lưu lượng vào (m ³ /h)
Giới hạn cho phép theo GPMT	67,5	45	6 đến 9	4,5	40	-	-
13:00 30-06-2026	15,82	15,14	7,5	0,86	31,12	132,85	140,89
14:00 30-06-2026	17,09	21,24	7,3	0,85	31,43	114,6	141,15
15:00 30-06-2026	17,59	23,78	7,2	0,82	31,65	115,15	100,11
16:00 30-06-2026	17,96	22,16	7,21	0,82	31,71	99,65	127,58
17:00 30-06-2026	19,49	28,29	7,21	0,83	31,68	120,95	119,51
18:00 30-06-2026	21,28	32,46	7,27	0,84	31,58	94,66	106,5
19:00 30-06-2026	19,69	24,3	7,35	0,85	31,48	111,34	126,31
20:00 30-06-2026	4,17	19,68	7,43	0,86	31,36	107,67	13,31
21:00 30-06-2026	4,67	14,98	7,5	0,86	31,28	15,17	0
22:00 30-06-2026	5,43	11,34	7,57	0,86	31,2	0,85	0
23:00 30-06-2026	6,19	8,63	7,63	0,87	31,13	0	0

(Ghi chú: ngày 01/6/2026 và ngày 26/6/2026: Kiểm định thiết bị đo tại trạm quan trắc nước thải định kỳ năm 2026)