

KẾT QUẢ ONLINE TRẠM QTTĐ KCN KHAI QUANG THÁNG 7/2026

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
		mg/L	mg/L	-	oC	m3/h	mg/L	m3/h
1	2026-07-01 00:00:00	3,26	43,27	6,70	31,56	479,78	1,53	482,86
2	2026-07-01 01:00:00	5,90	42,81	6,86	31,55	606,77	1,61	710,22
3	2026-07-01 02:00:00	2,92	42,71	6,75	31,53	777,90	1,48	405,89
4	2026-07-01 03:00:00	2,57	42,40	6,66	31,50	524,32	1,43	751,44
5	2026-07-01 04:00:00	1,79	41,53	6,71	31,44	422,86	1,44	334,14
6	2026-07-01 05:00:00	5,11	45,25	6,85	31,44	383,22	1,67	763,46
7	2026-07-01 06:00:00	5,35	43,20	6,75	31,43	406,48	1,44	735,35
8	2026-07-01 07:00:00	2,08	35,40	5,70	26,16	467,11	1,21	7,22
9	2026-07-01 08:00:00	3,24	42,57	6,78	31,38	162,25	1,44	919,90
10	2026-07-01 09:00:00	2,31	39,64	6,27	28,75	300,40	1,46	459,73
11	2026-07-01 10:00:00	6,17	20,79	6,76	31,39	729,01	1,46	182,71
12	2026-07-01 11:00:00	2,24	6,73	6,78	31,48	545,03	1,40	280,90
13	2026-07-01 12:00:00	2,27	9,24	6,85	31,49	634,60	1,44	84,54
14	2026-07-01 13:00:00	7,25	11,26	6,75	31,58	434,81	1,55	895,06
15	2026-07-01 14:00:00	2,36	9,06	6,16	28,93	738,47	1,33	364,05
16	2026-07-01 15:00:00	5,21	9,90	6,72	31,62	653,44	1,41	575,00
17	2026-07-01 16:00:00	3,26	8,79	6,21	29,07	564,05	1,34	177,48
18	2026-07-01 17:00:00	4,41	10,25	5,73	26,46	609,18	1,35	618,39
19	2026-07-01 18:00:00	2,64	8,49	5,53	26,46	494,97	1,22	926,03
20	2026-07-01 19:00:00	2,52	10,87	6,71	31,69	454,94	1,49	9,11
21	2026-07-01 20:00:00	9,56	12,86	6,72	31,67	440,87	1,48	824,58
22	2026-07-01 21:00:00	4,09	12,48	6,77	31,65	444,59	1,57	675,28
23	2026-07-01 22:00:00	3,19	11,01	6,74	31,64	694,61	1,50	204,01
24	2026-07-01 23:00:00	3,53	10,57	6,64	31,62	506,68	1,45	660,31
25	2026-07-02 00:00:00	3,74	11,25	6,76	31,53	496,93	1,49	113,00
26	2026-07-02 01:00:00	7,41	12,21	6,85	31,53	597,79	1,58	725,41
27	2026-07-02 02:00:00	3,79	11,04	6,77	31,52	753,70	1,47	390,58
28	2026-07-02 03:00:00	4,32	11,17	6,66	31,52	541,93	1,44	714,45
29	2026-07-02 04:00:00	3,73	9,50	5,58	26,22	430,91	1,23	301,55
30	2026-07-02 05:00:00	6,53	13,56	6,85	31,44	608,69	1,61	773,82
31	2026-07-02 06:00:00	6,38	11,40	6,74	31,43	656,93	1,45	711,46
32	2026-07-02 07:00:00	3,90	11,12	6,81	31,41	521,35	1,47	11,50
33	2026-07-02 08:00:00	5,18	11,28	6,75	31,40	123,37	1,46	981,81
34	2026-07-02 09:00:00	5,81	12,20	6,75	31,42	221,68	1,53	744,89
35	2026-07-02 10:00:00	8,62	12,28	6,69	31,44	415,80	1,48	178,28
36	2026-07-02 11:00:00	6,15	10,85	6,76	31,54	511,10	1,42	485,19
37	2026-07-02 12:00:00	6,38	11,64	6,84	31,50	592,46	1,46	108,69
38	2026-07-02 13:00:00	5,28	12,02	6,77	31,54	423,02	1,56	874,21
39	2026-07-02 14:00:00	3,60	11,17	6,81	31,53	735,06	1,47	252,41
40	2026-07-02 15:00:00	6,17	11,35	6,83	31,51	643,99	1,44	354,45
41	2026-07-02 16:00:00	4,67	11,19	6,84	31,49	539,92	1,45	215,41
42	2026-07-02 17:00:00	5,93	13,00	6,93	31,49	612,16	1,58	605,81

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
43	2026-07-02 18:00:00	3,80	10,77	6,69	31,48	475,72	1,42	932,80
44	2026-07-02 19:00:00	2,92	10,89	6,75	31,44	743,31	1,44	11,43
45	2026-07-02 20:00:00	7,12	11,17	6,15	28,55	563,38	1,30	603,13
46	2026-07-02 21:00:00	4,72	12,27	6,83	31,41	284,34	1,52	684,45
47	2026-07-02 22:00:00	3,40	11,08	6,80	31,37	510,37	1,46	193,20
48	2026-07-02 23:00:00	3,24	10,41	6,69	31,34	499,08	1,38	773,70
49	2026-07-03 00:00:00	5,62	13,12	6,94	31,30	539,68	1,53	681,05
50	2026-07-03 01:00:00	8,44	11,63	6,76	31,28	734,19	1,44	487,27
51	2026-07-03 02:00:00	2,76	8,91	5,65	26,03	693,40	1,14	284,26
52	2026-07-03 03:00:00	3,47	7,37	3,99	18,20	535,02	0,86	578,30
53	2026-07-03 04:00:00	1,53	6,34	4,02	18,71	576,31	0,83	81,42
54	2026-07-03 05:00:00	3,09	11,02	6,75	31,13	746,49	1,37	453,81
55	2026-07-03 06:00:00	6,26	12,65	6,82	31,11	470,32	1,41	902,44
56	2026-07-03 07:00:00	5,23	13,85	6,96	31,07	604,99	1,53	180,25
57	2026-07-03 08:00:00	3,88	11,73	6,80	31,03	361,50	1,39	882,92
58	2026-07-03 09:00:00	2,83	10,94	6,72	31,06	244,58	1,34	511,54
59	2026-07-03 10:00:00	5,26	11,68	6,78	31,09	367,17	1,36	273,99
60	2026-07-03 11:00:00	5,71	12,76	6,88	31,23	540,75	1,44	853,39
61	2026-07-03 12:00:00	2,99	10,65	6,28	28,64	561,99	1,27	152,26
62	2026-07-03 13:00:00	3,47	9,28	5,59	26,07	532,50	1,13	500,46
63	2026-07-03 14:00:00	3,47	10,22	6,21	28,71	691,60	1,24	313,87
64	2026-07-03 15:00:00	6,58	10,94	5,73	26,17	561,15	1,19	441,63
65	2026-07-03 16:00:00	2,43	8,55	5,12	23,54	722,13	1,02	134,90
66	2026-07-03 17:00:00	3,22	11,43	6,81	31,40	744,30	1,36	405,69
67	2026-07-03 18:00:00	4,45	12,27	6,73	31,40	310,37	1,37	1075,60
68	2026-07-03 19:00:00	5,37	13,57	6,34	28,78	609,78	1,41	294,80
69	2026-07-03 20:00:00	4,65	9,45	5,07	23,52	763,01	1,05	601,10
70	2026-07-03 21:00:00	3,14	10,08	5,63	26,15	691,82	1,12	440,04
71	2026-07-03 22:00:00	3,67	10,53	5,67	26,09	481,67	1,13	279,10
72	2026-07-03 23:00:00	4,84	12,64	6,72	31,30	366,68	1,40	954,01
73	2026-07-04 00:00:00	3,47	11,88	6,65	31,26	716,84	1,36	438,15
74	2026-07-04 01:00:00	8,58	12,81	6,71	31,23	765,94	1,33	487,34
75	2026-07-04 02:00:00	5,18	12,32	6,70	31,20	321,45	1,33	494,24
76	2026-07-04 03:00:00	5,51	12,89	6,70	31,18	283,89	1,36	1051,62
77	2026-07-04 04:00:00	2,91	10,97	6,05	28,32	520,28	1,20	204,97
78	2026-07-04 05:00:00	4,24	11,05	6,15	28,52	788,34	1,21	269,36
79	2026-07-04 06:00:00	8,45	11,48	5,53	25,43	518,30	1,07	556,22
80	2026-07-04 07:00:00	4,16	8,85	3,86	17,28	553,55	0,82	348,94
81	2026-07-04 08:00:00	5,07	12,70	6,74	31,04	406,39	1,33	835,77
82	2026-07-04 09:00:00	4,30	12,16	6,65	31,03	327,50	1,28	331,21
83	2026-07-04 10:00:00	6,17	13,08	6,71	31,05	358,76	1,31	263,35
84	2026-07-04 11:00:00	7,64	13,82	6,79	31,12	555,73	1,39	820,76
85	2026-07-04 12:00:00	4,77	13,17	6,77	31,09	688,73	1,34	55,22
86	2026-07-04 13:00:00	3,88	11,44	6,06	28,52	487,08	1,22	554,09
87	2026-07-04 14:00:00	3,84	8,47	4,48	20,76	599,85	0,89	289,87
88	2026-07-04 15:00:00	9,01	12,87	5,70	26,05	547,28	1,21	569,59

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
89	2026-07-04 16:00:00	2,63	6,62	3,36	15,60	730,64	0,68	114,69
90	2026-07-04 17:00:00	5,31	12,54	6,74	31,13	733,02	1,32	401,76
91	2026-07-04 18:00:00	5,98	13,31	6,62	31,19	322,46	1,37	1093,41
92	2026-07-04 19:00:00	7,30	15,75	6,81	31,24	600,43	1,55	350,32
93	2026-07-04 20:00:00	8,03	14,01	6,64	31,16	734,72	1,41	703,03
94	2026-07-04 21:00:00	4,57	11,07	5,52	25,94	284,72	1,12	366,55
95	2026-07-04 22:00:00	5,96	13,56	6,69	31,10	354,61	1,37	270,18
96	2026-07-04 23:00:00	6,15	12,29	6,12	28,50	121,43	1,31	909,98
97	2026-07-05 00:00:00	4,28	12,51	6,65	31,04	757,06	1,37	293,77
98	2026-07-05 01:00:00	10,81	14,35	6,64	31,02	793,02	1,36	553,86
99	2026-07-05 02:00:00	5,13	13,41	6,72	31,00	570,02	1,35	227,80
100	2026-07-05 03:00:00	8,63	15,21	6,76	31,03	507,28	1,49	694,67
101	2026-07-05 04:00:00	4,18	12,75	6,61	30,95	478,99	1,38	272,81
102	2026-07-05 05:00:00	4,01	12,60	6,66	30,91	599,94	1,36	397,72
103	2026-07-05 06:00:00	8,34	11,86	5,46	25,27	466,82	1,11	829,30
104	2026-07-05 07:00:00	7,37	15,29	6,86	30,94	611,76	1,55	354,11
105	2026-07-05 08:00:00	5,34	14,10	6,65	30,85	529,06	1,38	710,74
106	2026-07-05 09:00:00	4,26	13,35	6,56	30,83	252,47	1,33	682,04
107	2026-07-05 10:00:00	3,62	13,24	6,60	30,84	642,37	1,35	12,21
108	2026-07-05 11:00:00	4,10	13,60	6,61	30,89	608,62	1,37	392,21
109	2026-07-05 12:00:00	6,31	14,01	6,58	31,01	537,38	1,34	769,53
110	2026-07-05 13:00:00	4,59	13,83	6,67	31,22	671,24	1,36	2,81
111	2026-07-05 14:00:00	4,34	11,21	5,02	23,48	309,97	1,03	255,03
112	2026-07-05 15:00:00	5,22	15,44	6,54	31,35	51,03	1,39	1027,79
113	2026-07-05 16:00:00	5,97	15,57	6,58	31,37	527,22	1,38	5,46
114	2026-07-05 17:00:00	6,09	15,58	6,59	31,38	472,82	1,37	354,02
115	2026-07-05 18:00:00	10,70	16,42	6,65	31,41	108,55	1,38	801,40
116	2026-07-05 19:00:00	10,85	17,24	6,89	31,49	522,76	1,53	347,18
117	2026-07-05 20:00:00	8,17	15,82	6,59	31,37	663,89	1,41	430,72
118	2026-07-05 21:00:00	5,53	14,23	5,95	28,73	607,68	1,27	218,75
119	2026-07-05 22:00:00	5,34	14,40	5,97	28,48	344,18	1,26	133,78
120	2026-07-05 23:00:00	10,98	17,32	6,64	31,35	357,09	1,42	987,13
121	2026-07-06 00:00:00	6,23	16,37	6,59	31,32	748,81	1,38	247,54
122	2026-07-06 01:00:00	6,24	16,47	6,51	31,26	398,35	1,50	561,86
123	2026-07-06 02:00:00	7,02	16,44	6,57	31,24	536,91	1,43	417,53
124	2026-07-06 03:00:00	11,68	19,05	6,73	31,29	433,86	1,48	609,09
125	2026-07-06 04:00:00	6,62	13,88	5,44	26,00	292,93	1,15	263,58
126	2026-07-06 05:00:00	6,57	13,67	5,49	25,98	320,84	1,20	315,62
127	2026-07-06 06:00:00	8,69	16,15	5,89	28,01	109,77	1,61	845,09
128	2026-07-06 07:00:00	11,10	18,99	6,68	31,15	0,15	1,83	237,04
129	2026-07-06 08:00:00	8,59	18,52	6,58	31,11	0,44	1,72	9,10
130	2026-07-06 09:00:00	11,83	17,41	5,96	28,51	198,59	1,32	375,50
131	2026-07-06 10:00:00	7,94	16,53	5,97	28,28	383,85	1,26	14,71
132	2026-07-06 11:00:00	9,13	18,59	6,63	31,12	291,92	1,39	9,17
133	2026-07-06 12:00:00	9,58	19,55	6,74	31,12	313,82	1,42	4,15
134	2026-07-06 13:00:00	9,75	19,85	6,77	31,18	467,36	1,43	0,67

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
135	2026-07-06 14:00:00	11,94	20,44	6,72	31,25	549,14	1,44	472,87
136	2026-07-06 15:00:00	14,21	20,50	6,64	31,24	483,90	1,40	576,24
137	2026-07-06 16:00:00	13,41	20,13	6,69	31,18	576,14	1,39	8,02
138	2026-07-06 17:00:00	11,51	20,54	6,69	31,29	457,52	1,40	368,97
139	2026-07-06 18:00:00	15,96	19,05	5,52	26,16	187,45	1,16	723,08
140	2026-07-06 19:00:00	16,02	23,18	6,84	31,44	614,82	1,57	325,25
141	2026-07-06 20:00:00	16,56	22,62	6,75	31,33	701,91	1,46	217,06
142	2026-07-06 21:00:00	15,01	20,74	6,09	28,69	542,57	1,27	437,82
143	2026-07-06 22:00:00	11,72	21,47	6,73	31,26	644,14	1,41	104,29
144	2026-07-06 23:00:00	13,99	22,44	6,80	31,24	534,60	1,66	718,71
145	2026-07-07 00:00:00	11,86	21,94	6,61	31,19	433,49	1,68	1226,52
146	2026-07-07 01:00:00	11,97	22,12	6,63	31,17	749,28	1,54	20,51
147	2026-07-07 02:00:00	14,83	23,24	6,68	31,12	490,47	1,48	470,72
148	2026-07-07 03:00:00	18,29	24,48	6,67	31,10	250,95	1,46	1063,91
149	2026-07-07 04:00:00	16,17	21,39	6,04	28,48	486,86	1,29	16,85
150	2026-07-07 05:00:00	20,40	23,66	6,62	31,01	430,74	1,73	421,34
151	2026-07-07 06:00:00	20,58	24,06	6,61	30,97	227,86	1,89	1050,19
152	2026-07-07 07:00:00	22,25	24,57	6,79	30,99	610,49	1,62	358,75
153	2026-07-07 08:00:00	21,41	25,98	6,62	30,93	773,88	1,74	388,90
154	2026-07-07 09:00:00	23,02	25,01	6,02	28,36	263,71	1,52	499,13
155	2026-07-07 10:00:00	13,21	25,58	6,65	31,01	414,20	1,44	101,01
156	2026-07-07 11:00:00	21,77	25,39	6,76	31,23	508,23	1,94	709,03
157	2026-07-07 12:00:00	4,80	26,50	6,54	31,18	431,71	2,17	933,79
158	2026-07-07 13:00:00	3,69	27,65	6,58	31,25	756,42	2,11	11,08
159	2026-07-07 14:00:00	4,50	28,92	6,62	31,38	594,33	2,00	396,80
160	2026-07-07 15:00:00	4,61	25,84	6,09	28,90	349,43	1,43	707,42
161	2026-07-07 16:00:00	1,92	21,60	5,14	24,56	790,03	1,15	4,67
162	2026-07-07 17:00:00	2,69	28,50	6,64	31,62	621,16	2,02	329,55
163	2026-07-07 18:00:00	5,14	32,10	6,65	31,64	225,42	2,82	1132,71
164	2026-07-07 19:00:00	6,04	33,11	6,80	31,68	338,39	1,99	358,46
165	2026-07-07 20:00:00	4,69	30,01	6,04	28,78	519,94	2,42	402,89
166	2026-07-07 21:00:00	5,11	26,90	5,47	26,40	257,37	1,65	718,52
167	2026-07-07 22:00:00	3,34	31,59	6,61	31,65	596,46	1,68	80,84
168	2026-07-07 23:00:00	6,73	34,06	6,81	31,67	454,90	1,93	490,84
169	2026-07-08 00:00:00	6,42	35,52	6,59	31,56	423,14	2,60	757,47
170	2026-07-08 01:00:00	5,71	35,80	6,63	31,53	740,57	2,57	25,93
171	2026-07-08 02:00:00	8,22	36,78	6,63	31,52	594,29	2,40	776,11
172	2026-07-08 03:00:00	4,82	32,90	6,10	28,95	513,55	1,62	653,23
173	2026-07-08 04:00:00	3,79	34,72	6,60	31,53	600,74	1,60	71,49
174	2026-07-08 05:00:00	6,41	36,75	6,57	31,48	232,58	2,62	963,88
175	2026-07-08 06:00:00	5,31	36,50	6,65	31,47	460,11	2,63	455,11
176	2026-07-08 07:00:00	5,53	36,30	6,61	31,49	635,18	1,61	579,26
177	2026-07-08 08:00:00	4,76	35,95	6,59	31,49	603,95	1,69	332,46
178	2026-07-08 09:00:00	4,36	37,12	6,61	31,47	726,09	2,04	298,30
179	2026-07-08 10:00:00	4,31	34,96	5,95	28,43	489,40	2,17	483,65
180	2026-07-08 11:00:00	4,39	38,30	6,81	31,81	338,18	2,12	661,66

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
181	2026-07-08 12:00:00	4,52	37,20	6,56	31,75	491,55	2,28	894,29
182	2026-07-08 13:00:00	2,95	37,44	6,61	31,80	643,49	2,00	33,95
183	2026-07-08 14:00:00	3,54	38,43	6,62	31,92	484,47	2,14	786,32
184	2026-07-08 15:00:00	3,57	35,92	6,02	28,89	417,48	1,84	676,43
185	2026-07-08 16:00:00	4,67	40,46	6,62	32,05	635,44	2,36	70,27
186	2026-07-08 17:00:00	8,59	40,17	6,54	32,07	775,51	2,12	777,58
187	2026-07-08 18:00:00	4,63	40,07	6,64	32,06	597,00	2,38	333,45
188	2026-07-08 19:00:00	4,25	40,65	6,72	32,05	397,10	2,15	919,02
189	2026-07-08 20:00:00	4,13	40,45	6,61	32,02	471,49	2,30	451,66
190	2026-07-08 21:00:00	4,67	26,98	4,37	21,35	576,59	1,06	603,27
191	2026-07-08 22:00:00	4,14	33,22	5,42	26,09	563,45	1,23	242,21
192	2026-07-08 23:00:00	5,18	40,83	6,79	31,91	612,25	1,70	649,38
193	2026-07-09 00:00:00	4,97	41,64	6,55	31,84	532,45	1,86	713,93
194	2026-07-09 01:00:00	3,79	41,42	6,59	31,79	643,33	1,80	52,62
195	2026-07-09 02:00:00	7,27	42,68	6,60	31,75	730,76	1,70	784,89
196	2026-07-09 03:00:00	4,76	41,79	6,67	31,79	525,03	1,52	800,93
197	2026-07-09 04:00:00	3,80	34,72	5,51	26,42	690,33	1,20	43,68
198	2026-07-09 05:00:00	5,99	35,79	5,44	26,37	502,32	1,67	986,74
199	2026-07-09 06:00:00	5,59	38,87	6,03	28,73	320,06	1,81	535,22
200	2026-07-09 07:00:00	10,24	43,09	6,74	31,64	337,47	1,58	803,80
201	2026-07-09 08:00:00	7,52	42,26	6,58	31,57	499,86	1,47	458,05
202	2026-07-09 09:00:00	7,19	43,28	6,55	31,54	475,65	1,55	639,11
203	2026-07-09 10:00:00	6,34	38,51	6,60	31,49	423,08	1,99	527,97
204	2026-07-09 11:00:00	28,03	16,80	6,28	28,70	618,17	1,51	379,70
205	2026-07-09 12:00:00	5,65	13,56	5,97	28,63	752,36	1,35	417,91
206	2026-07-09 13:00:00	2,01	13,94	6,58	31,50	749,59	1,40	43,62
207	2026-07-09 14:00:00	3,40	14,28	6,59	31,48	515,33	1,53	815,73
208	2026-07-09 15:00:00	6,96	14,98	6,63	31,52	447,10	1,71	792,03
209	2026-07-09 16:00:00	6,94	16,70	6,59	31,40	799,28	2,05	80,04
210	2026-07-09 17:00:00	13,70	15,63	5,98	28,82	714,55	1,61	824,87
211	2026-07-09 18:00:00	8,89	16,32	6,62	31,43	539,44	1,97	582,24
212	2026-07-09 19:00:00	11,36	15,56	6,68	31,42	496,23	1,94	945,67
213	2026-07-09 20:00:00	9,75	16,70	6,56	31,36	733,83	2,07	459,46
214	2026-07-09 21:00:00	13,05	16,85	6,49	31,34	595,57	2,02	716,98
215	2026-07-09 22:00:00	13,01	16,28	6,57	31,31	614,11	1,63	406,55
216	2026-07-09 23:00:00	10,50	10,09	4,92	22,77	412,77	1,44	593,63
217	2026-07-10 00:00:00	10,20	15,49	5,77	27,78	273,33	2,13	917,10
218	2026-07-10 01:00:00	11,12	17,95	6,56	31,22	469,91	2,10	53,15
219	2026-07-10 02:00:00	15,24	18,55	6,57	31,19	319,66	1,97	739,51
220	2026-07-10 03:00:00	15,04	16,43	6,71	31,22	205,54	1,59	563,39
221	2026-07-10 04:00:00	12,57	16,51	6,59	31,17	410,49	1,47	75,98
222	2026-07-10 05:00:00	12,81	15,93	5,37	25,95	465,57	1,38	553,05
223	2026-07-10 06:00:00	16,79	13,68	5,62	25,45	564,67	1,40	337,04
224	2026-07-10 07:00:00	19,75	16,52	5,99	28,26	610,84	1,42	429,14
225	2026-07-10 08:00:00	7,27	16,36	6,52	31,10	404,93	1,46	348,55
226	2026-07-10 09:00:00	2,80	12,83	4,92	23,31	317,66	1,10	397,03

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
227	2026-07-10 10:00:00	47,10	18,40	6,59	31,15	381,16	1,57	663,19
228	2026-07-10 11:00:00	3,21	17,35	6,57	31,18	773,48	1,49	312,73
229	2026-07-10 12:00:00	6,52	16,71	6,50	31,27	602,18	1,48	539,47
230	2026-07-10 13:00:00	7,95	16,05	6,63	31,36	596,58	1,47	112,95
231	2026-07-10 14:00:00	77,64	17,13	6,70	31,50	529,02	1,58	1085,10
232	2026-07-10 15:00:00	8,72	15,93	5,92	28,88	623,84	1,39	478,44
233	2026-07-10 16:00:00	3,43	15,36	5,41	26,26	765,02	1,27	57,26
234	2026-07-10 17:00:00	12,99	17,73	6,50	31,54	489,60	1,63	935,08
235	2026-07-10 18:00:00	10,38	17,24	6,62	31,54	565,75	1,61	765,94
236	2026-07-10 19:00:00	6,13	18,32	6,43	31,53	562,45	1,55	527,79
237	2026-07-10 20:00:00	5,79	17,64	6,44	31,51	612,91	1,53	364,28
238	2026-07-10 21:00:00	10,22	17,37	6,48	31,46	690,09	1,48	735,96
239	2026-07-10 22:00:00	13,41	17,51	6,65	31,42	517,64	1,61	528,94
240	2026-07-10 23:00:00	6,73	16,78	6,52	31,42	799,43	1,53	394,30
241	2026-07-11 00:00:00	7,59	17,29	6,42	31,42	411,80	1,52	1132,71
242	2026-07-11 01:00:00	6,19	13,21	4,92	23,50	587,38	1,12	101,46
243	2026-07-11 02:00:00	16,12	16,32	6,14	28,70	603,74	1,51	961,77
244	2026-07-11 03:00:00	10,60	13,58	5,47	26,10	625,99	1,20	490,91
245	2026-07-11 04:00:00	5,52	10,06	4,22	19,91	644,10	0,92	52,73
246	2026-07-11 05:00:00	14,70	16,63	6,51	31,27	384,55	1,41	1026,45
247	2026-07-11 06:00:00	17,25	16,34	6,63	31,21	566,07	1,51	743,27
248	2026-07-11 07:00:00	17,77	16,45	6,59	31,24	747,47	1,38	457,89
249	2026-07-11 08:00:00	15,57	15,48	6,60	31,22	448,00	1,33	397,21
250	2026-07-11 09:00:00	16,15	15,59	6,59	31,21	268,19	1,31	764,75
251	2026-07-11 10:00:00	48,68	16,40	6,66	31,30	244,21	1,46	645,15
252	2026-07-11 11:00:00	6,69	15,55	6,63	31,34	803,06	1,36	313,16
253	2026-07-11 12:00:00	6,90	15,52	6,63	31,45	565,47	1,33	606,62
254	2026-07-11 13:00:00	5,41	15,89	6,72	31,45	647,74	1,33	109,88
255	2026-07-11 14:00:00	11,57	16,58	6,79	31,49	505,94	1,51	1006,11
256	2026-07-11 15:00:00	2,51	12,58	5,40	25,82	608,61	1,10	320,89
257	2026-07-11 16:00:00	2,18	15,31	6,62	31,58	732,67	1,34	36,09
258	2026-07-11 17:00:00	10,40	16,61	6,58	31,59	489,73	1,32	881,62
259	2026-07-11 18:00:00	3,84	16,41	6,64	31,59	567,22	1,43	731,51
260	2026-07-11 19:00:00	3,55	15,79	6,56	31,58	636,44	1,33	543,34
261	2026-07-11 20:00:00	3,73	15,63	6,54	31,57	697,66	1,32	388,29
262	2026-07-11 21:00:00	7,28	16,10	6,58	31,55	410,82	1,32	766,96
263	2026-07-11 22:00:00	5,26	16,17	6,76	31,46	231,03	1,44	504,52
264	2026-07-11 23:00:00	5,16	15,65	6,62	31,48	650,61	1,36	230,30
265	2026-07-12 00:00:00	2,64	13,99	5,97	28,62	252,22	1,22	1044,09
266	2026-07-12 01:00:00	0,43	2,77	1,13	5,23	731,56	0,22	35,73
267	2026-07-12 02:00:00	4,01	12,37	5,10	23,53	356,07	1,10	767,19
268	2026-07-12 03:00:00	4,49	15,44	6,76	31,39	405,13	1,34	125,18
269	2026-07-12 04:00:00	3,50	13,84	6,25	28,74	547,25	1,22	13,20
270	2026-07-12 05:00:00	2,75	11,62	5,02	23,51	323,03	0,99	821,01
271	2026-07-12 06:00:00	2,49	13,47	5,75	26,06	564,71	1,21	429,95
272	2026-07-12 07:00:00	5,31	5,43	2,01	9,39	662,15	0,39	278,27

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
273	2026-07-12 08:00:00	4,14	15,31	6,76	31,29	464,32	1,31	352,63
274	2026-07-12 09:00:00	4,39	14,62	6,28	28,69	155,08	1,21	295,50
275	2026-07-12 10:00:00	3,36	16,90	6,93	31,32	0,44	1,51	373,14
276	2026-07-12 11:00:00	3,89	14,82	6,33	28,75	390,93	1,32	265,03
277	2026-07-12 12:00:00	2,88	15,78	6,75	31,48	405,85	1,35	406,28
278	2026-07-12 13:00:00	1,96	16,26	6,59	31,64	413,16	1,38	343,54
279	2026-07-12 14:00:00	4,17	15,33	6,23	29,11	593,24	1,46	490,62
280	2026-07-12 15:00:00	1,99	11,88	4,87	23,13	600,40	1,07	116,26
281	2026-07-12 16:00:00	12,81	17,39	6,53	31,89	421,32	1,42	446,63
282	2026-07-12 17:00:00	5,83	16,61	6,59	31,93	720,39	1,42	411,70
283	2026-07-12 18:00:00	3,72	17,20	6,60	31,97	433,18	1,56	830,63
284	2026-07-12 19:00:00	2,79	17,31	6,42	31,90	534,11	1,48	541,55
285	2026-07-12 20:00:00	2,78	16,11	5,91	29,26	741,20	1,35	317,11
286	2026-07-12 21:00:00	4,72	16,73	5,92	29,28	316,43	1,37	648,09
287	2026-07-12 22:00:00	7,72	19,45	6,62	31,79	185,04	1,61	691,47
288	2026-07-12 23:00:00	5,08	18,31	6,52	31,84	771,51	1,50	322,69
289	2026-07-13 00:00:00	3,94	16,46	5,75	28,30	432,90	1,38	397,07
290	2026-07-13 01:00:00	3,64	18,64	6,45	31,74	389,76	1,51	623,87
291	2026-07-13 02:00:00	4,09	18,53	6,65	31,71	609,42	1,64	659,54
292	2026-07-13 03:00:00	4,41	18,45	6,53	31,71	537,96	1,55	342,64
293	2026-07-13 04:00:00	10,01	17,13	5,82	28,52	220,07	1,36	458,04
294	2026-07-13 05:00:00	5,58	18,28	6,50	31,67	320,31	1,49	419,57
295	2026-07-13 06:00:00	4,55	18,90	6,54	31,63	320,90	1,64	788,01
296	2026-07-13 07:00:00	3,48	18,92	6,38	31,61	475,54	1,50	542,52
297	2026-07-13 08:00:00	2,60	17,38	5,92	28,96	592,01	1,38	28,20
298	2026-07-13 09:00:00	3,06	19,62	6,54	31,58	398,84	1,52	145,87
299	2026-07-13 10:00:00	6,10	19,84	6,62	31,63	123,50	1,64	728,92
300	2026-07-13 11:00:00	4,35	19,60	6,61	31,64	641,83	1,64	327,33
301	2026-07-13 12:00:00	3,60	19,99	6,62	31,64	554,91	2,07	514,08
302	2026-07-13 13:00:00	5,12	19,22	6,02	29,13	452,71	1,60	590,83
303	2026-07-13 14:00:00	5,70	20,96	6,76	31,91	611,82	1,68	422,97
304	2026-07-13 15:00:00	5,33	21,00	6,69	31,90	715,83	1,58	263,86
305	2026-07-13 16:00:00	9,26	21,45	6,54	31,94	466,38	1,59	465,15
306	2026-07-13 17:00:00	5,06	18,62	5,90	28,78	585,73	1,42	201,40
307	2026-07-13 18:00:00	3,68	18,85	6,04	29,35	227,02	1,58	802,86
308	2026-07-13 19:00:00	3,76	21,09	6,41	31,97	242,85	1,91	528,94
309	2026-07-13 20:00:00	3,36	17,46	5,41	26,63	500,33	1,50	292,80
310	2026-07-13 21:00:00	4,94	18,87	5,99	29,06	341,30	1,43	432,77
311	2026-07-13 22:00:00	7,02	20,99	6,58	31,93	344,78	1,66	709,06
312	2026-07-13 23:00:00	4,81	20,47	6,56	31,91	795,92	1,61	19,18
313	2026-07-14 00:00:00	4,34	20,44	6,57	31,88	562,86	1,59	53,42
314	2026-07-14 01:00:00	4,76	21,09	6,42	31,82	321,53	1,70	620,01
315	2026-07-14 02:00:00	5,04	20,49	6,67	31,79	607,48	1,68	666,69
316	2026-07-14 03:00:00	5,11	17,86	5,76	27,80	680,83	1,34	535,94
317	2026-07-14 04:00:00	11,57	21,11	6,45	31,75	502,07	1,58	469,86
318	2026-07-14 05:00:00	7,97	20,39	6,54	31,71	605,61	1,55	423,19

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
319	2026-07-14 06:00:00	6,24	20,34	6,63	31,66	424,98	1,59	849,82
320	2026-07-14 07:00:00	4,39	17,42	5,31	26,36	490,46	1,31	552,20
321	2026-07-14 08:00:00	5,54	20,59	6,49	31,60	604,88	1,52	322,30
322	2026-07-14 09:00:00	6,62	20,80	6,60	31,62	513,60	1,47	654,19
323	2026-07-14 10:00:00	7,94	21,13	6,60	31,71	334,27	1,64	733,51
324	2026-07-14 11:00:00	4,93	15,39	4,94	23,82	784,25	1,17	229,39
325	2026-07-14 12:00:00	7,00	20,80	6,55	31,82	507,05	1,48	539,45
326	2026-07-14 13:00:00	6,15	17,57	5,39	26,65	250,27	1,28	572,04
327	2026-07-14 14:00:00	7,45	17,84	5,55	26,81	293,61	1,39	402,59
328	2026-07-14 15:00:00	12,22	22,23	6,49	32,17	362,92	1,57	535,94
329	2026-07-14 16:00:00	13,06	21,52	6,53	32,23	537,23	1,53	445,64
330	2026-07-14 17:00:00	11,50	21,56	6,59	32,29	743,69	1,56	315,93
331	2026-07-14 18:00:00	9,33	21,59	6,74	32,36	423,64	1,70	377,68
332	2026-07-14 19:00:00	8,94	20,93	6,49	32,29	531,68	1,53	544,51
333	2026-07-14 20:00:00	9,83	20,85	6,59	32,31	585,56	1,55	287,99
334	2026-07-14 21:00:00	14,30	21,86	6,62	32,31	293,90	1,60	572,21
335	2026-07-14 22:00:00	13,89	21,59	6,67	32,25	273,85	1,68	689,89
336	2026-07-14 23:00:00	13,12	19,50	6,08	29,57	797,87	1,46	271,23
337	2026-07-15 00:00:00	13,25	21,18	6,67	32,25	503,20	1,59	246,30
338	2026-07-15 01:00:00	12,18	21,33	6,55	32,13	329,33	1,56	546,55
339	2026-07-15 02:00:00	12,76	21,66	6,77	32,10	605,21	1,76	625,21
340	2026-07-15 03:00:00	12,18	21,09	6,67	32,11	722,73	1,62	399,42
341	2026-07-15 04:00:00	16,59	21,03	6,60	32,07	461,06	1,54	465,90
342	2026-07-15 05:00:00	13,47	19,13	6,11	29,38	585,05	1,43	407,18
343	2026-07-15 06:00:00	13,26	20,88	6,72	32,02	253,76	1,67	828,10
344	2026-07-15 07:00:00	12,07	20,44	6,54	31,98	191,19	1,52	535,96
345	2026-07-15 08:00:00	4,57	20,40	6,58	31,97	472,64	1,53	276,43
346	2026-07-15 09:00:00	6,87	20,91	6,65	31,95	555,01	1,55	536,03
347	2026-07-15 10:00:00	13,42	21,12	6,70	32,01	414,27	1,67	693,39
348	2026-07-15 11:00:00	3,05	18,87	6,09	29,15	793,10	1,45	10,09
349	2026-07-15 12:00:00	3,03	15,56	5,06	24,10	513,68	1,18	21,44
350	2026-07-15 13:00:00	7,00	19,60	5,97	29,53	305,35	1,41	612,30
351	2026-07-15 14:00:00	20,83	21,85	6,78	32,34	611,52	1,77	608,71
352	2026-07-15 15:00:00	5,82	19,24	6,00	29,62	714,15	1,46	532,90
353	2026-07-15 16:00:00	9,62	19,38	6,03	29,65	513,05	1,40	447,49
354	2026-07-15 17:00:00	8,11	20,95	6,60	32,39	588,40	1,54	349,17
355	2026-07-15 18:00:00	8,85	21,08	6,65	32,46	444,15	1,65	786,49
356	2026-07-15 19:00:00	8,31	20,76	6,46	32,37	718,04	1,53	322,60
357	2026-07-15 20:00:00	10,06	21,01	6,50	32,38	582,04	1,53	461,70
358	2026-07-15 21:00:00	14,04	21,46	6,61	32,34	330,71	1,53	795,95
359	2026-07-15 22:00:00	12,11	21,96	6,86	32,30	607,04	1,70	359,69
360	2026-07-15 23:00:00	13,59	20,97	6,58	32,28	438,15	1,54	908,02
361	2026-07-16 00:00:00	11,10	20,25	6,54	32,27	453,01	1,51	563,40
362	2026-07-16 01:00:00	13,12	17,74	5,49	26,84	320,05	1,25	334,19
363	2026-07-16 02:00:00	12,70	21,53	6,74	32,21	586,96	1,62	696,86
364	2026-07-16 03:00:00	4,25	6,87	2,23	10,73	759,00	0,51	297,44

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
365	2026-07-16 04:00:00	9,10	15,47	4,84	24,09	480,84	1,09	507,01
366	2026-07-16 05:00:00	10,07	15,37	4,83	23,34	595,01	1,08	385,09
367	2026-07-16 06:00:00	13,61	21,57	6,72	32,08	566,57	1,55	890,57
368	2026-07-16 07:00:00	4,13	20,50	6,68	32,07	771,53	1,47	86,92
369	2026-07-16 08:00:00	5,26	20,62	6,70	32,06	680,13	1,46	558,74
370	2026-07-16 09:00:00	5,77	21,12	6,59	31,98	333,59	1,46	1045,77
371	2026-07-16 10:00:00	3,99	21,95	6,84	31,97	610,31	1,67	377,36
372	2026-07-16 11:00:00	6,37	14,52	4,38	21,29	759,76	0,97	416,11
373	2026-07-16 12:00:00	1,64	5,63	1,79	8,71	564,12	0,39	362,23
374	2026-07-16 13:00:00	6,31	20,83	6,56	32,05	596,07	1,43	450,31
375	2026-07-16 14:00:00	8,59	21,70	6,63	32,15	474,35	1,52	805,55
376	2026-07-16 15:00:00	5,12	21,02	6,53	32,15	518,41	1,45	513,74
377	2026-07-16 16:00:00	5,11	21,45	6,51	32,24	412,32	1,42	469,52
378	2026-07-16 17:00:00	5,69	21,19	6,59	32,24	506,77	1,45	360,69
379	2026-07-16 18:00:00	68,13	21,33	6,59	32,29	407,93	1,50	1169,01
380	2026-07-16 19:00:00	1,53	21,06	6,53	32,27	694,05	1,45	138,23
381	2026-07-16 20:00:00	2,65	21,33	6,58	32,24	761,00	1,44	373,74
382	2026-07-16 21:00:00	6,14	21,52	6,63	32,19	482,84	1,42	521,43
383	2026-07-16 22:00:00	21,17	22,07	6,90	32,16	606,93	1,64	361,88
384	2026-07-16 23:00:00	9,38	19,97	6,03	29,45	582,25	1,32	778,92
385	2026-07-17 00:00:00	9,86	17,17	5,36	26,28	561,77	1,17	428,21
386	2026-07-17 01:00:00	6,35	17,57	5,23	25,65	320,10	1,12	208,64
387	2026-07-17 02:00:00	9,43	21,61	6,75	32,07	536,50	1,51	630,90
388	2026-07-17 03:00:00	8,87	20,99	6,63	32,03	653,60	1,44	498,59
389	2026-07-17 04:00:00	6,08	21,36	6,43	32,00	366,15	1,38	640,92
390	2026-07-17 05:00:00	7,05	21,28	6,61	31,97	746,36	1,41	338,73
391	2026-07-17 06:00:00	15,25	22,00	6,77	31,97	567,79	1,48	834,51
392	2026-07-17 07:00:00	5,54	17,62	5,60	26,62	745,84	1,19	75,00
393	2026-07-17 08:00:00	5,40	18,92	6,07	28,70	678,85	1,29	550,28
394	2026-07-17 09:00:00	9,16	21,54	6,61	31,89	195,36	1,44	1066,22
395	2026-07-17 10:00:00	5,18	21,98	6,86	31,96	405,99	1,66	347,08
396	2026-07-17 11:00:00	7,50	18,26	5,31	26,16	683,37	1,19	590,00
397	2026-07-17 12:00:00	5,16	20,95	6,50	32,06	671,70	1,44	471,37
398	2026-07-17 13:00:00	4,78	21,28	6,52	32,10	502,47	1,47	443,77
399	2026-07-17 14:00:00	6,93	21,56	6,71	32,23	458,43	1,56	782,19
400	2026-07-17 15:00:00	4,20	21,18	6,66	32,21	747,87	1,48	268,31
401	2026-07-17 16:00:00	9,73	22,12	6,53	32,19	725,61	1,47	480,29
402	2026-07-17 17:00:00	7,04	20,23	6,10	29,54	571,34	1,38	352,89
403	2026-07-17 18:00:00	4,73	21,56	6,61	32,28	510,17	1,55	1190,61
404	2026-07-17 19:00:00	4,65	21,44	6,45	32,26	717,65	1,52	127,86
405	2026-07-17 20:00:00	6,07	21,74	6,45	32,24	560,76	1,51	428,77
406	2026-07-17 21:00:00	6,93	21,74	6,56	32,23	266,40	1,52	783,66
407	2026-07-17 22:00:00	5,50	21,93	6,92	32,13	381,00	1,62	348,28
408	2026-07-17 23:00:00	7,48	21,55	6,46	32,14	326,65	1,52	846,85
409	2026-07-18 00:00:00	5,97	20,90	6,49	32,13	511,16	1,52	320,07
410	2026-07-18 01:00:00	10,50	22,01	6,46	32,08	597,11	1,52	398,99

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
411	2026-07-18 02:00:00	7,91	21,65	6,80	32,12	590,37	1,59	656,77
412	2026-07-18 03:00:00	8,15	21,43	6,63	32,07	705,98	1,53	273,71
413	2026-07-18 04:00:00	8,23	17,87	5,26	26,69	499,22	1,27	485,08
414	2026-07-18 05:00:00	8,11	17,55	5,26	26,18	596,61	1,25	212,18
415	2026-07-18 06:00:00	14,32	21,94	6,49	31,97	567,62	1,51	919,63
416	2026-07-18 07:00:00	10,76	21,25	6,55	31,91	767,99	1,52	67,16
417	2026-07-18 08:00:00	11,21	21,37	6,58	31,90	493,59	1,52	439,64
418	2026-07-18 09:00:00	14,85	22,05	6,51	31,95	107,11	1,55	1050,89
419	2026-07-18 10:00:00	13,52	22,53	6,85	32,09	173,05	1,75	321,07
420	2026-07-18 11:00:00	7,34	22,75	6,49	31,94	467,36	1,56	677,08
421	2026-07-18 12:00:00	12,06	20,55	6,59	32,17	399,86	1,55	290,89
422	2026-07-18 13:00:00	6,91	20,86	6,62	32,30	272,98	1,58	255,63
423	2026-07-18 14:00:00	17,21	20,43	6,93	32,47	320,83	1,69	525,87
424	2026-07-18 15:00:00	11,84	20,86	6,70	32,51	756,62	1,55	230,01
425	2026-07-18 16:00:00	15,62	23,26	6,62	32,48	727,41	1,54	91,15
426	2026-07-18 17:00:00	13,02	22,27	6,70	32,58	594,90	1,54	348,97
427	2026-07-18 18:00:00	14,65	21,75	6,72	32,72	514,11	1,65	803,82
428	2026-07-18 19:00:00	6,76	20,81	6,43	32,67	533,12	1,56	466,58
429	2026-07-18 20:00:00	8,52	20,84	6,53	32,66	631,16	1,55	259,36
430	2026-07-18 21:00:00	10,27	20,77	6,65	32,63	387,29	1,52	614,69
431	2026-07-18 22:00:00	26,10	20,44	6,65	32,49	125,22	1,66	709,79
432	2026-07-18 23:00:00	10,18	20,50	6,59	32,50	594,62	1,55	260,85
433	2026-07-19 00:00:00	12,29	20,36	6,67	32,49	487,86	1,49	450,42
434	2026-07-19 01:00:00	16,18	20,53	6,46	32,45	332,18	1,57	650,61
435	2026-07-19 02:00:00	17,93	20,76	6,84	32,34	611,41	1,82	492,25
436	2026-07-19 03:00:00	16,46	20,89	6,68	32,34	723,92	1,61	38,98
437	2026-07-19 04:00:00	14,10	21,10	6,46	32,36	356,42	1,53	476,56
438	2026-07-19 05:00:00	14,03	21,16	6,59	32,31	371,82	1,53	369,73
439	2026-07-19 06:00:00	16,78	20,77	6,73	32,26	203,93	1,66	786,31
440	2026-07-19 07:00:00	7,84	20,57	6,45	32,28	416,59	1,67	623,65
441	2026-07-19 08:00:00	6,90	20,64	6,56	32,24	740,85	1,54	199,86
442	2026-07-19 09:00:00	8,43	21,07	6,68	32,20	502,81	1,52	131,02
443	2026-07-19 10:00:00	16,98	21,59	6,66	32,22	367,91	1,71	706,75
444	2026-07-19 11:00:00	6,67	21,21	6,66	32,21	796,28	1,60	279,83
445	2026-07-19 12:00:00	7,65	21,15	6,73	32,14	439,24	1,52	293,00
446	2026-07-19 13:00:00	14,50	18,53	6,59	32,10	332,37	2,35	695,73
447	2026-07-19 14:00:00	8,13	18,67	6,79	32,05	611,67	1,85	603,65
448	2026-07-19 15:00:00	13,02	18,23	6,61	32,07	642,70	1,57	514,87
449	2026-07-19 16:00:00	0,32	19,44	6,46	32,09	585,85	1,57	476,20
450	2026-07-19 17:00:00	0,43	19,26	6,53	32,03	613,67	1,55	384,89
451	2026-07-19 18:00:00	1,58	18,82	6,64	31,98	386,59	1,71	793,04
452	2026-07-19 19:00:00	33,88	19,43	6,58	31,99	528,88	3,12	617,12
453	2026-07-19 20:00:00	1,60	19,63	6,57	31,95	553,95	2,39	258,54
454	2026-07-19 21:00:00	1,83	18,65	6,56	31,87	320,07	1,56	579,64
455	2026-07-19 22:00:00	1,99	19,69	6,59	31,87	97,46	1,73	724,88
456	2026-07-19 23:00:00	1,90	19,50	6,56	31,84	391,49	1,61	235,38

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
457	2026-07-20 00:00:00	1,95	19,24	6,64	31,78	294,14	1,52	292,32
458	2026-07-20 01:00:00	1,65	20,26	6,56	31,78	171,98	2,72	695,65
459	2026-07-20 02:00:00	1,94	19,59	6,75	31,69	564,53	1,85	392,01
460	2026-07-20 03:00:00	2,07	20,19	6,65	31,67	704,29	1,90	12,96
461	2026-07-20 04:00:00	2,11	20,56	6,46	31,75	430,99	1,66	477,96
462	2026-07-20 05:00:00	2,05	20,07	6,59	31,67	441,61	1,54	321,29
463	2026-07-20 06:00:00	2,93	19,80	6,78	31,56	187,03	1,70	401,98
464	2026-07-20 07:00:00	6,26	20,02	6,44	31,63	54,13	1,77	629,24
465	2026-07-20 08:00:00	3,56	20,17	6,55	31,57	494,02	1,52	228,68
466	2026-07-20 09:00:00	14,21	20,09	6,72	31,50	216,58	1,49	350,66
467	2026-07-20 10:00:00	12,78	20,30	6,62	31,59	291,17	1,55	705,16
468	2026-07-20 11:00:00	6,12	19,98	6,64	31,58	272,23	1,50	122,16
469	2026-07-20 12:00:00	12,90	20,00	6,74	31,54	383,00	1,50	27,54
470	2026-07-20 13:00:00	13,66	19,85	6,56	31,65	492,33	1,48	298,53
471	2026-07-20 14:00:00	14,32	20,27	6,89	31,65	319,73	1,65	302,38
472	2026-07-20 15:00:00	19,01	19,61	6,73	31,66	525,07	1,46	483,60
473	2026-07-20 16:00:00	116,96	23,56	6,63	31,72	397,77	1,45	173,40
474	2026-07-20 17:00:00	7,50	20,90	6,73	31,78	582,99	1,47	287,58
475	2026-07-20 18:00:00	14,41	20,21	6,77	31,74	495,23	1,69	458,78
476	2026-07-20 19:00:00	14,80	19,91	6,49	31,80	535,95	1,43	624,96
477	2026-07-20 20:00:00	15,57	19,80	6,63	31,72	760,92	1,44	229,28
478	2026-07-20 21:00:00	3,30	20,49	6,79	31,66	482,94	1,48	368,40
479	2026-07-20 22:00:00	3,43	20,72	6,64	31,68	121,74	1,66	740,87
480	2026-07-20 23:00:00	3,59	20,52	6,63	31,67	526,80	1,50	263,50
481	2026-07-21 00:00:00	3,55	20,53	6,69	31,62	547,86	1,46	646,99
482	2026-07-21 01:00:00	3,04	20,30	6,51	31,60	334,89	1,46	668,03
483	2026-07-21 02:00:00	2,85	20,65	6,73	31,47	612,08	1,78	478,74
484	2026-07-21 03:00:00	2,34	20,55	6,69	31,51	641,48	1,53	32,30
485	2026-07-21 04:00:00	1,99	21,17	6,51	31,58	394,47	1,44	481,37
486	2026-07-21 05:00:00	1,90	20,81	6,63	31,52	596,12	1,45	347,45
487	2026-07-21 06:00:00	2,58	20,99	6,73	31,45	426,84	1,59	772,28
488	2026-07-21 07:00:00	2,28	20,16	6,47	31,51	539,72	1,45	622,67
489	2026-07-21 08:00:00	2,16	20,17	6,55	31,47	744,61	1,44	237,19
490	2026-07-21 09:00:00	2,21	21,15	6,70	31,42	520,72	1,45	523,58
491	2026-07-21 10:00:00	2,28	23,53	6,61	31,41	454,31	1,61	1002,14
492	2026-07-21 11:00:00	2,04	20,98	6,56	31,51	801,31	1,48	251,16
493	2026-07-21 12:00:00	2,13	21,55	6,62	31,55	564,38	1,48	507,65
494	2026-07-21 13:00:00	2,06	20,80	6,50	31,69	340,89	1,48	655,12
495	2026-07-21 14:00:00	2,77	21,70	6,76	31,69	614,94	1,70	565,14
496	2026-07-21 15:00:00	2,14	21,36	6,60	31,78	709,32	1,51	493,88
497	2026-07-21 16:00:00	2,00	21,73	6,43	31,90	545,45	1,52	462,35
498	2026-07-21 17:00:00	1,93	21,43	6,53	31,91	599,43	1,49	347,91
499	2026-07-21 18:00:00	2,38	22,37	6,65	31,95	416,83	1,56	800,98
500	2026-07-21 19:00:00	1,95	21,11	6,43	31,95	533,75	1,53	609,78
501	2026-07-21 20:00:00	1,84	21,50	6,49	31,92	779,72	1,50	155,96
502	2026-07-21 21:00:00	1,93	21,78	6,64	31,87	495,97	1,44	598,01

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
503	2026-07-21 22:00:00	2,10	22,21	6,63	31,76	382,32	1,57	737,56
504	2026-07-21 23:00:00	1,89	21,66	6,60	31,77	801,06	1,53	243,98
505	2026-07-22 00:00:00	1,95	21,71	6,66	31,77	507,16	1,47	604,24
506	2026-07-22 01:00:00	2,01	21,73	6,55	31,68	303,14	1,48	679,34
507	2026-07-22 02:00:00	2,16	22,71	6,78	31,53	607,47	1,64	582,64
508	2026-07-22 03:00:00	2,11	21,68	6,71	31,64	716,47	1,51	560,80
509	2026-07-22 04:00:00	2,09	22,45	6,60	31,65	496,08	1,49	437,43
510	2026-07-22 05:00:00	2,12	21,87	6,68	31,58	454,43	1,47	331,49
511	2026-07-22 06:00:00	2,86	22,14	6,79	31,52	231,50	1,52	814,63
512	2026-07-22 07:00:00	2,66	21,20	6,59	31,57	216,71	1,52	621,68
513	2026-07-22 08:00:00	2,56	21,32	6,67	31,54	540,49	1,51	211,47
514	2026-07-22 09:00:00	2,66	21,89	6,82	31,50	516,18	1,47	390,22
515	2026-07-22 10:00:00	2,96	23,06	6,79	31,54	372,96	1,56	734,28
516	2026-07-22 11:00:00	2,85	22,28	6,81	31,61	799,62	1,57	116,10
517	2026-07-22 12:00:00	2,85	22,47	6,93	31,64	452,07	1,52	23,89
518	2026-07-22 13:00:00	3,09	22,05	6,74	31,78	302,15	1,53	664,98
519	2026-07-22 14:00:00	3,58	23,25	6,98	31,86	614,89	1,66	541,30
520	2026-07-22 15:00:00	3,31	22,27	6,89	31,89	698,09	1,60	493,90
521	2026-07-22 16:00:00	3,32	22,90	6,76	31,90	515,55	1,57	521,91
522	2026-07-22 17:00:00	3,30	22,28	6,79	31,90	594,73	1,55	353,30
523	2026-07-22 18:00:00	3,65	22,65	6,86	31,93	395,42	1,59	805,45
524	2026-07-22 19:00:00	3,49	21,51	6,62	31,90	504,93	1,60	615,66
525	2026-07-22 20:00:00	3,36	21,57	6,68	31,89	612,69	1,59	242,33
526	2026-07-22 21:00:00	3,55	22,30	6,80	31,82	402,72	1,57	778,41
527	2026-07-22 22:00:00	3,96	23,05	6,76	31,65	345,39	1,67	802,10
528	2026-07-22 23:00:00	3,85	22,13	6,77	31,63	792,35	1,55	226,61
529	2026-07-23 00:00:00	3,80	21,51	6,88	31,58	636,04	1,45	617,52
530	2026-07-23 01:00:00	4,05	21,79	6,64	31,53	302,95	1,53	756,72
531	2026-07-23 02:00:00	4,37	23,28	6,88	31,44	596,27	1,73	606,15
532	2026-07-23 03:00:00	4,73	21,68	6,80	31,39	583,93	1,44	550,46
533	2026-07-23 04:00:00	4,56	22,63	6,71	31,41	558,75	1,50	479,54
534	2026-07-23 05:00:00	4,53	21,82	6,78	31,34	701,81	1,48	347,50
535	2026-07-23 06:00:00	5,02	21,89	6,87	31,26	365,07	1,51	778,46
536	2026-07-23 07:00:00	5,06	21,15	6,67	31,26	501,87	1,47	613,40
537	2026-07-23 08:00:00	5,17	21,27	6,74	31,20	750,82	1,45	183,36
538	2026-07-23 09:00:00	3,87	21,90	6,81	31,13	468,14	1,38	573,19
539	2026-07-23 10:00:00	2,97	23,07	6,77	31,20	372,80	1,56	704,59
540	2026-07-23 11:00:00	2,93	22,10	6,76	31,20	644,11	1,50	221,92
541	2026-07-23 12:00:00	2,75	21,92	6,78	31,19	385,21	1,42	447,01
542	2026-07-23 13:00:00	3,07	22,20	6,71	31,28	435,32	1,50	959,75
543	2026-07-23 14:00:00	2,97	21,79	6,68	31,32	794,25	1,53	203,72
544	2026-07-23 15:00:00	3,12	22,33	6,78	31,38	696,12	1,42	483,45
545	2026-07-23 16:00:00	3,44	23,54	6,75	31,54	383,77	1,48	757,85
546	2026-07-23 17:00:00	3,42	22,77	6,74	31,54	769,27	1,50	215,82
547	2026-07-23 18:00:00	3,66	22,56	6,77	31,54	453,31	1,40	550,64
548	2026-07-23 19:00:00	3,80	22,56	6,68	31,51	437,35	1,45	952,51

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
549	2026-07-23 20:00:00	3,71	22,25	6,66	31,52	794,08	1,48	225,60
550	2026-07-23 21:00:00	3,74	22,77	6,73	31,49	697,07	1,40	588,81
551	2026-07-23 22:00:00	3,85	24,03	6,75	31,44	363,20	1,44	791,17
552	2026-07-23 23:00:00	3,70	23,05	6,71	31,45	788,09	1,47	232,01
553	2026-07-24 00:00:00	3,61	22,79	6,66	31,41	521,32	1,41	595,18
554	2026-07-24 01:00:00	3,88	22,68	6,70	31,33	310,31	1,45	973,52
555	2026-07-24 02:00:00	3,83	22,20	6,64	31,32	681,96	1,46	224,52
556	2026-07-24 03:00:00	3,83	22,71	6,65	31,31	472,72	1,40	575,44
557	2026-07-24 04:00:00	4,10	24,32	6,76	31,27	97,18	1,47	784,58
558	2026-07-24 05:00:00	4,11	23,36	6,72	31,22	643,71	1,44	225,37
559	2026-07-24 06:00:00	4,12	23,18	6,76	31,18	475,54	1,37	345,61
560	2026-07-24 07:00:00	4,20	23,52	6,66	31,14	344,69	1,50	978,31
561	2026-07-24 08:00:00	4,09	22,63	6,67	31,12	785,71	1,42	176,78
562	2026-07-24 09:00:00	4,26	22,95	6,80	31,07	490,04	1,37	157,95
563	2026-07-24 10:00:00	4,70	24,51	6,78	31,13	97,33	1,49	759,36
564	2026-07-24 11:00:00	4,76	23,49	6,76	31,12	659,78	1,42	209,36
565	2026-07-24 12:00:00	4,48	22,72	6,75	31,10	524,02	1,35	430,04
566	2026-07-24 13:00:00	4,03	22,91	6,65	31,17	321,11	1,45	1024,86
567	2026-07-24 14:00:00	3,86	22,52	6,66	31,23	794,70	1,42	144,53
568	2026-07-24 15:00:00	3,88	22,53	6,79	31,25	692,42	1,35	124,37
569	2026-07-24 16:00:00	4,21	24,64	6,79	31,32	361,84	1,49	779,02
570	2026-07-24 17:00:00	4,34	23,75	6,75	31,34	788,92	1,43	237,88
571	2026-07-24 18:00:00	4,38	22,51	6,65	31,36	543,42	1,33	622,63
572	2026-07-24 19:00:00	4,22	23,06	6,62	31,33	317,62	1,47	935,58
573	2026-07-24 20:00:00	4,04	22,34	6,58	31,33	639,71	1,42	210,80
574	2026-07-24 21:00:00	4,16	22,64	6,64	31,34	365,22	1,30	567,82
575	2026-07-24 22:00:00	4,10	22,43	6,17	28,64	248,06	1,32	673,80
576	2026-07-24 23:00:00	4,54	23,50	6,70	31,27	796,91	1,42	217,79
577	2026-07-25 00:00:00	4,58	22,38	6,70	31,28	578,83	1,32	530,83
578	2026-07-25 01:00:00	4,65	22,42	6,61	31,23	315,98	1,38	770,41
579	2026-07-25 02:00:00	4,67	21,98	6,63	31,21	802,30	1,37	185,62
580	2026-07-25 03:00:00	4,70	22,21	6,75	31,20	723,05	1,31	353,57
581	2026-07-25 04:00:00	5,04	24,36	6,78	31,13	364,98	1,46	781,27
582	2026-07-25 05:00:00	5,12	23,32	6,74	31,15	796,59	1,45	244,65
583	2026-07-25 06:00:00	5,27	22,28	6,73	31,11	281,22	1,32	589,41
584	2026-07-25 07:00:00	4,90	23,19	6,69	30,99	44,15	1,47	986,55
585	2026-07-25 08:00:00	4,66	22,32	6,67	30,98	774,13	1,42	214,52
586	2026-07-25 09:00:00	4,59	22,21	6,79	30,95	738,27	1,31	468,63
587	2026-07-25 10:00:00	4,99	24,35	6,83	30,91	364,63	1,49	778,19
588	2026-07-25 11:00:00	5,07	23,07	6,82	30,97	756,07	1,48	201,00
589	2026-07-25 12:00:00	5,03	22,40	6,87	30,98	524,22	1,35	277,78
590	2026-07-25 13:00:00	5,06	23,08	6,73	31,09	337,09	1,47	1036,97
591	2026-07-25 14:00:00	4,46	22,46	6,68	31,14	793,27	1,45	210,57
592	2026-07-25 15:00:00	4,44	22,24	6,75	31,21	744,50	1,33	622,93
593	2026-07-25 16:00:00	4,46	24,26	6,80	31,23	369,95	1,50	774,30
594	2026-07-25 17:00:00	4,87	22,91	6,75	31,29	695,04	1,50	218,45

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
595	2026-07-25 18:00:00	5,13	22,07	6,75	31,32	533,46	1,33	576,61
596	2026-07-25 19:00:00	5,14	22,61	6,73	31,28	394,52	1,47	987,76
597	2026-07-25 20:00:00	4,70	21,87	6,69	31,30	537,60	1,43	226,27
598	2026-07-25 21:00:00	4,95	22,09	6,79	31,30	556,35	1,30	561,48
599	2026-07-25 22:00:00	5,10	23,95	6,83	31,23	368,58	1,50	801,05
600	2026-07-25 23:00:00	4,76	22,67	6,79	31,26	692,83	1,43	199,32
601	2026-07-26 00:00:00	4,82	22,24	6,85	31,23	576,70	1,30	308,20
602	2026-07-26 01:00:00	4,64	22,34	6,70	31,19	324,08	1,45	1008,30
603	2026-07-26 02:00:00	4,09	21,74	6,68	31,19	515,14	1,37	226,88
604	2026-07-26 03:00:00	4,09	22,23	6,74	31,18	468,41	1,26	604,70
605	2026-07-26 04:00:00	4,36	23,80	6,75	31,11	303,26	1,50	811,86
606	2026-07-26 05:00:00	4,32	22,63	6,74	31,13	683,68	1,37	254,57
607	2026-07-26 06:00:00	4,29	22,43	6,81	31,08	448,20	1,28	151,44
608	2026-07-26 07:00:00	4,43	22,51	6,65	31,04	494,92	1,39	1002,41
609	2026-07-26 08:00:00	4,35	21,74	6,67	31,05	519,26	1,32	237,47
610	2026-07-26 09:00:00	4,37	21,99	6,77	31,07	320,27	1,22	505,93
611	2026-07-26 10:00:00	4,63	23,78	6,75	31,13	112,67	1,42	817,62
612	2026-07-26 11:00:00	4,62	22,69	6,74	31,21	787,73	1,35	207,35
613	2026-07-26 12:00:00	4,60	22,02	6,85	31,32	494,96	1,25	219,50
614	2026-07-26 13:00:00	4,79	22,14	6,64	31,48	304,65	1,34	799,19
615	2026-07-26 14:00:00	4,81	21,94	6,69	31,58	597,24	1,32	165,77
616	2026-07-26 15:00:00	4,90	22,17	6,82	31,71	632,03	1,24	286,28
617	2026-07-26 16:00:00	5,30	23,86	6,74	31,77	590,69	1,38	683,49
618	2026-07-26 17:00:00	5,36	23,13	6,71	31,84	795,54	1,34	219,75
619	2026-07-26 18:00:00	5,41	22,93	6,65	31,91	499,05	1,27	561,52
620	2026-07-26 19:00:00	4,95	23,02	6,57	31,84	133,67	1,34	825,13
621	2026-07-26 20:00:00	4,42	22,77	6,55	31,87	519,57	1,32	210,23
622	2026-07-26 21:00:00	4,50	23,29	6,60	31,91	475,92	1,24	595,68
623	2026-07-26 22:00:00	4,73	24,04	6,70	31,75	80,26	1,37	827,79
624	2026-07-26 23:00:00	4,32	21,48	6,12	29,14	475,19	1,23	157,59
625	2026-07-27 00:00:00	4,73	23,34	6,72	31,78	303,50	1,28	67,71
626	2026-07-27 01:00:00	4,93	23,71	6,58	31,75	43,12	1,37	966,13
627	2026-07-27 02:00:00	4,90	23,08	6,55	31,75	512,52	1,34	20,42
628	2026-07-27 03:00:00	4,83	22,97	6,56	31,73	336,18	1,33	9,31
629	2026-07-27 04:00:00	5,12	24,44	6,68	31,64	310,41	1,42	790,63
630	2026-07-27 05:00:00	5,13	23,46	6,70	31,65	591,94	1,37	23,24
631	2026-07-27 06:00:00	5,19	23,23	6,70	31,64	445,31	1,37	7,67
632	2026-07-27 07:00:00	5,25	23,67	6,57	31,61	388,35	1,42	878,40
633	2026-07-27 08:00:00	5,30	23,53	6,58	31,59	518,83	1,35	192,96
634	2026-07-27 09:00:00	5,49	23,76	6,71	31,64	479,76	1,26	429,82
635	2026-07-27 10:00:00	5,76	24,39	6,63	31,69	211,96	1,29	467,65
636	2026-07-27 11:00:00	3,38	24,95	6,79	31,75	607,52	1,46	393,76
637	2026-07-27 12:00:00	1,68	22,14	6,24	29,16	596,82	1,22	31,21
638	2026-07-27 13:00:00	1,74	23,94	6,48	31,88	463,25	1,32	590,19
639	2026-07-27 14:00:00	1,58	23,79	6,57	31,84	583,33	1,31	125,83
640	2026-07-27 15:00:00	1,84	25,25	6,75	31,85	514,36	1,36	777,14

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
641	2026-07-27 16:00:00	2,66	25,45	6,60	31,80	554,38	1,32	494,92
642	2026-07-27 17:00:00	2,52	24,75	6,63	31,79	740,15	1,29	214,75
643	2026-07-27 18:00:00	2,43	25,01	6,59	31,77	393,29	1,27	541,74
644	2026-07-27 19:00:00	2,51	24,98	6,54	31,66	313,12	1,37	966,45
645	2026-07-27 20:00:00	2,39	24,97	6,51	31,66	569,42	1,36	209,43
646	2026-07-27 21:00:00	2,42	25,37	6,57	31,66	488,87	1,24	554,87
647	2026-07-27 22:00:00	2,29	26,02	6,56	31,59	79,41	1,26	497,44
648	2026-07-27 23:00:00	2,59	26,59	6,77	31,48	429,52	1,40	595,47
649	2026-07-28 00:00:00	2,66	25,33	6,74	31,51	642,02	1,30	323,18
650	2026-07-28 01:00:00	2,41	22,78	5,91	28,61	407,92	1,20	537,87
651	2026-07-28 02:00:00	2,65	24,86	6,58	31,44	598,37	1,30	151,87
652	2026-07-28 03:00:00	3,12	26,26	6,70	31,39	540,25	1,42	799,38
653	2026-07-28 04:00:00	3,27	25,80	6,65	31,37	742,70	1,32	93,70
654	2026-07-28 05:00:00	3,42	25,82	6,68	31,29	747,64	1,33	335,93
655	2026-07-28 06:00:00	3,35	26,04	6,57	31,23	261,39	1,53	1057,43
656	2026-07-28 07:00:00	3,24	29,77	6,74	31,13	404,16	1,66	399,11
657	2026-07-28 08:00:00	3,30	27,76	6,63	31,14	524,51	1,45	632,61
658	2026-07-28 09:00:00	3,34	27,22	6,57	31,14	401,62	1,47	605,69
659	2026-07-28 10:00:00	3,31	26,12	6,58	31,08	263,64	1,26	335,71
660	2026-07-28 11:00:00	3,60	26,90	6,66	31,12	455,08	1,43	805,59
661	2026-07-28 12:00:00	3,44	25,96	6,58	31,14	712,34	1,31	43,87
662	2026-07-28 13:00:00	3,52	26,32	6,59	31,16	700,32	1,27	464,86
663	2026-07-28 14:00:00	3,46	25,91	6,60	31,16	587,37	1,25	171,50
664	2026-07-28 15:00:00	3,55	27,61	6,60	31,21	439,22	1,37	1101,23
665	2026-07-28 16:00:00	3,57	26,04	6,49	31,22	695,86	1,27	83,19
666	2026-07-28 17:00:00	3,54	26,61	6,52	31,22	735,88	1,28	314,57
667	2026-07-28 18:00:00	3,60	27,02	6,59	31,26	453,44	1,31	805,62
668	2026-07-28 19:00:00	3,81	27,44	6,74	31,18	594,20	1,44	420,05
669	2026-07-28 20:00:00	3,86	25,85	6,55	31,17	463,03	1,30	812,08
670	2026-07-28 21:00:00	3,67	26,27	6,46	31,20	595,25	1,18	668,53
671	2026-07-28 22:00:00	3,63	25,50	6,51	31,10	310,38	1,21	293,38
672	2026-07-28 23:00:00	4,03	27,26	6,72	31,06	454,86	1,50	766,65
673	2026-07-29 00:00:00	3,88	26,54	6,61	31,08	701,04	1,54	613,70
674	2026-07-29 01:00:00	3,90	24,75	6,49	31,04	544,58	1,21	641,25
675	2026-07-29 02:00:00	3,98	25,25	6,54	30,99	598,66	1,20	161,88
676	2026-07-29 03:00:00	4,17	26,49	6,71	30,95	517,57	1,36	858,00
677	2026-07-29 04:00:00	4,19	25,22	6,67	30,97	731,89	1,24	70,98
678	2026-07-29 05:00:00	4,04	25,41	6,68	30,95	703,43	1,23	331,63
679	2026-07-29 06:00:00	4,05	25,30	6,51	30,92	262,12	1,21	1074,07
680	2026-07-29 07:00:00	4,26	26,38	6,78	30,76	500,43	1,43	376,77
681	2026-07-29 08:00:00	4,48	26,42	6,63	30,79	483,01	1,32	656,48
682	2026-07-29 09:00:00	4,43	25,52	6,57	30,79	446,33	1,11	620,49
683	2026-07-29 10:00:00	4,26	24,82	6,59	30,68	473,30	1,15	322,22
684	2026-07-29 11:00:00	4,55	25,43	6,66	30,67	436,28	1,28	877,86
685	2026-07-29 12:00:00	4,61	24,78	6,64	30,67	703,03	1,22	155,52
686	2026-07-29 13:00:00	4,64	25,65	6,54	30,74	760,52	1,18	473,44

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
687	2026-07-29 14:00:00	4,65	25,02	6,61	30,77	600,45	1,14	184,05
688	2026-07-29 15:00:00	4,89	24,78	6,54	30,85	494,60	1,14	1047,68
689	2026-07-29 16:00:00	4,82	24,49	6,49	30,89	492,63	1,19	141,03
690	2026-07-29 17:00:00	5,09	25,77	6,65	30,90	600,81	1,31	609,98
691	2026-07-29 18:00:00	5,33	26,48	6,55	30,94	606,71	1,24	845,75
692	2026-07-29 19:00:00	5,17	25,85	6,58	30,91	735,08	1,24	18,11
693	2026-07-29 20:00:00	5,35	25,31	6,58	30,86	317,53	1,27	1027,97
694	2026-07-29 21:00:00	5,65	24,80	6,54	30,87	639,04	1,23	700,02
695	2026-07-29 22:00:00	5,63	25,02	6,51	30,84	798,49	1,25	291,52
696	2026-07-29 23:00:00	5,91	26,28	6,70	30,74	586,44	1,36	732,43
697	2026-07-30 00:00:00	5,46	24,89	5,93	27,70	575,05	1,22	754,81
698	2026-07-30 01:00:00	5,85	24,78	6,45	30,80	473,46	1,27	632,01
699	2026-07-30 02:00:00	5,92	26,11	6,68	30,65	590,90	1,37	536,28
700	2026-07-30 03:00:00	5,95	26,20	6,54	30,74	693,48	1,31	992,14
701	2026-07-30 04:00:00	5,77	26,11	6,56	30,72	723,09	1,24	96,91
702	2026-07-30 05:00:00	5,85	26,43	6,74	30,55	595,70	1,42	666,68
703	2026-07-30 06:00:00	5,95	26,62	6,50	30,66	419,00	1,31	1095,15
704	2026-07-30 07:00:00	5,72	25,70	6,52	30,60	796,09	1,30	20,52
705	2026-07-30 08:00:00	6,05	27,03	6,62	30,55	626,75	1,34	880,90
706	2026-07-30 09:00:00	6,18	25,33	6,56	30,64	553,66	1,25	703,74
707	2026-07-30 10:00:00	6,12	25,87	6,52	30,66	628,70	1,25	309,13
708	2026-07-30 11:00:00	6,61	26,09	6,60	30,72	495,00	1,32	836,12
709	2026-07-30 12:00:00	6,96	27,65	6,46	30,78	652,44	1,27	640,12
710	2026-07-30 13:00:00	6,93	27,76	6,47	30,90	528,29	1,20	449,77
711	2026-07-30 14:00:00	7,42	27,41	6,66	30,93	375,22	1,31	499,75
712	2026-07-30 15:00:00	8,05	24,64	6,46	31,05	524,79	1,21	1100,44
713	2026-07-30 16:00:00	7,93	24,46	6,43	30,98	677,12	1,20	175,61
714	2026-07-30 17:00:00	8,26	25,67	6,64	30,84	629,21	1,46	599,36
715	2026-07-30 18:00:00	7,99	25,54	5,95	28,14	529,57	1,12	532,20
716	2026-07-30 19:00:00	8,69	27,15	6,59	30,92	791,35	1,22	13,81
717	2026-07-30 20:00:00	9,33	26,18	6,57	30,86	161,77	1,29	1049,57
718	2026-07-30 21:00:00	10,09	23,92	6,51	30,91	420,30	1,17	680,68
719	2026-07-30 22:00:00	9,71	25,76	6,47	30,85	499,07	1,19	281,31
720	2026-07-30 23:00:00	10,10	27,74	6,65	30,75	431,81	1,38	576,91