

KẾT QUẢ ONLINE TRẠM QTTĐ KCN KHAI QUANG THÁNG 10/2025

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
1	00:00 01/10/2025	1.79	20.32	7.3	29.25	565.83	0.0	925.85
2	01:00 01/10/2025	1.7808	20.3033	7.2817	29.2467	660.13	0.0	546.8717
3	02:00 01/10/2025	1.78	20.3075	7.3417	29.21	777.7875	0.0	30.8733
4	03:00 01/10/2025	1.7892	20.3233	7.3417	29.185	567.455	0.0	1350.1092
5	04:00 01/10/2025	1.7817	20.31	7.3317	29.1933	713.7275	0.0	216.1733
6	05:00 01/10/2025	1.7883	20.3158	7.3508	29.1958	705.5517	0.0	318.255
7	06:00 01/10/2025	1.79	20.3167	7.3225	29.1942	595.7892	0.0	1003.6458
8	07:00 01/10/2025	1.7908	20.3267	7.3258	29.095	490.1067	0.0	653.2717
9	08:00 01/10/2025	1.7942	20.31	7.3308	29.2017	369.0883	0.0	728.6033
10	09:00 01/10/2025	1.7908	20.3067	7.3267	29.2167	411.4058	0.0	735.265
11	10:00 01/10/2025	1.7933	20.3067	7.3067	29.23	522.5008	0.0	668.0367
12	11:00 01/10/2025	1.7908	20.3167	7.3342	29.1783	507.6758	0.0	620.455
13	12:00 01/10/2025	1.7958	20.3242	7.3717	29.2217	764.4958	0.0	496.4167
14	13:00 01/10/2025	1.7917	20.3	7.3775	29.3558	699.7492	0.0	510.1142
15	14:00 01/10/2025	1.79	20.2967	7.4608	29.3442	681.6308	0.0	27.5417
16	15:00 01/10/2025	1.7917	20.3	7.4458	29.4275	464.8875	0.0	1378.9692
17	16:00 01/10/2025	1.79	20.2942	7.3525	29.4925	710.0725	0.0	169.3725
18	17:00 01/10/2025	1.7933	20.3025	7.3692	29.5175	836.2333	0.0	302.4825
19	18:00 01/10/2025	1.7908	20.3042	7.3583	29.5275	488.8258	0.0	927.0217
20	19:00 01/10/2025	1.7917	20.3183	7.3917	29.4742	554.8892	0.0	564.07
21	20:00 01/10/2025	1.7908	20.2942	7.31	29.5475	483.83	0.0	696.6725
22	21:00 01/10/2025	1.7908	20.2958	7.3367	29.5508	388.2142	0.0	713.8867
23	22:00 01/10/2025	1.7975	20.3333	7.3425	29.5233	403.6917	0.0	581.1825
24	23:00 01/10/2025	1.7917	20.3175	7.3817	29.4733	242.2508	0.0117	587.4017
25	00:00 02/10/2025	1.79	20.3008	7.3608	29.4842	737.3442	0.0008	571.9042
26	01:00 02/10/2025	1.79	20.295	7.2608	29.535	666.4825	0.0	547.5508
27	02:00 02/10/2025	1.79	20.2917	7.3342	29.4908	783.0092	0.0	29.4967
28	03:00 02/10/2025	1.7925	20.3125	7.3617	29.4775	498.3725	0.0	979.665
29	04:00 02/10/2025	1.79	20.2942	7.3675	29.4925	711.02	0.0	93.7317
30	05:00 02/10/2025	1.79	20.2975	7.3858	29.4842	842.7533	0.0	321.4333
31	06:00 02/10/2025	1.79	20.2992	7.3408	29.4425	534.3292	0.0	960.1958
32	07:00 02/10/2025	1.79	20.3133	7.3675	29.4092	369.1017	0.0	637.0733
33	08:00 02/10/2025	1.7917	20.305	7.3408	29.4642	450.8058	0.0	725.7975
34	09:00 02/10/2025	1.7908	20.2917	7.3558	29.4492	384.0942	0.0	719.7833
35	10:00 02/10/2025	1.79	20.2958	7.3108	29.5208	406.1533	0.0	595.0317
36	11:00 02/10/2025	1.7908	20.3117	7.3275	29.7067	216.0117	0.0	612.3133
37	12:00 02/10/2025	1.795	20.32	7.3175	29.6483	632.1708	0.0033	322.0783
38	13:00 02/10/2025	1.7917	20.31	7.3092	29.8683	659.1292	0.0075	488.1075
39	14:00 02/10/2025	1.79	20.305	7.3567	29.9208	707.3258	0.1592	12.6733

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
40	15:00 02/10/2025	1.7908	20.3117	7.3258	30.1192	475.4742	0.3517	949.8442
41	16:00 02/10/2025	1.79	20.3208	7.3267	30.1617	720.9108	0.5517	47.2392
42	17:00 02/10/2025	1.7925	20.335	7.3425	30.1842	857.235	0.5658	290.8442
43	18:00 02/10/2025	1.79	20.3225	7.3108	30.2192	629.225	0.5642	928.01
44	19:00 02/10/2025	1.7908	20.3333	7.3158	30.2433	553.5308	0.8567	593.0942
45	20:00 02/10/2025	1.7908	20.3175	7.265	30.21	676.9475	0.7383	693.8508
46	21:00 02/10/2025	1.7908	20.3167	7.3017	30.2442	716.12	0.6675	721.4667
47	22:00 02/10/2025	1.8	20.3542	7.2942	30.1983	763.5767	0.6275	612.57
48	23:00 02/10/2025	1.7925	20.3408	7.2942	30.2367	510.5275	0.7208	622.6133
49	00:00 03/10/2025	1.79	20.3242	7.2825	30.2008	560.3058	0.6608	909.705
50	01:00 03/10/2025	1.79	20.3075	7.2375	30.1575	443.3925	0.49	664.0933
51	02:00 03/10/2025	1.79	20.3175	7.2883	30.1433	518.5125	0.5375	29.6333
52	03:00 03/10/2025	1.7933	20.3275	7.2975	30.1558	518.5575	0.575	1304.1392
53	04:00 03/10/2025	1.79	20.3267	7.2892	30.1525	717.0467	0.6775	175.6083
54	05:00 03/10/2025	1.79	20.3175	7.3092	30.0717	719.2625	0.6308	308.48
55	06:00 03/10/2025	1.79	20.3117	7.2842	29.99	489.245	0.5167	596.0358
56	07:00 03/10/2025	1.79	20.3275	7.2808	30.0933	555.1383	0.6008	487.7333
57	08:00 03/10/2025	1.7942	20.32	7.2933	29.9692	722.7633	0.5858	722.0283
58	09:00 03/10/2025	1.7908	20.315	7.3042	29.9975	660.9825	0.41	719.2067
59	10:00 03/10/2025	1.7908	20.3175	7.2767	29.9958	482.1542	0.3517	615.4933
60	11:00 03/10/2025	1.79	20.335	7.265	30.3167	308.7975	0.5017	597.0208
61	12:00 03/10/2025	1.7917	20.33	7.2917	30.2467	747.6175	0.9175	842.4625
62	13:00 03/10/2025	1.7908	20.3192	7.2825	30.2258	634.0642	0.7875	532.7508
63	14:00 03/10/2025	1.79	20.3142	7.3267	30.3242	595.8317	0.9425	16.1233
64	15:00 03/10/2025	1.7925	20.3283	7.2875	30.4808	512.8467	1.1508	1225.8825
65	16:00 03/10/2025	1.7917	20.3283	7.2742	30.5125	703.2892	1.4575	153.0067
66	17:00 03/10/2025	1.7925	20.3308	7.3075	30.4542	713.7225	1.27	288.8558
67	18:00 03/10/2025	1.79	20.3258	7.2808	30.4658	658.1858	1.0708	927.0725
68	19:00 03/10/2025	1.7908	20.3408	7.31	30.5825	594.7967	1.3925	545.6483
69	20:00 03/10/2025	1.79	20.3133	7.2425	30.4025	693.5925	1.28	650.5675
70	21:00 03/10/2025	1.79	20.32	7.2808	30.4833	787.4092	1.095	703.775
71	22:00 03/10/2025	1.7967	20.3475	7.2767	30.4042	705.1858	1.1125	590.4258
72	23:00 03/10/2025	1.7908	20.3442	7.2833	30.4767	401.19	1.11	601.0633
73	00:00 04/10/2025	1.7875	20.32	7.265	30.4183	526.92	1.1475	836.9375
74	01:00 04/10/2025	1.7842	20.3125	7.2392	30.3158	481.685	0.875	660.0825
75	02:00 04/10/2025	1.78	20.3117	7.28	30.3208	782.4883	0.865	30.1242
76	03:00 04/10/2025	1.79	20.3333	7.2908	30.3842	520.3367	0.9142	1201.0725
77	04:00 04/10/2025	1.79	20.3208	7.2925	30.3917	708.0342	1.0992	172.4483
78	05:00 04/10/2025	1.79	20.3033	7.3192	30.2825	734.9192	0.9942	310.8117
79	06:00 04/10/2025	1.79	20.2992	7.2983	30.2125	484.7067	0.7892	862.26
80	07:00 04/10/2025	1.79	20.3325	7.2625	30.3808	550.3225	0.915	517.7092
81	08:00 04/10/2025	1.7942	20.3183	7.3017	30.1858	537.2833	1.0933	720.09

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
82	09:00 04/10/2025	1.7908	20.3	7.3158	30.2242	460.7642	0.8042	715.2967
83	10:00 04/10/2025	1.79	20.2942	7.3008	30.2033	316.6558	0.78	619.9292
84	11:00 04/10/2025	1.79	20.3267	7.245	30.615	334.0792	0.9508	591.7
85	12:00 04/10/2025	1.795	20.325	7.315	30.4925	596.2792	1.6442	602.135
86	13:00 04/10/2025	1.7925	20.3	7.3233	30.44	713.3267	1.32	498.3708
87	14:00 04/10/2025	1.79	20.2933	7.3733	30.5425	772.8367	1.4808	14.66
88	15:00 04/10/2025	1.7917	20.305	7.3325	30.7267	469.8033	1.7608	1148.4758
89	16:00 04/10/2025	1.79	20.2908	7.3267	30.7567	496.8933	2.0008	48.5125
90	17:00 04/10/2025	1.795	20.3117	7.3625	30.7267	670.0667	1.9425	282.6525
91	18:00 04/10/2025	1.79	20.2967	7.335	30.7308	444.8125	1.7383	916.6892
92	19:00 04/10/2025	1.7917	20.3242	7.26	30.9933	501.8292	2.2967	566.4983
93	20:00 04/10/2025	1.7908	20.2908	7.2825	30.6683	671.4192	2.5083	675.2758
94	21:00 04/10/2025	1.7917	20.3	7.3492	30.7408	648.9583	2.035	563.0492
95	22:00 04/10/2025	1.7983	20.3175	7.3483	30.6283	567.3417	1.9642	485.37
96	23:00 04/10/2025	1.7925	20.3225	7.3358	30.7692	531.0125	1.9842	483.195
97	00:00 05/10/2025	1.79	20.2992	7.3517	30.6458	750.7242	2.0042	734.7367
98	01:00 05/10/2025	1.79	20.2958	7.3167	30.5208	688.4267	1.5833	586.9425
99	02:00 05/10/2025	1.79	20.2942	7.3667	30.5292	753.3142	1.5642	30.7875
100	03:00 05/10/2025	1.7933	20.3133	7.35	30.5883	518.5333	1.6508	1285.6317
101	04:00 05/10/2025	1.79	20.3033	7.345	30.5383	704.8817	1.7375	181.895
102	05:00 05/10/2025	1.7917	20.3067	7.3658	30.4775	668.9858	1.7283	309.7067
103	06:00 05/10/2025	1.79	20.3025	7.3133	30.4092	478.5083	1.4725	979.465
104	07:00 05/10/2025	1.7925	20.3342	7.265	30.7067	575.0708	1.8133	645.4342
105	08:00 05/10/2025	1.7992	20.3183	7.3258	30.4058	542.8158	2.1442	707.4458
106	09:00 05/10/2025	1.7925	20.3067	7.3242	30.4342	550.2242	1.5092	706.3933
107	10:00 05/10/2025	1.7983	20.3	7.3108	30.42	524.0408	1.4483	612.4175
108	11:00 05/10/2025	1.7983	20.3408	7.2725	30.9342	256.445	1.8175	579.245
109	12:00 05/10/2025	1.795	20.3158	7.2867	30.7092	527.4108	2.8558	831.5675
110	13:00 05/10/2025	1.7908	20.3	7.3175	30.5808	484.2808	2.1658	635.3242
111	14:00 05/10/2025	1.79	20.2992	7.3492	30.6767	480.7167	2.2658	23.3767
112	15:00 05/10/2025	1.795	20.3042	7.3075	30.7242	239.5842	2.3642	583.7142
113	16:00 05/10/2025	1.8	20.3192	7.3017	30.7342	479.475	2.1833	45.9125
114	17:00 05/10/2025	1.805	20.3325	7.3333	30.7658	802.4983	2.2458	287.7858
115	18:00 05/10/2025	1.8	20.3092	7.3117	30.7292	476.58	2.1617	351.9183
116	19:00 05/10/2025	1.8017	20.3475	7.2825	31.1758	551.4167	2.8483	482.4817
117	20:00 05/10/2025	1.8	20.3075	7.2558	30.8558	468.9225	3.7067	758.3417
118	21:00 05/10/2025	1.8008	20.3092	7.3408	30.875	483.6092	3.0717	551.0358
119	22:00 05/10/2025	1.8017	20.3125	7.3225	30.735	322.3758	2.8433	486.6267
120	23:00 05/10/2025	1.805	20.3458	7.3442	31.1767	353.7625	3.0892	648.8858
121	00:00 06/10/2025	1.8008	20.3075	7.3908	30.95	553.3208	4.1908	582.8817
122	01:00 06/10/2025	1.7975	20.2967	7.2967	30.6558	456.0458	2.5875	556.3192
123	02:00 06/10/2025	1.79	20.2983	7.3658	30.7233	602.3208	2.4108	31.655

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
124	03:00 06/10/2025	1.7942	20.32	7.3792	30.8083	534.275	2.5533	1083.6558
125	04:00 06/10/2025	1.79	20.3	7.3817	30.6883	504.2142	2.5667	93.2583
126	05:00 06/10/2025	1.7925	20.3017	7.3942	30.6342	559.2475	2.3275	305.4933
127	06:00 06/10/2025	1.7958	20.2958	7.3458	30.585	370.255	1.9575	989.1858
128	07:00 06/10/2025	1.79	20.2967	7.3375	30.5567	562.5783	1.9442	228.2567
129	08:00 06/10/2025	1.8008	20.3167	7.3375	30.475	733.0783	1.7658	609.7975
130	09:00 06/10/2025	1.7958	20.3008	7.3292	30.5867	568.915	1.6708	713.7842
131	10:00 06/10/2025	1.8	20.31	7.2992	30.5217	498.585	1.8292	634.305
132	11:00 06/10/2025	1.8	20.3	7.2933	30.485	257.9717	1.6392	191.1742
133	12:00 06/10/2025	1.8	20.2992	7.3167	30.53	520.8067	1.6542	751.85
134	13:00 06/10/2025	1.8008	20.3058	7.3217	30.4017	733.5475	1.6492	699.34
135	14:00 06/10/2025	1.8	20.2958	7.3792	30.3458	654.4858	1.6	33.5233
136	15:00 06/10/2025	1.8017	20.3067	7.3567	30.425	562.7392	1.575	1022.9758
137	16:00 06/10/2025	1.8	20.2958	7.3608	30.3983	598.0633	1.81	79.6625
138	17:00 06/10/2025	1.8067	20.3133	7.3742	30.2358	810.1783	1.5933	302.995
139	18:00 06/10/2025	1.8008	20.305	7.3142	30.3467	742.1525	1.4508	965.2925
140	19:00 06/10/2025	1.8017	20.3183	7.3725	30.5425	588.6842	1.9867	648.1383
141	20:00 06/10/2025	1.8033	20.3108	7.31	30.2425	592.7417	1.8875	751.1375
142	21:00 06/10/2025	1.8017	20.3075	7.3358	30.2767	577.3783	1.5117	723.605
143	22:00 06/10/2025	1.8042	20.3208	7.34	30.1808	514.4175	1.4608	651.2142
144	23:00 06/10/2025	1.8025	20.3292	7.3583	30.3842	482.38	1.48	635.9533
145	00:00 07/10/2025	1.8008	20.3067	7.3617	30.2317	791.7825	1.7758	798.1917
146	01:00 07/10/2025	1.8008	20.3033	7.3025	30.0508	681.3817	1.1817	622.4767
147	02:00 07/10/2025	1.8	20.3008	7.3625	30.085	798.05	1.1083	36.9733
148	03:00 07/10/2025	1.8058	20.3267	7.365	30.1275	572.3167	1.135	1289.1325
149	04:00 07/10/2025	1.8	20.3158	7.3592	30.1058	696.7033	1.2092	185.7192
150	05:00 07/10/2025	1.8025	20.3075	7.3833	29.9492	719.8867	0.9717	309.5025
151	06:00 07/10/2025	1.8	20.3033	7.3225	29.925	552.4233	0.7325	1009.135
152	07:00 07/10/2025	1.8033	20.3483	7.3392	30.0842	564.1158	0.9	689.6692
153	08:00 07/10/2025	1.8083	20.3308	7.3417	29.8517	736.4142	0.8292	724.1333
154	09:00 07/10/2025	1.8017	20.3075	7.3258	29.8342	800.935	0.5358	715.96
155	10:00 07/10/2025	1.7983	20.3067	7.3008	29.7608	525.2733	0.4925	665.4542
156	11:00 07/10/2025	1.7925	20.3483	7.3	29.9583	217.9042	0.5867	660.305
157	12:00 07/10/2025	1.7917	20.3158	7.3083	29.8725	705.3483	0.7167	883.79
158	13:00 07/10/2025	1.7942	20.3075	7.32	29.755	781.495	0.4308	704.9642
159	14:00 07/10/2025	1.79	20.3075	7.36	29.7783	838.1858	0.3108	39.37
160	15:00 07/10/2025	1.7975	20.3258	7.3458	29.8175	492.4258	0.275	1253.7525
161	16:00 07/10/2025	1.8	20.3117	7.3192	29.7692	676.1525	0.2325	136.2175
162	17:00 07/10/2025	1.8058	20.33	7.3517	29.7325	593.43	0.1783	295.3467
163	18:00 07/10/2025	1.7967	20.305	7.3167	29.6975	628.2	0.6308	950.0992
164	19:00 07/10/2025	1.7983	20.3542	7.31	29.8433	593.6292	1.1158	679.525
165	20:00 07/10/2025	1.805	20.3383	7.2833	29.6633	627.385	1.1458	778.0208

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
166	21:00 07/10/2025	1.8	20.3083	7.3183	29.6292	572.3392	0.9458	704.54
167	22:00 07/10/2025	1.8075	20.33	7.3217	29.5792	536.6575	0.8417	630.6833
168	23:00 07/10/2025	1.8033	20.3425	7.3625	29.6775	291.6167	0.9408	563.5767
169	00:00 08/10/2025	1.8	20.3067	7.3442	29.5892	764.5667	1.0017	720.7
170	01:00 08/10/2025	1.7975	20.3075	7.2717	29.5525	503.125	0.7408	639.8108
171	02:00 08/10/2025	1.79	20.3058	7.3308	29.5375	614.9467	0.7575	31.5183
172	03:00 08/10/2025	1.8	20.3342	7.3242	29.5792	616.4875	0.7625	1153.2525
173	04:00 08/10/2025	1.8	20.32	7.3225	29.5708	701.3583	0.8858	192.8233
174	05:00 08/10/2025	1.7975	20.3167	7.3467	29.5042	811.385	0.7825	301.175
175	06:00 08/10/2025	1.7908	20.3042	7.285	29.4983	546.0475	0.6392	1011.4642
176	07:00 08/10/2025	1.7908	20.3217	7.3825	29.5175	564.7642	0.8758	487.1383
177	08:00 08/10/2025	1.7992	20.3325	7.3117	29.47	709.5025	0.6408	631.7892
178	09:00 08/10/2025	1.7942	20.3108	7.3183	29.465	670.06	0.5975	708.6842
179	10:00 08/10/2025	1.7942	20.3042	7.2892	29.4933	644.1133	0.5467	668.4958
180	11:00 08/10/2025	1.7892	20.3358	7.2808	29.6858	522.9633	0.8492	672.7433
181	12:00 08/10/2025	1.7683	20.27	7.2933	29.6892	788.4075	1.6308	854.5433
182	13:00 08/10/2025	1.7717	20.2692	7.3008	29.73	751.9258	1.4575	698.6583
183	14:00 08/10/2025	1.77	20.26	7.3358	29.7958	747.855	1.5367	29.3092
184	15:00 08/10/2025	1.77	20.2725	7.3283	29.9417	242.0892	1.7308	1416.4875
185	16:00 08/10/2025	1.77	20.2658	7.285	29.9658	466.41	1.9483	268.6842
186	17:00 08/10/2025	1.7758	20.29	7.3142	29.9625	553.1275	2.085	278.7783
187	18:00 08/10/2025	1.7675	20.2533	7.3133	30.0025	458.3633	2.05	850.685
188	19:00 08/10/2025	1.77	20.3008	7.295	30.09	560.725	2.295	513.3608
189	20:00 08/10/2025	1.7708	20.275	7.2617	29.9925	658.8158	2.1958	763.5583
190	21:00 08/10/2025	1.77	20.27	7.2883	29.9767	689.3675	2.0608	50.8917
191	22:00 08/10/2025	1.7733	20.29	7.3033	29.9367	558.3433	1.9925	448.1383
192	23:00 08/10/2025	1.7717	20.3067	7.3108	29.9958	539.77	2.3275	656.0908
193	00:00 09/10/2025	1.77	20.2725	7.3042	29.9492	742.2317	2.5667	857.1425
194	01:00 09/10/2025	1.77	20.27	7.2708	29.8783	678.5542	2.2925	742.7583
195	02:00 09/10/2025	1.77	20.2717	7.325	29.8525	814.1917	2.3292	34.2717
196	03:00 09/10/2025	1.7725	20.2992	7.3592	29.835	533.4517	2.3717	1276.8883
197	04:00 09/10/2025	1.77	20.2825	7.3642	29.7892	701.0625	2.2858	214.185
198	05:00 09/10/2025	1.7708	20.2858	7.3783	29.755	730.1517	2.2583	348.9467
199	06:00 09/10/2025	1.7692	20.2758	7.32	29.745	489.0842	2.0217	975.9467
200	07:00 09/10/2025	1.7683	20.3067	7.335	29.8233	594.3658	2.3375	687.9708
201	08:00 09/10/2025	1.7767	20.3083	7.335	29.7108	707.4533	2.2958	734.1933
202	09:00 09/10/2025	1.7675	20.2725	7.3175	29.7225	776.93	1.9717	696.8242
203	10:00 09/10/2025	1.77	20.275	7.3042	29.74	583.4475	1.9192	630.9225
204	11:00 09/10/2025	1.77	20.3017	7.315	30.0525	190.7142	2.3042	634.7983
205	12:00 09/10/2025	1.77	20.2775	7.3125	30.0267	463.2817	2.8425	812.8575
206	13:00 09/10/2025	1.7717	20.2808	7.3225	30.05	498.5375	2.7358	675.2758
207	14:00 09/10/2025	1.7667	20.2717	7.36	30.1925	833.5442	2.625	19.1317

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
208	15:00 09/10/2025	1.7717	20.2875	7.3525	30.4058	526.55	0.7125	1225.7192
209	16:00 09/10/2025	1.77	20.2742	7.3308	30.3933	694.1917	0.8267	91.32
210	17:00 09/10/2025	1.775	20.305	7.3742	30.3708	660.255	0.7892	271.8283
211	18:00 09/10/2025	1.7675	20.2775	7.3433	30.4108	446.5067	0.7283	941.6375
212	19:00 09/10/2025	1.765	20.2933	7.3825	30.5525	596.1975	1.2567	479.1
213	20:00 09/10/2025	1.7692	20.2825	7.3217	30.2933	655.3525	1.0758	659.4042
214	21:00 09/10/2025	1.7708	20.2833	7.3808	30.3683	781.3817	0.8892	517.88
215	22:00 09/10/2025	1.7742	20.3042	7.3692	30.2725	742.5792	0.8683	478.7267
216	23:00 09/10/2025	1.7708	20.3092	7.3583	30.4092	311.7492	0.8925	645.6233
217	00:00 10/10/2025	1.77	20.2808	7.35	30.325	518.02	1.0117	789.9008
218	01:00 10/10/2025	1.77	20.2792	7.3175	30.1625	447.5917	0.7492	747.4833
219	02:00 10/10/2025	1.77	20.2833	7.355	30.1817	695.6183	0.7417	46.6258
220	03:00 10/10/2025	1.7725	20.3033	7.36	30.2592	530.3908	0.8683	1118.7025
221	04:00 10/10/2025	1.77	20.2867	7.3725	30.2433	507.0842	1.09	225.2817
222	05:00 10/10/2025	1.77	20.2825	7.4042	30.1058	532.4792	0.965	332.0875
223	06:00 10/10/2025	1.7708	20.2775	7.3625	30.0092	373.8042	0.6758	869.9242
224	07:00 10/10/2025	1.77	20.32	7.3808	30.1942	563.145	0.8	513.8875
225	08:00 10/10/2025	1.7775	20.3225	7.3858	29.95	693.6308	0.7858	713.6833
226	09:00 10/10/2025	1.77	20.2808	7.39	30.0125	630.325	0.5367	693.6808
227	10:00 10/10/2025	1.77	20.2858	7.3792	29.9983	621.7475	0.5333	619.7742
228	11:00 10/10/2025	1.77	20.2842	7.3608	29.9725	274.2267	0.3767	236.6342
229	12:00 10/10/2025	1.77	20.2817	7.375	30.1392	519.3717	0.4242	678.1833
230	13:00 10/10/2025	1.7717	20.2892	7.385	30.11	674.79	0.6175	693.8158
231	14:00 10/10/2025	1.77	20.2758	7.4208	30.2358	753.7058	0.6992	26.2658
232	15:00 10/10/2025	1.7717	20.2908	7.3717	30.3967	484.4767	0.9025	1078.4733
233	16:00 10/10/2025	1.77	20.2792	7.3658	30.4117	694.4108	1.0067	69.635
234	17:00 10/10/2025	1.775	20.2992	7.405	30.3792	829.5408	1.0408	258.2167
235	18:00 10/10/2025	1.77	20.2775	7.3625	30.4	662.5767	1.0033	917.1492
236	19:00 10/10/2025	1.7783	20.3192	7.3342	30.6292	551.9683	1.45	611.6675
237	20:00 10/10/2025	1.7708	20.2908	7.3117	30.3042	532.9575	1.4517	767.2817
238	21:00 10/10/2025	1.77	20.2858	7.3433	30.3925	667.9208	1.0283	672.71
239	22:00 10/10/2025	1.7758	20.3117	7.35	30.265	403.7958	1.0275	593.8425
240	23:00 10/10/2025	1.7717	20.3117	7.2758	30.4167	451.1617	0.8467	669.6342
241	00:00 11/10/2025	1.77	20.2833	7.3083	30.3433	745.1283	1.1208	791.4792
242	01:00 11/10/2025	1.77	20.2808	7.2858	30.0758	676.6608	0.7217	655.9717
243	02:00 11/10/2025	1.77	20.28	7.3217	30.1358	771.4175	0.6358	41.9192
244	03:00 11/10/2025	1.7725	20.2983	7.3367	30.1892	524.9833	0.7225	1172.1308
245	04:00 11/10/2025	1.77	20.2867	7.3517	30.11	696.1975	0.7675	102.7583
246	05:00 11/10/2025	1.7708	20.285	7.37	30.0225	709.8975	0.6842	281.9558
247	06:00 11/10/2025	1.77	20.2792	7.2925	29.9817	402.5425	0.4783	979.6183
248	07:00 11/10/2025	1.77	20.3083	7.2275	30.255	589.9658	0.645	679.305
249	08:00 11/10/2025	1.7767	20.3208	7.295	29.9517	589.7067	0.8542	737.05

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
250	09:00 11/10/2025	1.7708	20.285	7.3075	29.9867	478.8925	0.5025	684.4025
251	10:00 11/10/2025	1.7708	20.295	7.29	29.9383	326.9375	0.465	623.0358
252	11:00 11/10/2025	1.77	20.3033	7.2617	30.2667	217.23	0.5375	606.4533
253	12:00 11/10/2025	1.7717	20.2942	7.3075	30.0533	707.4742	0.8017	542.5217
254	13:00 11/10/2025	1.7725	20.2933	7.32	29.9083	536.3267	0.4208	579.1442
255	14:00 11/10/2025	1.77	20.2792	7.3742	30.0142	827.8542	0.3442	33.1658
256	15:00 11/10/2025	1.77	20.2908	7.3317	30.1667	532.5108	0.4425	981.0008
257	16:00 11/10/2025	1.77	20.2825	7.3242	30.1317	695.8608	0.5242	116.8783
258	17:00 11/10/2025	1.7742	20.2967	7.3533	30.1258	828.2475	0.575	263.5517
259	18:00 11/10/2025	1.77	20.2792	7.3175	30.0792	662.7817	0.4392	941.3492
260	19:00 11/10/2025	1.7708	20.3042	7.2467	30.425	556.8483	0.66	627.5233
261	20:00 11/10/2025	1.7708	20.2825	7.2717	29.9825	649.0275	0.7992	705.2025
262	21:00 11/10/2025	1.7708	20.2783	7.3083	30.0658	737.665	0.435	676.6683
263	22:00 11/10/2025	1.7758	20.3033	7.3192	29.9733	359.6517	0.4575	603.53
264	23:00 11/10/2025	1.7708	20.3108	7.245	30.2917	276.2942	0.4708	674.0192
265	00:00 12/10/2025	1.77	20.2783	7.2825	30.1142	743.7142	0.925	806.4183
266	01:00 12/10/2025	1.77	20.2733	7.2917	29.8567	533.235	0.4342	709.4167
267	02:00 12/10/2025	1.77	20.2783	7.3308	29.9242	749.4975	0.3858	41.2217
268	03:00 12/10/2025	1.7725	20.31	7.325	30.0342	556.9975	0.5083	1057.1733
269	04:00 12/10/2025	1.77	20.2975	7.3675	29.9392	688.1467	0.64	149.7092
270	05:00 12/10/2025	1.77	20.3008	7.4108	29.8658	796.7208	0.5625	271.2342
271	06:00 12/10/2025	1.77	20.295	7.3308	29.765	237.7933	0.3533	982.4383
272	07:00 12/10/2025	1.77	20.3158	7.265	30.1275	322.3258	0.4742	653.1333
273	08:00 12/10/2025	1.7758	20.3375	7.3192	29.7658	240.7533	0.6967	684.3333
274	09:00 12/10/2025	1.7717	20.3058	7.3658	29.7867	323.1458	0.3592	598.4133
275	10:00 12/10/2025	1.7708	20.3158	7.3367	29.7725	412.595	0.2958	522.8267
276	11:00 12/10/2025	1.7708	20.3233	7.2542	30.2283	489.5292	0.3858	610.615
277	12:00 12/10/2025	1.6225	18.6275	6.6958	27.5775	343.4725	0.7658	68.9017
278	13:00 12/10/2025	1.7733	20.3417	7.35	30.075	326.0667	0.6533	420.9133
279	14:00 12/10/2025	1.77	20.3333	7.3592	30.025	590.9308	0.5875	187.9967
280	15:00 12/10/2025	1.7717	20.3217	7.395	30.19	570.265	0.6867	557.2717
281	16:00 12/10/2025	1.7708	20.3108	7.3967	30.2558	640.4117	0.8642	274.105
282	17:00 12/10/2025	1.77	20.315	7.445	30.2883	824.8533	0.8917	9.3083
283	18:00 12/10/2025	1.7742	20.3208	7.42	30.3108	756.2933	0.9592	987.9625
284	19:00 12/10/2025	1.7725	20.315	7.3592	30.6108	385.3433	1.3908	474.5792
285	20:00 12/10/2025	1.7708	20.3275	7.3842	30.3825	423.9017	1.6925	312.9525
286	21:00 12/10/2025	1.7717	20.3167	7.3692	30.2583	136.2325	1.1242	984.5808
287	22:00 12/10/2025	1.77	20.32	7.3908	30.2483	324.9442	0.9967	214.8475
288	23:00 12/10/2025	1.7767	20.3567	7.3425	30.4275	242.9542	0.9692	951.8842
289	00:00 13/10/2025	1.7708	20.3258	7.3417	30.4133	569.0542	1.4392	336.3017
290	01:00 13/10/2025	1.77	20.3375	7.3825	30.2117	716.985	1.1233	465.8958
291	02:00 13/10/2025	1.77	20.3292	7.3858	30.1475	549.6792	0.8483	224.2275

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép Thời gian</u>	40,5	60,75	6 - 9	40		4,05	
292	03:00 13/10/2025	1.7708	20.3333	7.4192	30.1808	618.2725	0.8825	106.3592
293	04:00 13/10/2025	1.7775	20.3542	7.4025	30.0533	645.6575	0.8358	563.8142
294	05:00 13/10/2025	1.77	20.3383	7.4467	30.0767	829.0758	0.8308	38.6567
295	06:00 13/10/2025	1.7717	20.33	7.4208	30.0458	578.5142	0.8142	1164.255
296	07:00 13/10/2025	1.7708	20.3258	7.29	30.3883	477.7033	0.9275	702.0917
297	08:00 13/10/2025	1.7758	20.345	7.3258	30.1783	519.4825	1.47	380.52
298	09:00 13/10/2025	1.7767	20.3275	7.3808	30.0233	435.0183	0.9308	944.85
299	10:00 13/10/2025	1.77	20.325	7.3917	30.0675	323.34	0.7483	228.75
300	11:00 13/10/2025	1.7725	20.3342	7.3417	30.3558	225.4383	0.8042	1004.8192
301	12:00 13/10/2025	1.7708	20.3133	7.3833	30.37	472.2642	1.4875	419.8092
302	13:00 13/10/2025	1.7767	20.3408	7.3783	30.2408	531.4383	1.2675	443.3808
303	14:00 13/10/2025	1.775	20.3233	7.3908	30.2433	595.9375	1.1842	205.195
304	15:00 13/10/2025	1.7725	20.3175	7.3383	30.6608	609.3792	1.4967	438.7758
305	16:00 13/10/2025	1.7708	20.3092	7.305	30.2858	641.7342	1.7558	590.9525
306	17:00 13/10/2025	1.77	20.2975	7.3483	30.34	831.7925	1.4125	26.5892
307	18:00 13/10/2025	1.7717	20.3	7.3525	30.2858	752.5933	1.2575	1015.1017
308	19:00 13/10/2025	1.7717	20.2925	7.3642	30.4542	477.8292	1.35	455.8192
309	20:00 13/10/2025	1.7708	20.2942	7.3475	30.2742	731.5967	1.4125	296.47
310	21:00 13/10/2025	1.7717	20.2975	7.3117	30.195	516.0025	1.0808	970.05
311	22:00 13/10/2025	1.77	20.29	7.3283	30.1708	531.2125	1.1075	229.955
312	23:00 13/10/2025	1.7767	20.32	7.2717	30.31	510.0383	1.1217	944.5775
313	00:00 14/10/2025	1.7708	20.2892	7.2825	30.2975	585.6342	1.5883	740.84
314	01:00 14/10/2025	1.77	20.2967	7.2933	30.0892	356.8758	1.2592	659.5042
315	02:00 14/10/2025	1.77	20.2908	7.2867	30.0333	307.0767	0.99	233.695
316	03:00 14/10/2025	1.7725	20.2925	7.3467	30.165	576.2075	1.1233	887.0683
317	04:00 14/10/2025	1.7742	20.31	7.3317	29.9867	456.1967	1.0317	595.8467
318	05:00 14/10/2025	1.77	20.2942	7.37	30.0233	841.2367	0.9367	28.2558
319	06:00 14/10/2025	1.7708	20.2967	7.3367	29.9517	756.7575	0.8642	929.5375
320	07:00 14/10/2025	1.7717	20.2983	7.3117	30.1967	523.2925	0.91	360.5342
321	08:00 14/10/2025	1.7758	20.3092	7.3233	29.9925	788.225	1.15	290.4692
322	09:00 14/10/2025	1.7725	20.3017	7.3142	29.8283	695.6525	0.6883	949.7425
323	10:00 14/10/2025	1.77	20.2917	7.3267	29.8158	440.05	0.5525	232.505
324	11:00 14/10/2025	1.7733	20.2967	7.2908	29.9092	188.665	0.5183	987.1475
325	12:00 14/10/2025	1.7708	20.2925	7.3092	29.8975	327.5692	0.7142	664.605
326	13:00 14/10/2025	1.7775	20.2983	7.3075	29.7967	538.025	0.4992	636.7867
327	14:00 14/10/2025	1.7742	20.2825	7.3092	29.7958	527.33	0.3733	201.2017
328	15:00 14/10/2025	1.775	20.2908	7.3	30.1642	581.2917	0.5625	501.2267
329	16:00 14/10/2025	1.7708	20.2692	7.2708	29.8717	404.465	0.7192	667.4408
330	17:00 14/10/2025	1.77	20.27	7.3192	29.8917	718.615	0.5642	23.5817
331	18:00 14/10/2025	1.775	20.2883	7.3492	29.8475	784.6425	0.545	974.0783
332	19:00 14/10/2025	1.7725	20.2875	7.36	29.7908	497.0025	0.5042	254.6633
333	20:00 14/10/2025	1.7725	20.2825	7.3808	29.7517	569.6083	0.4892	278.455

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u> <u>Thời gian</u>	40,5	60,75	6 - 9	40		4,05	
334	21:00 14/10/2025	1.7725	20.2883	7.3408	29.7683	199.2592	0.4283	969.6258
335	22:00 14/10/2025	1.77	20.2842	7.3508	29.7217	450.9125	0.4408	223.8375
336	23:00 14/10/2025	1.7842	20.315	7.3467	29.8158	288.8475	0.4467	815.0842
337	00:00 15/10/2025	1.7775	20.2883	7.3775	29.7483	685.4258	0.5192	445.9458
338	01:00 15/10/2025	1.7742	20.2883	7.345	29.7058	693.6508	0.375	486.4933
339	02:00 15/10/2025	1.77	20.28	7.3183	29.66	688.8917	0.2983	229.65
340	03:00 15/10/2025	1.78	20.3108	7.3842	29.825	586.305	0.445	520.6167
341	04:00 15/10/2025	1.7833	20.3058	7.3508	29.6342	653.5008	0.4058	555.7425
342	05:00 15/10/2025	1.78	20.295	7.4183	29.6383	770.02	0.325	29.395
343	06:00 15/10/2025	1.78	20.2908	7.3792	29.6017	636.7433	0.2325	1103.3833
344	07:00 15/10/2025	1.775	20.3042	7.3217	29.7525	533.3933	0.2875	772.9225
345	08:00 15/10/2025	1.775	20.3008	7.3208	29.6633	802.9883	0.42	421.645
346	09:00 15/10/2025	1.78	20.2892	7.3592	29.5625	727.74	0.1717	916.4692
347	10:00 15/10/2025	1.78	20.285	7.3683	29.5617	475.8817	0.1142	230.5325
348	11:00 15/10/2025	1.7808	20.3008	7.3317	29.765	165.7242	0.1217	983.8658
349	12:00 15/10/2025	1.78	20.2967	7.3375	29.8367	624.1933	0.2808	648.9017
350	13:00 15/10/2025	1.7858	20.3133	7.3383	29.7975	600.2125	0.2333	627.5075
351	14:00 15/10/2025	1.78	20.2983	7.3542	29.8592	730.2142	0.2767	190.9025
352	15:00 15/10/2025	1.7817	20.3133	7.36	30.1267	626.5633	0.4825	581.8775
353	16:00 15/10/2025	1.78	20.2792	7.3392	30.01	579.4258	0.62	635.5283
354	17:00 15/10/2025	1.78	20.2792	7.4025	30.0258	674.6017	0.6133	18.5017
355	18:00 15/10/2025	1.7808	20.2892	7.3992	30.0017	785.4283	0.5392	975.5208
356	19:00 15/10/2025	1.78	20.31	7.3717	30.18	527.5967	0.6367	660.2017
357	20:00 15/10/2025	1.78	20.2975	7.3667	30.0342	686.5358	0.795	356.5067
358	21:00 15/10/2025	1.78	20.2833	7.3467	29.9642	615.6683	0.495	967.7908
359	22:00 15/10/2025	1.78	20.2808	7.3583	29.9317	749.9267	0.5183	233.2533
360	23:00 15/10/2025	1.7842	20.3217	7.3667	29.9625	515.7733	0.5475	882.7533
361	00:00 16/10/2025	1.7742	20.295	7.36	29.9525	776.5817	0.6408	647.2192
362	01:00 16/10/2025	1.775	20.2833	7.3375	29.8683	659.0125	0.5825	664.0767
363	02:00 16/10/2025	1.7717	20.2775	7.3225	29.8233	447.3875	0.4883	246.2175
364	03:00 16/10/2025	1.7808	20.3008	7.3133	29.9567	582.6033	0.5575	1029.6375
365	04:00 16/10/2025	1.7833	20.3133	7.3367	29.8208	625.2317	0.605	795.1642
366	05:00 16/10/2025	1.78	20.2917	7.3683	29.7958	834.5367	0.5142	26.0467
367	06:00 16/10/2025	1.78	20.2908	7.3442	29.6733	658.2575	0.3433	1117.7617
368	07:00 16/10/2025	1.7808	20.3092	7.31	29.8517	372.4883	0.42	666.1167
369	08:00 16/10/2025	1.7825	20.3025	7.2983	29.7158	528.1075	0.4633	294.89
370	09:00 16/10/2025	1.7767	20.2933	7.3033	29.6442	483.8325	0.245	909.6717
371	10:00 16/10/2025	1.7708	20.2875	7.3233	29.6575	548.2025	0.2192	226.6067
372	11:00 16/10/2025	1.775	20.2992	7.2708	29.8983	429.8658	0.2225	1018.0583
373	12:00 16/10/2025	1.77	20.3	7.24	30.04	594.0692	0.33	910.56
374	13:00 16/10/2025	1.8475	9.4333	7.2758	29.9875	540.9083	0.5558	694.6325
375	14:00 16/10/2025	1.905	3.9842	7.3483	29.9883	504.1717	0.96	189.46

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
376	15:00 16/10/2025	1.8883	4.0117	7.3408	30.3008	587.53	1.105	929.18
377	16:00 16/10/2025	1.8358	3.9892	7.3217	30.145	379.4392	1.1933	714.3633
378	17:00 16/10/2025	1.8133	3.9842	7.375	30.1233	768.8325	1.15	23.905
379	18:00 16/10/2025	1.805	3.9917	7.4108	30.1175	732.9175	1.1067	972.3783
380	19:00 16/10/2025	1.78	4.0033	7.4275	30.0383	530.9058	1.095	295.72
381	20:00 16/10/2025	1.7633	4.0067	7.4383	29.9575	718.3133	1.0542	257.86
382	21:00 16/10/2025	1.7892	3.9908	7.3825	29.9667	619.3783	1.0125	973.3125
383	22:00 16/10/2025	1.7667	3.9883	7.3858	29.9017	734.5017	1.0375	243.7708
384	23:00 16/10/2025	1.7808	4.0417	7.3908	29.9567	254.1125	1.0408	809.0167
385	00:00 17/10/2025	1.7725	3.9942	7.3775	29.9258	671.3817	1.0783	588.8283
386	01:00 17/10/2025	1.7733	3.9933	7.33	29.8558	695.7392	1.0558	688.6667
387	02:00 17/10/2025	1.765	3.9833	7.3167	29.7933	668.1458	1.0033	233.0992
388	03:00 17/10/2025	1.7808	4.0975	7.3208	29.9608	629.96	1.0533	798.2775
389	04:00 17/10/2025	1.7783	4.0483	7.3392	29.7725	657.145	1.0658	647.9842
390	05:00 17/10/2025	1.7675	4.02	7.3725	29.7617	849.6408	1.01	26.6083
391	06:00 17/10/2025	1.7658	4.0092	7.3367	29.7	671.0025	0.9625	1106.4417
392	07:00 17/10/2025	1.6242	3.6925	6.6442	27.3725	490.0742	0.8892	685.47
393	08:00 17/10/2025	1.7667	4.0075	7.265	29.7475	799.2392	1.0367	399.6883
394	09:00 17/10/2025	1.7692	3.995	7.335	29.6075	482.3342	0.9117	906.7133
395	10:00 17/10/2025	1.7625	3.9925	7.3475	29.6417	546.5425	0.8875	234.765
396	11:00 17/10/2025	1.77	4.015	7.2842	29.885	162.1	0.89	997.1392
397	12:00 17/10/2025	1.7675	4.0075	7.3108	29.97	530.0075	1.0625	599.5192
398	13:00 17/10/2025	1.77	4.0292	7.3383	29.8733	556.5192	1.0308	434.2375
399	14:00 17/10/2025	1.7708	4.0108	7.3608	29.9725	699.6575	1.0267	182.8142
400	15:00 17/10/2025	1.7717	4.0433	7.2883	30.4742	589.9833	1.14	409.3567
401	16:00 17/10/2025	1.7633	3.9867	7.2942	30.1642	568.6717	1.2875	595.6783
402	17:00 17/10/2025	1.76	3.995	7.3425	30.1608	842.9958	1.1217	8.2533
403	18:00 17/10/2025	1.7633	3.9975	7.3733	30.1542	760.8217	1.13	869.6175
404	19:00 17/10/2025	1.7642	4.0475	7.2875	30.395	488.7442	1.2042	499.6792
405	20:00 17/10/2025	1.7617	4.0158	7.3	30.2808	743.7067	1.3708	397.9217
406	21:00 17/10/2025	1.7617	3.9883	7.3325	30.115	603.5208	1.1583	958.0858
407	22:00 17/10/2025	1.76	3.9817	7.335	30.0917	733.6617	1.1367	231.5367
408	23:00 17/10/2025	1.7717	4.0375	7.315	30.1267	518.3575	1.1067	901.2258
409	00:00 18/10/2025	1.7625	3.9975	7.3183	30.16	774.2225	1.1758	703.6225
410	01:00 18/10/2025	1.765	3.9808	7.325	29.9908	659.7167	1.1217	686.3217
411	02:00 18/10/2025	1.76	3.9825	7.3217	29.9067	634.6833	1.0417	234.8642
412	03:00 18/10/2025	1.7675	4.0292	7.3058	30.0842	337.3192	1.095	1016.295
413	04:00 18/10/2025	1.7683	4.025	7.33	29.9017	446.3583	1.1567	809.7433
414	05:00 18/10/2025	1.76	4.0158	7.3625	29.905	567.3375	1.1083	29.5475
415	06:00 18/10/2025	1.7625	4.0133	7.355	29.835	588.4258	1.0925	932.3742
416	07:00 18/10/2025	1.7642	4.0475	7.2667	30.0833	486.1067	1.0917	556.0308
417	08:00 18/10/2025	1.7633	4.0325	7.2942	29.9717	731.2633	1.2458	394.7942

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
418	09:00 18/10/2025	1.77	4.0325	7.3792	29.755	400.0775	1.0775	507.2083
419	10:00 18/10/2025	1.77	4.0358	7.4208	29.8167	539.5442	1.0242	21.4067
420	11:00 18/10/2025	1.7758	4.0767	7.3233	30.0883	333.6617	1.0133	1002.3383
421	12:00 18/10/2025	1.7675	4.0358	7.3692	30.1258	572.8175	1.2117	554.57
422	13:00 18/10/2025	1.7783	4.0692	7.3867	29.9892	776.9133	1.1358	420.8967
423	14:00 18/10/2025	1.77	4.0433	7.3942	30.0608	691.6825	1.1058	189.595
424	15:00 18/10/2025	1.7708	4.0675	7.3058	30.6708	587.7908	1.24	455.5467
425	16:00 18/10/2025	1.7625	4.0275	7.3317	30.2542	583.4558	1.4192	668.94
426	17:00 18/10/2025	1.76	4.0367	7.3667	30.2675	826.0817	1.2517	9.9367
427	18:00 18/10/2025	1.7675	4.045	7.3942	30.25	817.5817	1.2708	932.4267
428	19:00 18/10/2025	1.7692	4.0767	7.3275	30.5933	582.8608	1.3942	661.24
429	20:00 18/10/2025	1.7692	4.0592	7.3542	30.3708	796.1975	1.6283	331.595
430	21:00 18/10/2025	1.7708	4.0308	7.3833	30.2008	807.6458	1.3425	973.3992
431	22:00 18/10/2025	1.7658	4.0342	7.3875	30.1867	643.2442	1.3158	253.5408
432	23:00 18/10/2025	1.7725	4.0733	7.3658	30.2558	329.8033	1.2842	877.4
433	00:00 19/10/2025	1.7692	4.0458	7.36	30.2408	522.2217	1.3825	638.8592
434	01:00 19/10/2025	1.7692	4.0442	7.3725	30.0758	760.8308	1.305	681.7167
435	02:00 19/10/2025	1.7717	4.0533	7.3783	29.9933	840.01	1.2125	257.6208
436	03:00 19/10/2025	1.7717	4.085	7.3508	30.2967	598.7492	1.2933	604.4958
437	04:00 19/10/2025	1.775	4.0783	7.3908	30.0	710.1208	1.4075	653.3725
438	05:00 19/10/2025	1.77	4.0567	7.4467	30.02	831.2967	1.31	26.795
439	06:00 19/10/2025	1.77	4.0542	7.3967	29.9475	702.44	1.2642	1067.6625
440	07:00 19/10/2025	1.6225	3.7383	6.6975	27.66	336.2408	1.16	684.6892
441	08:00 19/10/2025	1.7683	4.0717	7.3092	30.0492	520.775	1.4067	385.5333
442	09:00 19/10/2025	1.7708	4.0883	7.3642	29.8892	303.6192	1.2075	893.8342
443	10:00 19/10/2025	1.77	4.0875	7.3658	29.9267	327.68	1.1525	232.25
444	11:00 19/10/2025	1.7708	4.11	7.3025	30.125	284.7775	1.1192	967.91
445	12:00 19/10/2025	1.77	4.105	7.3117	30.165	585.1408	1.285	246.4567
446	13:00 19/10/2025	1.7775	4.1508	7.3558	30.0908	684.7667	1.2175	383.51
447	14:00 19/10/2025	1.77	4.1358	7.37	30.0975	540.0358	1.2025	192.7908
448	15:00 19/10/2025	1.7717	4.1325	7.4267	30.345	590.0817	1.325	552.3942
449	16:00 19/10/2025	1.7708	4.1158	7.3092	30.1317	590.7192	1.2967	597.9717
450	17:00 19/10/2025	1.77	4.1117	7.3742	30.2058	807.5333	1.2908	22.3083
451	18:00 19/10/2025	1.7725	15.0383	7.3683	30.1767	539.1283	1.2542	939.4608
452	19:00 19/10/2025	1.7708	15.0792	7.3808	30.3775	246.5125	1.3383	493.885
453	20:00 19/10/2025	1.77	15.045	7.3658	30.1708	465.5225	1.3817	241.2733
454	21:00 19/10/2025	1.7708	14.9525	7.3433	30.0633	599.945	1.2317	847.0483
455	22:00 19/10/2025	1.77	14.96	7.3558	30.0275	631.4125	1.2258	58.7092
456	23:00 19/10/2025	1.7742	15.0617	7.3417	30.1683	506.2492	1.2583	903.6042
457	00:00 20/10/2025	1.7708	14.9808	7.375	30.1767	433.1875	1.4525	411.0408
458	01:00 20/10/2025	1.7708	14.9725	7.3567	29.9625	305.2942	1.3083	424.3125
459	02:00 20/10/2025	1.77	14.9267	7.3275	29.8767	323.1692	1.1792	237.55

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
460	03:00 20/10/2025	1.7717	15.0233	7.38	30.085	320.5233	1.2392	923.8275
461	04:00 20/10/2025	1.7742	15.0467	7.3458	29.8575	317.32	1.2475	717.5458
462	05:00 20/10/2025	1.77	15.0092	7.39	29.8817	552.3183	1.18	28.1375
463	06:00 20/10/2025	1.7708	14.9917	7.3217	29.7992	478.8958	1.1292	575.795
464	07:00 20/10/2025	1.77	14.9917	7.3283	29.77	239.9892	1.0875	79.6125
465	08:00 20/10/2025	1.7733	15.0408	7.3642	29.7692	319.9142	1.085	239.6933
466	09:00 20/10/2025	1.7742	15.1542	7.3217	29.7242	239.4067	1.0675	320.6283
467	10:00 20/10/2025	1.78	15.3658	7.3258	29.4917	376.6817	1.0275	7.8617
468	11:00 20/10/2025	1.82	15.31	7.3325	29.8317	225.0883	0.8083	425.7408
469	12:00 20/10/2025	1.77	15.0625	7.3825	30.1467	359.7975	0.965	83.2492
470	13:00 20/10/2025	1.77	15.1242	7.4792	30.1117	441.0667	0.9042	3.9217
471	14:00 20/10/2025	1.77	15.2108	7.5025	30.2708	351.7	0.8658	1.0975
472	15:00 20/10/2025	1.78	15.3767	7.4692	30.3433	249.6167	0.8775	492.1008
473	16:00 20/10/2025	1.7792	15.3625	7.3933	30.15	516.0533	0.9333	168.5725
474	17:00 20/10/2025	1.78	15.3525	7.4175	30.0908	783.5592	0.9742	205.825
475	18:00 20/10/2025	1.7733	15.2233	7.35	30.0675	736.0842	0.975	915.5158
476	19:00 20/10/2025	1.7708	15.2342	7.3533	30.3367	582.7575	1.1108	605.67
477	20:00 20/10/2025	1.7756	15.37	7.3589	30.0356	701.7756	1.2367	541.2244
478	21:00 20/10/2025	1.7725	15.2967	7.3508	30.0042	810.4917	1.1017	594.9308
479	22:00 20/10/2025	1.7767	15.3083	7.3283	29.9208	637.3817	1.09	663.6358
480	23:00 20/10/2025	1.7708	15.2558	7.3508	30.1217	444.685	1.1233	684.6233
481	00:00 21/10/2025	1.7725	15.24	7.3342	29.9258	532.1775	1.23	708.4833
482	01:00 21/10/2025	1.775	15.4375	7.3592	29.7175	505.3017	1.1083	809.75
483	02:00 21/10/2025	1.77	15.36	7.3917	29.6758	792.995	1.0567	33.2017
484	03:00 21/10/2025	1.7725	15.3617	7.38	29.695	529.4492	1.0275	1226.2642
485	04:00 21/10/2025	1.77	15.2758	7.3567	29.6375	461.07	1.0167	206.6733
486	05:00 21/10/2025	1.775	15.3633	7.3967	29.5225	610.2433	0.9825	216.7683
487	06:00 21/10/2025	1.7758	15.4	7.3925	29.425	598.805	0.9142	854.5608
488	07:00 21/10/2025	1.7717	15.4092	7.3742	29.6483	583.2	0.9167	557.8833
489	08:00 21/10/2025	1.7717	15.3333	7.3275	29.4358	656.2142	0.965	747.8742
490	09:00 21/10/2025	1.7717	15.3267	7.3675	29.3508	762.1075	0.8667	569.4917
491	10:00 21/10/2025	1.7767	15.4225	7.3792	29.3167	544.5992	0.8092	594.8467
492	11:00 21/10/2025	1.7775	15.4575	7.39	29.3458	250.5508	0.7967	233.8625
493	12:00 21/10/2025	1.7733	15.3942	7.3992	29.415	527.07	0.8042	524.3558
494	13:00 21/10/2025	1.7722	15.3311	7.3311	29.4867	571.7833	0.8044	1030.8256
495	14:00 21/10/2025	1.77	15.375	7.42	29.485	611.64	0.84	5.33
496	15:00 21/10/2025	1.7817	15.5567	7.39	29.6525	585.3425	0.855	851.8575
497	16:00 21/10/2025	1.7725	15.49	7.3825	29.6708	555.2833	0.9267	193.2992
498	17:00 21/10/2025	1.7758	15.4808	7.4092	29.5725	606.9575	0.8917	210.9908
499	18:00 21/10/2025	1.7792	15.395	7.355	29.45	569.025	0.8175	915.1767
500	19:00 21/10/2025	1.7808	15.5742	7.405	29.7258	585.3767	0.8658	650.6525
501	20:00 21/10/2025	1.7833	15.5892	7.39	29.4717	744.0233	0.9358	681.9208

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u> <u>Thời gian</u>	40,5	60,75	6 - 9	40		4,05	
502	21:00 21/10/2025	1.7808	15.4617	7.4242	29.3525	790.5117	0.8425	577.325
503	22:00 21/10/2025	1.78	15.4333	7.3917	29.2892	734.7217	0.7983	612.11
504	23:00 21/10/2025	1.7775	15.4692	7.4033	29.385	467.5683	0.8242	546.565
505	00:00 22/10/2025	1.78	15.4075	7.3858	29.2383	571.1458	0.8183	565.09
506	01:00 22/10/2025	1.7808	15.5842	7.3892	29.1308	449.8808	0.7475	788.2333
507	02:00 22/10/2025	1.78	15.5458	7.43	29.0942	397.2608	0.7283	24.33
508	03:00 22/10/2025	1.7808	15.5392	7.4017	29.1442	287.4875	0.7117	1286.07
509	04:00 22/10/2025	1.78	15.4567	7.3683	29.1225	498.1592	0.7183	302.7733
510	05:00 22/10/2025	1.7858	15.5483	7.4042	29.0225	803.7817	0.705	205.9583
511	06:00 22/10/2025	1.785	15.6975	7.4025	28.8783	731.9008	0.6542	408.1692
512	07:00 22/10/2025	1.7808	15.5658	7.4225	28.9808	577.0683	0.6508	406.2983
513	08:00 22/10/2025	1.7808	15.4808	7.365	28.82	521.125	0.6342	675.4458
514	09:00 22/10/2025	1.7808	15.49	7.4033	28.735	539.6908	0.5983	551.5458
515	10:00 22/10/2025	1.785	15.6433	7.405	28.7083	369.8508	0.5625	570.34
516	11:00 22/10/2025	1.7833	15.6842	7.3708	28.9733	250.5175	0.5692	586.8767
517	12:00 22/10/2025	1.7817	15.5775	7.4433	28.7933	640.0033	0.6275	436.0383
518	13:00 22/10/2025	1.7808	15.5117	7.375	28.8175	539.5533	0.5342	595.9158
519	14:00 22/10/2025	1.78	15.4975	7.4342	28.8483	711.77	0.5408	8.7983
520	15:00 22/10/2025	1.7825	15.6825	7.4275	28.9758	603.9067	0.5492	872.7108
521	16:00 22/10/2025	1.78	15.7467	7.4408	28.945	636.435	0.5542	103.045
522	17:00 22/10/2025	1.7808	15.7283	7.4667	28.9425	838.0117	0.5533	200.01
523	18:00 22/10/2025	1.7808	15.5667	7.4008	28.8617	553.0917	0.5442	923.8267
524	19:00 22/10/2025	1.78	15.6492	7.3758	29.015	519.4958	0.5675	637.21
525	20:00 22/10/2025	1.7892	15.8483	7.3892	28.8583	711.3492	0.6	603.6142
526	21:00 22/10/2025	1.7808	15.67	7.4167	28.7742	780.8492	0.5758	570.2533
527	22:00 22/10/2025	1.7808	15.62	7.3892	28.7217	743.3408	0.5533	607.4717
528	23:00 22/10/2025	1.78	15.6233	7.3192	28.8783	184.1517	0.5608	675.2267
529	00:00 23/10/2025	1.7808	15.575	7.3442	28.7417	524.5967	0.595	676.5008
530	01:00 23/10/2025	1.7892	15.7883	7.3883	28.63	549.9967	0.5392	793.9775
531	02:00 23/10/2025	1.78	15.7475	7.425	28.5825	823.665	0.5283	24.3983
532	03:00 23/10/2025	1.7842	15.7058	7.3575	28.61	499.0717	0.5108	1099.4942
533	04:00 23/10/2025	1.78	15.5825	7.34	28.5708	629.8208	0.5192	228.1883
534	05:00 23/10/2025	1.7867	15.6983	7.395	28.4767	840.605	0.505	191.7858
535	06:00 23/10/2025	1.7875	15.7742	7.3792	28.3675	674.4758	0.4742	838.9933
536	07:00 23/10/2025	1.7817	15.735	7.2833	28.47	514.9883	0.465	587.3842
537	08:00 23/10/2025	1.7825	15.615	7.2958	28.3725	654.8342	0.4758	752.0192
538	09:00 23/10/2025	1.7808	15.65	7.3275	28.225	629.9033	0.4575	562.7267
539	10:00 23/10/2025	1.7875	15.8025	7.3508	28.1867	330.2042	0.4342	607.9633
540	11:00 23/10/2025	1.7858	15.86	7.3067	28.3217	253.1892	0.4383	634.8833
541	12:00 23/10/2025	1.7808	15.7167	7.3525	28.1892	687.5917	0.4442	555.1125
542	13:00 23/10/2025	1.7817	15.6525	7.325	28.2917	570.4583	0.4283	806.9617
543	14:00 23/10/2025	1.78	15.6675	7.3433	28.3283	680.4908	0.4517	317.9158

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
544	15:00 23/10/2025	1.79	15.8483	7.3858	28.2775	837.005	0.4358	384.1908
545	16:00 23/10/2025	1.7908	15.9025	7.4025	28.2417	502.9667	0.4283	726.5117
546	17:00 23/10/2025	1.7825	15.8258	7.355	28.3383	350.6417	0.4375	781.4033
547	18:00 23/10/2025	1.7867	15.7067	7.35	28.2233	562.5367	0.4242	502.1292
548	19:00 23/10/2025	1.785	15.8092	7.4075	28.175	705.9942	0.4283	847.3542
549	20:00 23/10/2025	1.78	15.8725	7.3817	28.2492	672.8742	0.4433	319.0867
550	21:00 23/10/2025	1.7817	15.7967	7.3892	28.1383	461.65	0.4208	498.78
551	22:00 23/10/2025	1.7817	15.795	7.3758	28.0975	274.325	0.4142	592.7725
552	23:00 23/10/2025	1.7808	15.7758	7.3175	28.1483	624.7783	0.4075	771.5958
553	00:00 24/10/2025	1.7825	15.8208	7.3533	28.07	852.6392	0.4117	576.9333
554	01:00 24/10/2025	1.7808	15.8933	7.3242	28.1475	651.4017	0.4158	364.6817
555	02:00 24/10/2025	1.7833	15.8383	7.3592	28.075	327.75	0.4158	664.7917
556	03:00 24/10/2025	1.7817	15.8558	7.3425	28.0283	597.8583	0.4033	676.0233
557	04:00 24/10/2025	1.7833	15.8558	7.3208	28.0583	796.4617	0.4017	747.585
558	05:00 24/10/2025	1.7858	15.8117	7.3683	27.9817	706.8742	0.395	430.55
559	06:00 24/10/2025	1.7817	15.9158	7.3442	28.0608	671.9717	0.4067	356.5242
560	07:00 24/10/2025	1.7883	15.8083	7.3392	28.0283	526.2417	0.3942	830.7167
561	08:00 24/10/2025	1.7908	15.8517	7.3008	27.9567	373.4833	0.3892	880.1367
562	09:00 24/10/2025	1.785	15.8308	7.3158	27.9817	520.9108	0.39	635.665
563	10:00 24/10/2025	1.7858	15.8667	7.3408	27.9617	640.6608	0.3833	337.1167
564	11:00 24/10/2025	1.7808	15.9117	7.325	28.0375	616.8675	0.4	404.5992
565	12:00 24/10/2025	1.7842	15.7475	7.34	28.0142	527.1667	0.375	622.6633
566	13:00 24/10/2025	1.7883	15.7092	7.2575	27.8592	463.4583	0.3508	617.8375
567	14:00 24/10/2025	1.7875	15.7192	7.3483	27.9675	803.5967	0.35	650.0583
568	15:00 24/10/2025	1.79	15.8742	7.3208	27.9967	643.2458	0.35	293.24
569	16:00 24/10/2025	1.7858	15.9225	7.2892	28.0667	740.7542	0.3675	258.8617
570	17:00 24/10/2025	1.7808	15.7542	7.3433	27.9858	527.6708	0.35	683.8767
571	18:00 24/10/2025	1.7867	15.72	7.2567	27.8442	824.4458	0.3317	640.4575
572	19:00 24/10/2025	1.7892	15.7667	7.3133	27.845	741.9117	0.3358	18.8425
573	20:00 24/10/2025	1.7833	15.7525	7.3417	27.8892	601.7617	0.3325	687.5108
574	21:00 24/10/2025	1.7967	16.1833	7.3475	28.0033	491.0333	0.36	583.2892
575	22:00 24/10/2025	1.79	15.8158	7.3092	27.8492	646.5742	0.3583	272.8625
576	23:00 24/10/2025	1.7858	15.7075	7.2958	27.8275	462.71	0.34	1047.1525
577	00:00 25/10/2025	1.78	15.7075	7.2967	27.7625	406.64	0.34	141.315
578	01:00 25/10/2025	1.7958	16.3717	7.3525	27.7983	242.8417	0.355	839.8108
579	02:00 25/10/2025	1.7942	16.0517	7.395	27.7292	577.2092	0.3483	416.1733
580	03:00 25/10/2025	1.7917	16.1075	7.3667	27.6925	736.6342	0.3392	414.5567
581	04:00 25/10/2025	1.79	15.9158	7.3142	27.6825	466.8975	0.335	239.6575
582	05:00 25/10/2025	1.79	16.12	7.3083	27.8325	529.0592	0.3475	488.4458
583	06:00 25/10/2025	1.81	17.0133	7.4833	27.5958	750.52	0.3583	621.3392
584	07:00 25/10/2025	1.8	16.7717	7.4883	27.6042	657.4275	0.34	24.2617
585	08:00 25/10/2025	1.795	16.3008	7.3825	27.6408	470.225	0.3233	1216.0

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
586	09:00 25/10/2025	1.7908	16.2242	7.3133	27.7875	246.9658	0.3408	513.3425
587	10:00 25/10/2025	1.795	16.2933	7.35	27.7033	566.4117	0.3425	225.2642
588	11:00 25/10/2025	1.7975	16.4817	7.4292	27.7133	308.4425	0.3392	992.9425
589	12:00 25/10/2025	1.7992	16.745	7.4717	27.7033	743.9642	0.3392	119.4617
590	13:00 25/10/2025	1.7933	16.415	7.3533	27.8717	468.605	0.335	852.6058
591	14:00 25/10/2025	1.7908	16.3258	7.3692	27.7817	789.0367	0.3458	104.235
592	15:00 25/10/2025	1.7992	16.7817	7.45	27.8283	576.0658	0.3492	376.5433
593	16:00 25/10/2025	1.81	17.3092	7.535	27.8317	450.9667	0.355	263.0583
594	17:00 25/10/2025	1.795	16.5375	7.375	27.9492	539.9417	0.3425	1001.8283
595	18:00 25/10/2025	1.7925	16.5	7.3375	27.9292	465.7733	0.345	705.56
596	19:00 25/10/2025	1.79	16.4483	7.3667	27.9283	589.4533	0.3575	18.8917
597	20:00 25/10/2025	1.8	16.9217	7.4642	27.8517	344.6558	0.365	932.8508
598	21:00 25/10/2025	1.7925	16.9067	7.3575	27.9942	414.1375	0.3625	588.3033
599	22:00 25/10/2025	1.8	17.0775	7.4558	27.8567	823.9067	0.3808	251.4008
600	23:00 25/10/2025	1.7917	16.6108	7.3675	27.8358	570.47	0.3492	579.4817
601	00:00 26/10/2025	1.79	16.6725	7.4092	27.8183	542.5633	0.3533	17.025
602	01:00 26/10/2025	1.8042	17.3217	7.4742	27.8383	225.2358	0.3667	899.4425
603	02:00 26/10/2025	1.8008	16.8817	7.4567	27.7167	658.6817	0.3533	601.6933
604	03:00 26/10/2025	1.8008	16.9833	7.4267	27.75	672.0258	0.3417	426.505
605	04:00 26/10/2025	1.7983	16.8667	7.3558	27.7842	617.9092	0.3442	245.9467
606	05:00 26/10/2025	1.7925	17.0233	7.2808	27.9217	543.4133	0.355	577.3083
607	06:00 26/10/2025	1.8125	17.7692	7.5158	27.7608	675.8908	0.3783	638.7742
608	07:00 26/10/2025	1.8083	17.5825	7.5175	27.7383	338.5433	0.36	25.3833
609	08:00 26/10/2025	1.8	17.1	7.4375	27.7	468.8033	0.3417	1224.455
610	09:00 26/10/2025	1.7908	16.98	7.39	27.83	253.3842	0.35	585.6692
611	10:00 26/10/2025	1.7958	17.0333	7.41	27.805	585.9825	0.3508	218.8575
612	11:00 26/10/2025	1.8058	17.3733	7.5325	27.8	466.8283	0.3492	614.0983
613	12:00 26/10/2025	1.8	17.3633	7.5775	27.9008	475.9425	0.345	8.2708
614	13:00 26/10/2025	1.8	17.0683	7.4392	28.1725	312.9742	0.35	906.39
615	14:00 26/10/2025	1.8	16.9792	7.4525	28.0867	783.5975	0.37	22.035
616	15:00 26/10/2025	1.805	17.2325	7.4608	28.13	609.04	0.3658	359.6
617	16:00 26/10/2025	1.8042	17.4358	7.4475	28.0883	714.4517	0.3642	238.2317
618	17:00 26/10/2025	1.8	17.0825	7.4208	28.2242	545.7442	0.3783	855.615
619	18:00 26/10/2025	1.8008	16.9775	7.3892	28.1633	600.31	0.3767	617.8883
620	19:00 26/10/2025	1.8	16.9667	7.4267	28.1742	798.5417	0.385	18.9092
621	20:00 26/10/2025	1.8017	17.0733	7.4417	28.105	594.4358	0.3867	1126.0533
622	21:00 26/10/2025	1.7983	17.1183	7.3783	28.2067	250.51	0.3925	558.53
623	22:00 26/10/2025	1.8008	17.1733	7.3883	28.0867	522.1542	0.3958	235.7833
624	23:00 26/10/2025	1.8	16.9333	7.405	28.0175	442.8975	0.3808	1049.0542
625	00:00 27/10/2025	1.7958	16.9692	7.4	27.9842	665.2108	0.3717	148.4367
626	01:00 27/10/2025	1.8	17.2125	7.4083	28.0425	497.3883	0.3792	880.7658
627	02:00 27/10/2025	1.8	17.1333	7.44	27.9242	656.5233	0.3767	143.1683

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
628	03:00 27/10/2025	1.8	17.115	7.4308	27.92	530.0767	0.3608	389.3725
629	04:00 27/10/2025	1.8	17.01	7.3992	27.8817	472.9525	0.3542	233.645
630	05:00 27/10/2025	1.8	17.0658	7.3875	27.9592	541.175	0.3583	1153.0558
631	06:00 27/10/2025	1.8033	17.2133	7.4133	27.8458	476.3833	0.3525	694.6492
632	07:00 27/10/2025	1.8	17.1533	7.4417	27.8617	625.1875	0.3483	28.4592
633	08:00 27/10/2025	1.8008	17.0483	7.4225	27.8175	408.2125	0.3442	1219.3833
634	09:00 27/10/2025	1.8	17.0108	7.3658	27.8717	250.5425	0.3433	295.8558
635	10:00 27/10/2025	1.8042	17.0908	7.3942	27.8808	433.1342	0.3492	201.4225
636	11:00 27/10/2025	1.8008	17.1458	7.43	27.885	460.2517	0.3467	867.1358
637	12:00 27/10/2025	1.8	17.2217	7.4333	27.8942	547.3817	0.34	38.8592
638	13:00 27/10/2025	1.8008	17.1208	7.365	27.9942	351.3042	0.335	584.0025
639	14:00 27/10/2025	1.8	17.11	7.385	27.9742	755.9275	0.3325	17.1425
640	15:00 27/10/2025	1.8042	17.0075	7.4058	28.0417	659.45	0.33	350.6108
641	16:00 27/10/2025	1.7717	14.4233	7.4133	28.0717	662.9908	0.3383	223.3275
642	17:00 27/10/2025	1.7958	14.2808	7.3875	28.2417	545.74	0.3467	837.3125
643	18:00 27/10/2025	1.7725	14.2317	7.3383	28.1667	695.3108	0.3542	595.5758
644	19:00 27/10/2025	1.77	14.2375	7.3875	28.19	719.5208	0.3617	20.8125
645	20:00 27/10/2025	1.7717	14.2967	7.4125	28.1475	737.8867	0.37	1116.06
646	21:00 27/10/2025	1.9208	17.005	7.3983	28.2283	478.7475	0.3733	968.47
647	22:00 27/10/2025	2.405	31.9775	7.3425	28.12	730.8625	0.375	630.9225
648	23:00 27/10/2025	2.1542	27.2908	7.3933	28.0125	212.4225	0.3683	1157.9825
649	00:00 28/10/2025	1.9767	23.7083	7.7125	25.985	557.0192	0.3158	184.8525
650	01:00 28/10/2025	1.8967	19.8408	7.4842	27.0517	505.0008	0.2425	966.6175
651	02:00 28/10/2025	2.065	14.5217	7.3875	28.0267	822.3667	0.3058	64.4
652	03:00 28/10/2025	1.9292	14.4425	7.3825	28.025	636.6608	0.35	379.6708
653	04:00 28/10/2025	2.0333	14.3517	7.3217	27.975	655.7517	0.3483	225.91
654	05:00 28/10/2025	1.9183	14.6617	7.3742	28.1217	606.2725	0.3717	764.07
655	06:00 28/10/2025	2.09	14.5667	7.37	27.9067	748.1967	0.3625	596.9517
656	07:00 28/10/2025	1.7817	14.55	7.4133	27.9217	710.32	0.3508	26.3
657	08:00 28/10/2025	1.86	14.7325	7.3733	27.9067	393.7092	0.3483	1175.9975
658	09:00 28/10/2025	2.17	14.4325	7.3708	28.0375	243.1792	0.3592	690.1467
659	10:00 28/10/2025	1.8992	14.4017	7.3492	27.9275	564.0858	0.3592	218.7042
660	11:00 28/10/2025	1.9067	14.6108	7.3808	27.8717	461.7383	0.345	413.385
661	12:00 28/10/2025	1.7983	14.77	7.415	27.9242	466.9125	0.3425	165.9567
662	13:00 28/10/2025	2.095	14.4917	7.37	28.18	448.1442	0.3525	1037.3633
663	14:00 28/10/2025	1.8567	14.5583	7.4225	28.0825	826.8167	0.3725	123.3208
664	15:00 28/10/2025	1.8267	14.5575	7.435	28.0733	853.1067	0.3633	411.1942
665	16:00 28/10/2025	2.1158	14.5125	7.395	28.3342	562.3867	0.3708	701.6508
666	17:00 28/10/2025	1.9633	15.2283	7.455	28.1483	853.8508	0.3933	708.38
667	18:00 28/10/2025	2.0017	14.5017	7.375	28.0458	660.7225	0.365	626.0967
668	19:00 28/10/2025	1.9717	14.6	7.3892	28.3133	671.4125	0.3942	519.8867
669	20:00 28/10/2025	1.9017	14.6075	7.4025	28.1117	732.8308	0.4075	1130.0467

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u> <u>Thời gian</u>	40,5	60,75	6 - 9	40		4,05	
670	21:00 28/10/2025	1.8125	14.5508	7.4225	28.055	699.3817	0.39	238.655
671	22:00 28/10/2025	1.9433	14.485	7.4	28.2558	609.2683	0.4092	703.5367
672	23:00 28/10/2025	1.9308	14.5942	7.3892	28.02	494.9808	0.3975	1052.3333
673	00:00 29/10/2025	1.7892	14.405	7.3858	28.0108	463.7775	0.3808	144.17
674	01:00 29/10/2025	1.9567	14.625	7.4133	28.0875	251.4	0.3942	938.3908
675	02:00 29/10/2025	1.9033	14.6167	7.4033	28.0058	544.7067	0.39	665.1308
676	03:00 29/10/2025	1.8633	14.5158	7.3867	27.93	589.9267	0.3792	547.3483
677	04:00 29/10/2025	1.9117	14.4658	7.4275	27.9992	529.8825	0.3825	408.865
678	05:00 29/10/2025	1.8075	14.5733	7.4358	27.9167	757.7442	0.3808	178.5658
679	06:00 29/10/2025	1.8783	14.7008	7.4192	27.8225	692.0792	0.3608	570.5792
680	07:00 29/10/2025	1.8942	14.6025	7.3983	28.1025	624.6975	0.3808	506.495
681	08:00 29/10/2025	1.85	14.5917	7.4075	27.8883	478.1917	0.3867	1062.2583
682	09:00 29/10/2025	1.7833	14.405	7.3883	27.8525	245.9642	0.36	106.495
683	10:00 29/10/2025	1.7825	14.5142	7.4308	27.8875	326.0267	0.3583	189.8508
684	11:00 29/10/2025	1.9425	14.6692	7.4617	27.9933	313.1542	0.37	1236.19
685	12:00 29/10/2025	1.7917	14.6417	7.475	27.98	805.0017	0.37	42.7008
686	13:00 29/10/2025	1.8433	14.5308	7.3925	28.0392	662.0033	0.3517	565.9208
687	14:00 29/10/2025	1.7833	14.6433	7.4508	27.9667	651.9067	0.3575	65.4725
688	15:00 29/10/2025	1.8175	14.7358	7.4658	28.0225	572.0317	0.3475	347.5008
689	16:00 29/10/2025	1.8042	14.7867	7.4417	28.0817	715.5942	0.3517	228.8842
690	17:00 29/10/2025	1.8417	15.0817	7.4658	28.1342	731.6658	0.3617	653.695
691	18:00 29/10/2025	1.8158	14.7142	7.365	28.1542	430.1842	0.3625	672.32
692	19:00 29/10/2025	1.845	14.7208	7.37	28.4608	609.5958	0.3967	551.6808
693	20:00 29/10/2025	1.8283	14.8083	7.3983	28.2175	610.1525	0.4192	1084.1125
694	21:00 29/10/2025	1.7875	14.775	7.4108	28.1517	483.1033	0.3975	205.6192
695	22:00 29/10/2025	1.7725	14.7967	7.4275	28.1417	582.4108	0.3975	198.8558
696	23:00 29/10/2025	1.8792	14.8525	7.3875	28.2208	296.8208	0.4008	1499.0067
697	00:00 30/10/2025	1.785	14.6808	7.3708	28.1525	563.045	0.4008	160.3325
698	01:00 30/10/2025	1.795	14.9542	7.3858	28.0683	526.4183	0.3925	548.2833
699	02:00 30/10/2025	1.82	14.9192	7.4058	28.085	490.2508	0.38	646.2
700	03:00 30/10/2025	1.7958	14.8475	7.3883	28.0508	566.7567	0.3842	527.2617
701	04:00 30/10/2025	1.78	14.8	7.3583	28.0317	449.9383	0.3767	260.2033
702	05:00 30/10/2025	1.7975	14.9617	7.4033	28.0342	657.2117	0.38	654.1517
703	06:00 30/10/2025	1.7958	15.09	7.3908	27.995	668.3858	0.3708	646.5742
704	07:00 30/10/2025	1.77	15.02	7.4475	27.9283	607.605	0.3717	36.2767
705	08:00 30/10/2025	1.79	15.02	7.3967	27.9783	689.8092	0.3583	1122.6375
706	09:00 30/10/2025	1.7775	14.8558	7.3675	27.9767	705.5833	0.36	259.235
707	10:00 30/10/2025	1.7758	14.9633	7.405	27.9717	468.045	0.3583	186.8425
708	11:00 30/10/2025	1.8275	15.1225	7.4167	28.0725	268.9925	0.3683	1289.4992
709	12:00 30/10/2025	1.7767	15.0733	7.4083	28.0475	799.8975	0.375	131.4583
710	13:00 30/10/2025	1.785	14.9875	7.3417	28.0708	626.0242	0.365	607.1167
711	14:00 30/10/2025	1.7875	15.1792	7.3992	28.055	669.2383	0.37	293.1542

STT	Datetime	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép Thời gian	40,5	60,75	6 - 9	40		4,05	
712	15:00 30/10/2025	1.8058	15.2267	7.4	28.2175	571.4925	0.3883	853.44
713	16:00 30/10/2025	1.7792	15.2158	7.4108	28.0883	718.9108	0.3817	264.0433
714	17:00 30/10/2025	1.7925	15.3933	7.3975	28.1142	757.5533	0.3742	653.0483
715	18:00 30/10/2025	1.7883	15.105	7.315	28.095	544.4075	0.365	722.945
716	19:00 30/10/2025	1.7933	15.0642	7.3508	28.2742	624.9333	0.395	558.41
717	20:00 30/10/2025	1.7917	15.2083	7.3592	28.1125	753.8742	0.3933	1080.9008
718	21:00 30/10/2025	1.775	15.2317	7.3892	28.0592	742.4208	0.3717	218.7908
719	22:00 30/10/2025	1.7717	15.2692	7.4192	28.055	688.7425	0.3675	191.6008
720	23:00 30/10/2025	1.8067	15.1967	7.325	28.1217	300.1358	0.3658	1509.1675
721	00:00 31/10/2025	1.7733	15.1083	7.32	28.0658	825.6033	0.37	186.0092
722	01:00 31/10/2025	1.7883	15.4433	7.37	28.005	784.8533	0.3642	551.5783
723	02:00 31/10/2025	1.7908	15.3275	7.3658	28.0025	576.2958	0.3525	645.3167
724	03:00 31/10/2025	1.7908	15.2067	7.33	28.1217	563.7867	0.3708	1046.6417
725	04:00 31/10/2025	1.7758	15.1592	7.3142	28.0242	694.3058	0.3675	298.0317
726	05:00 31/10/2025	1.7817	15.3033	7.3442	27.9967	773.9858	0.365	626.6058
727	06:00 31/10/2025	1.7892	15.5633	7.3808	27.9375	532.6008	0.3592	647.3392
728	07:00 31/10/2025	1.7783	15.3542	7.3283	28.1333	336.1517	0.3742	543.7108
729	08:00 31/10/2025	1.7883	15.3733	7.3417	27.9683	503.5842	0.3767	1157.425
730	09:00 31/10/2025	1.7733	15.2683	7.34	27.9217	375.115	0.3583	250.4308
731	10:00 31/10/2025	1.7775	15.3825	7.3867	27.9033	417.0292	0.3567	180.9792
732	11:00 31/10/2025	1.7908	15.4633	7.3533	28.0258	340.5325	0.36	1027.8117
733	12:00 31/10/2025	1.78	15.5283	7.4108	27.9717	821.2167	0.3758	72.44
734	13:00 31/10/2025	1.7867	15.4467	7.3617	27.9517	259.2108	0.355	606.9617
735	14:00 31/10/2025	1.7808	15.53	7.3783	28.0658	804.4442	0.3683	478.0817
736	15:00 31/10/2025	1.7892	15.6375	7.4175	27.945	867.1275	0.3767	410.9733
737	16:00 31/10/2025	1.7925	15.72	7.43	27.89	746.2617	0.355	655.785
738	17:00 31/10/2025	1.78	15.5667	7.3275	28.1292	700.695	0.3692	565.4283
739	18:00 31/10/2025	1.78	15.48	7.3342	27.9233	548.7217	0.3708	677.1975
740	19:00 31/10/2025	1.7883	15.6175	7.3767	27.8458	634.4283	0.3583	718.7458
741	20:00 31/10/2025	1.7908	15.7658	7.3683	27.9875	852.815	0.3667	988.3008
742	21:00 31/10/2025	1.7808	15.8125	7.4067	27.8442	787.7858	0.3667	137.8658
743	22:00 31/10/2025	1.7917	15.7933	7.3742	27.7767	869.0942	0.3508	959.2258
744	23:00 31/10/2025	1.785	15.635	7.35	27.9017	478.4325	0.3575	885.3542