

KẾT QUẢ ONLINE TRẠM QTTĐ KCN KHAI QUANG THÁNG 5/2026

STT	Thông số	TSS (mg/l)	COD (mg/l)	pH{	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
1		mg/L	mg/L	-	oC	m3/h	mg/L	m3/h
2	00:00 01-05-2026	6,28	18,86	6,82	28,67	282,41	2,31	339,02
3	01:00 01-05-2026	2,92	20,05	6,74	28,57	485,93	2,61	7,97
4	02:00 01-05-2026	5	20,62	6,12	26,18	157,96	2,59	528,52
5	03:00 01-05-2026	3,96	21,19	6,74	28,5	266,36	2,7	113,8
6	04:00 01-05-2026	3,3	10,16	6,62	16,67	336,78	1,27	281,12
7	05:00 01-05-2026	8,68	19,89	6,22	26,04	331,44	2,59	400,2
8	06:00 01-05-2026	4,37	20,4	6,78	28,37	373,29	2,89	29,92
9	07:00 01-05-2026	5,91	20,16	6,76	28,36	324,56	2,9	88,75
10	08:00 01-05-2026	7,23	22,42	6,69	28,45	0	3,35	887,32
11	09:00 01-05-2026	6,44	22,09	6,66	28,42	261,07	3,23	23,26
12	10:00 01-05-2026	5,98	21,47	6,71	28,45	384,45	3,1	0,24
13	11:00 01-05-2026	12,05	22,11	6,71	28,48	228,05	3,11	548,42
14	12:00 01-05-2026	6,3	17,6	6,77	28,59	281,73	2,44	315,33
15	13:00 01-05-2026	6,86	19,45	6,75	28,49	625,52	2,91	3,08
16	14:00 01-05-2026	10,71	23,72	6,66	28,57	392,12	3,59	571,34
17	15:00 01-05-2026	12,62	22,32	6,7	28,52	543,62	3,29	86,6
18	16:00 01-05-2026	13,9	19,67	6,82	28,61	593,17	2,46	118,95
19	17:00 01-05-2026	20,08	23,94	6,75	28,56	559,31	3,5	467,8
20	18:00 01-05-2026	16,96	22,38	6,77	28,51	594,04	3,53	30,65
21	19:00 01-05-2026	14,37	15,38	6,58	23,76	412,57	2,3	603,93
22	20:00 01-05-2026	23,29	22,07	6,73	28,59	16,66	3,48	902,74
23	21:00 01-05-2026	24,47	21,99	6,72	28,54	332,22	3,52	26,04
24	22:00 01-05-2026	31,43	20,23	6,68	28,43	414,54	2,67	510,4
25	23:00 01-05-2026	36,56	22,2	6,72	28,45	266,35	3,27	565,74
26	00:00 02-05-2026	38,8	18,27	6,8	28,49	281,44	2,54	290,42
27	01:00 02-05-2026	31,87	19,54	6,76	28,43	256,64	2,96	8,68
28	06:00 02-05-2026	9,71	19,9	6,21	25,92	383,69	2,17	12,13
29	07:00 02-05-2026	3,9	18,84	6,66	28,26	490,16	2,72	644,86
30	08:00 02-05-2026	5,64	20,03	6,65	28,27	80,21	2,44	333,41
31	09:00 02-05-2026	3,62	19,18	6,68	28,3	266,66	2,29	5,04
32	10:00 02-05-2026	4,13	19,31	6,65	28,34	480,58	2,69	318,78
33	11:00 02-05-2026	10,29	20,33	6,7	28,46	307,46	2,68	518,64
34	12:00 02-05-2026	13,11	18,24	6,78	28,64	330,47	2,56	103,62
35	13:00 02-05-2026	7,62	18,74	6,77	28,72	745,07	2,67	0,02
36	14:00 02-05-2026	10,59	20,84	6,64	28,8	241,17	2,82	551,82
37	15:00 02-05-2026	13,18	20,14	6,65	28,78	548,17	2,72	110,06
38	16:00 02-05-2026	18,06	18,79	6,73	28,94	361,12	2,28	451,38
39	17:00 02-05-2026	9,55	22,13	6,69	28,9	312,7	3,12	457,48
40	18:00 02-05-2026	4,07	20,74	6,7	28,87	587,93	3,06	28,39
41	19:00 02-05-2026	3,73	17,93	6,69	28,89	549,94	2,35	588,63
42	20:00 02-05-2026	8,56	20,76	6,68	28,9	250,74	3,19	790,51
43	21:00 02-05-2026	3,38	20,29	6,66	28,84	531,27	2,95	29,94

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
44	22:00 02-05-2026	5,02	19,89	6,64	28,82	464,03	2,45	462,56
45	23:00 02-05-2026	9,6	21,68	6,69	28,78	203,44	3,12	569,1
46	00:00 03-05-2026	5,05	18,83	6,74	28,75	565,81	2,66	246,42
47	01:00 03-05-2026	3,6	18,66	6,68	28,75	746,47	2,48	320,28
48	02:00 03-05-2026	6,41	22,24	6,63	28,76	396,28	3,46	598,52
49	03:00 03-05-2026	4,79	20,75	6,68	28,71	545,34	3,18	116,78
50	04:00 03-05-2026	9,24	18,32	6,68	28,71	434,37	2,52	814,22
51	05:00 03-05-2026	8,81	21,45	6,66	28,67	432,98	3,39	478,92
52	06:00 03-05-2026	4,99	20,41	6,67	28,64	427,2	3,35	34,05
53	07:00 03-05-2026	4,48	15,74	6,5	23,86	233,94	2,13	589,54
54	08:00 03-05-2026	6,69	19,94	6,63	28,63	16,76	2,47	692,44
55	09:00 03-05-2026	5,56	20,42	6,6	28,63	193,76	2,38	11,77
56	10:00 03-05-2026	7,06	20,86	6,63	28,63	218,83	3,09	652,16
57	11:00 03-05-2026	16,13	22,2	6,64	28,58	422,82	2,56	229,41
58	12:00 03-05-2026	6,54	17,64	6,76	28,67	424,53	2,4	325,71
59	13:00 03-05-2026	6,07	19	6,7	28,68	772,11	2,38	4,85
60	14:00 03-05-2026	9,39	20,52	6,63	28,74	482,91	2,16	339,22
61	15:00 03-05-2026	9,25	19,89	6,65	28,73	546,75	2,33	86,97
62	16:00 03-05-2026	9,28	19,05	6,72	28,82	589,14	2,57	608,74
63	17:00 03-05-2026	11,34	19,18	6,12	26,38	436,06	2,44	411,97
64	18:00 03-05-2026	6,3	18,12	6,13	26,38	425,83	2,53	33,71
65	19:00 03-05-2026	5,76	17,91	6,67	28,78	70,19	2,36	748,77
66	20:00 03-05-2026	6,7	18,91	6,65	28,71	17,04	2,4	817,23
67	21:00 03-05-2026	5,6	18,64	6,65	28,65	94,49	2,27	19,93
68	22:00 03-05-2026	4,25	11,18	6,88	16,7	517,55	1,36	423,49
69	23:00 03-05-2026	0,89	1,52	6,57	2,37	400,95	0,24	60,06
70	00:00 04-05-2026	0,75	1,6	6,56	2,37	266,77	0,21	60,4
71	01:00 04-05-2026	2,52	4,71	1,7	7,09	502,86	0,6	2,25
72	02:00 04-05-2026	3,27	5,4	1,83	7,72	568,77	0,61	33,21
73	03:00 04-05-2026	11,47	19,45	6,71	28,28	546,61	2,29	104,35
74	04:00 04-05-2026	8,29	17,65	6,81	28,29	594,16	2,75	332,63
75	05:00 04-05-2026	13,12	19,73	6,7	28,23	573,63	2,29	474,38
76	06:00 04-05-2026	11,9	18,99	6,7	28,18	565,73	2,24	32,67
77	07:00 04-05-2026	10,76	17,86	6,75	28,15	417,12	2,24	697,37
78	08:00 04-05-2026	10,68	20,13	6,69	28,2	17,14	2,73	909,66
79	09:00 04-05-2026	10,42	19,51	6,69	28,2	364,53	2,35	28,9
80	10:00 04-05-2026	12,1	18,78	6,82	28,22	461,92	2,1	426,57
81	11:00 04-05-2026	14,97	19,8	6,77	28,27	436,01	2,26	570,68
82	13:00 04-05-2026	2,5	18,52	6,83	28,5	772,21	2,21	1,26
83	14:00 04-05-2026	4,26	20,7	6,72	28,62	378,31	2,51	546,96
84	15:00 04-05-2026	4,85	20,55	6,73	28,57	543,51	2,43	88,02
85	16:00 04-05-2026	47,56	18,3	6,2	26,32	591,7	2,4	986,23
86	17:00 04-05-2026	5,7	16,37	6,08	21,54	674,47	2,27	170,64
87	18:00 04-05-2026	3,71	18,61	6,23	26,29	741,81	2,53	2,94
88	19:00 04-05-2026	7,08	15,58	6,58	23,92	414,22	1,82	1139,44
89	20:00 04-05-2026	70,51	13,15	6,09	21,45	550,34	2,15	378,72

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
90	21:00 04-05-2026	4,85	16,72	6,58	23,85	613,72	1,96	191,9
91	22:00 04-05-2026	4,16	18,53	6,68	28,6	463,55	2,09	779,36
92	23:00 04-05-2026	4,04	18,76	6,72	28,51	395,77	2,24	347,5
93	00:00 05-05-2026	3,77	18,59	6,69	28,49	151,04	2,35	701,74
94	01:00 05-05-2026	1,7	16,85	6,75	28,49	523,17	1,98	474,31
95	02:00 05-05-2026	7,72	19,6	6,66	28,45	386,76	1,96	495,58
96	03:00 05-05-2026	2,78	18,16	6,7	28,38	267,48	2,13	119,14
97	04:00 05-05-2026	30,84	17,5	6,76	28,29	335,4	2,68	667,46
98	05:00 05-05-2026	1,42	17,09	6,66	28,33	338,59	2,03	260,88
99	06:00 05-05-2026	0,51	15,5	6,17	25,93	469,14	1,95	5,48
100	07:00 05-05-2026	6,93	15,66	5,48	23,12	262,41	1,74	336,35
101	08:00 05-05-2026	12,97	18,26	6,82	28,2	571,24	2,73	252,39
102	09:00 05-05-2026	2,56	17,36	6,67	28,34	665,89	1,99	504,2
103	10:00 05-05-2026	1,43	16,72	6,66	28,42	654,73	1,93	95,09
104	11:00 05-05-2026	3,48	17,14	6,72	28,55	548,55	2,05	247,51
105	12:00 05-05-2026	2,2	17,51	6,76	28,64	559,69	2,44	522,06
106	13:00 05-05-2026	2,02	16,03	6,73	28,75	768,8	1,94	605,64
107	14:00 05-05-2026	2,06	15,24	6,08	26,48	335,28	1,7	519,37
108	15:00 05-05-2026	4,54	16,95	6,7	28,94	670,87	2,06	83,84
109	16:00 05-05-2026	19,34	18,2	6,75	29,07	509,55	2,31	1250,52
110	17:00 05-05-2026	1,42	12,89	6,03	21,81	435,3	1,48	134,17
111	18:00 05-05-2026	1,34	15,58	6,2	26,63	309,36	1,82	0,1
112	19:00 05-05-2026	1,92	16,11	6,65	29,05	349,62	1,9	1124,15
113	20:00 05-05-2026	4,73	16,86	6,76	28,94	243,32	2,52	404,48
114	21:00 05-05-2026	6,9	14,78	6,6	24,15	498,41	1,63	105,56
115	22:00 05-05-2026	2,73	15,34	6,1	26,55	315,4	1,69	633,48
116	23:00 05-05-2026	6,09	17,42	6,7	28,88	495,16	1,93	271,44
117	00:00 06-05-2026	9,51	18,32	6,8	28,79	454,06	2,4	383,34
118	01:00 06-05-2026	2,71	16,1	6,72	28,83	767,38	1,86	451,28
119	02:00 06-05-2026	9,82	18,51	6,74	28,81	589,7	1,81	467,97
120	03:00 06-05-2026	3,04	17,14	6,78	28,77	638,44	1,94	112,14
121	04:00 06-05-2026	20,5	18	6,75	28,72	557,72	2,13	1136,34
122	05:00 06-05-2026	3,15	16,55	6,7	28,74	565,02	1,88	279,75
123	06:00 06-05-2026	1,76	16,5	6,74	28,7	624,19	1,92	4,21
124	07:00 06-05-2026	7,2	17,02	6,69	28,66	240,21	1,83	1114,84
125	08:00 06-05-2026	7,98	18,1	6,8	28,6	203,18	2,28	407,51
126	09:00 06-05-2026	3,02	15,58	6,15	26,28	195,95	1,7	415,17
127	10:00 06-05-2026	3,8	16,13	6,72	28,71	63,89	1,76	502,3
128	11:00 06-05-2026	4,4	12,68	6,06	21,54	258,93	1,39	97,48
129	12:00 06-05-2026	3,73	4,52	6,71	7,2	267,81	0,57	198,65
130	13:00 06-05-2026	0,61	3,05	6,25	5,25	501,04	0,35	0
131	14:00 06-05-2026	0	0	0	0	437,02	0	0
132	15:00 06-05-2026	3,41	11,11	6,35	18,44	240,25	1,29	88,52
133	16:00 06-05-2026	22,66	19,86	6,82	28,97	338,03	2,3	611,16
134	17:00 06-05-2026	3,76	17,2	6,79	28,97	674,21	1,87	161,5
135	18:00 06-05-2026	3,16	17,1	6,84	28,92	698,14	1,9	1,56

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
136	19:00 06-05-2026	4,39	17,38	6,71	29	404,14	1,94	682,5
137	20:00 06-05-2026	13,07	18,17	6,82	28,88	570,31	2,4	322,61
138	21:00 06-05-2026	6,08	18	6,75	28,93	799,53	1,92	410,36
139	22:00 06-05-2026	6,76	17,02	6,72	28,96	665,07	1,82	681,75
140	23:00 06-05-2026	6,16	17,66	6,75	28,86	549,92	1,91	288,47
141	00:00 07-05-2026	7,66	18,14	6,69	28,89	428,69	2,1	697,9
142	01:00 07-05-2026	6,03	16,54	6,66	28,93	770,42	1,87	660,1
143	02:00 07-05-2026	10,65	18,81	6,67	28,9	507,73	1,83	571,17
144	03:00 07-05-2026	6,93	17,86	6,72	28,85	278,21	1,96	108,82
145	04:00 07-05-2026	11,82	18,09	6,65	28,85	270,81	2,15	1264,99
146	05:00 07-05-2026	6,81	17,16	6,64	28,87	424,64	1,92	250,33
147	06:00 07-05-2026	6,66	17,1	6,68	28,85	404,5	1,94	3,9
148	07:00 07-05-2026	9,73	17,47	6,59	28,86	111,45	1,96	852,55
149	08:00 07-05-2026	8,98	18,71	6,72	28,77	336,7	2,32	413,04
150	09:00 07-05-2026	2,8	17,6	6,77	28,81	517,51	2,01	6,47
151	10:00 07-05-2026	3,4	18,32	6,63	28,92	551,95	2,02	596,56
152	11:00 07-05-2026	5,42	18,36	6,67	28,86	552	2	262,84
153	12:00 07-05-2026	1,92	19,09	6,69	28,88	532,68	2,26	508,84
154	13:00 07-05-2026	2,1	18,07	6,71	28,97	770,26	2	115,82
155	14:00 07-05-2026	7,74	19,26	6,68	29,1	474,41	1,94	560,62
156	15:00 07-05-2026	3,02	18,2	6,74	29,12	535,28	2,06	96,94
157	16:00 07-05-2026	6,25	20,41	6,72	29,25	563,74	2,44	1252,79
158	17:00 07-05-2026	3,22	19,7	6,7	29,25	690,45	2,09	147,38
159	18:00 07-05-2026	2,62	19,59	6,75	29,24	722,57	2,1	0,74
160	19:00 07-05-2026	2,06	18,1	6,64	29,3	133,03	2,03	1300,6
161	20:00 07-05-2026	1,41	18,5	6,71	29,21	320	2,44	432,81
162	21:00 07-05-2026	4,14	19,02	6,68	29,24	401,55	2,01	409,02
163	22:00 07-05-2026	4,5	19,65	6,67	29,3	335,43	2,24	665,54
164	23:00 07-05-2026	6,44	19,7	6,71	29,2	455,39	2,08	278,51
165	00:00 08-05-2026	2,94	19,55	6,68	29,17	296,1	2,24	706,85
166	01:00 08-05-2026	2,47	19,19	6,71	29,11	433,1	2,12	5,59
167	02:00 08-05-2026	5,67	19,82	6,73	29,07	344,59	1,95	367,2
168	03:00 08-05-2026	2,22	19,02	6,75	29,04	274,58	2,09	103,32
169	04:00 08-05-2026	2,55	19,06	6,71	29	564,09	2,38	806,42
170	05:00 08-05-2026	1,77	18,95	6,77	28,92	676,83	2,32	19,62
171	06:00 08-05-2026	1,39	18,9	6,73	28,88	738,57	2,32	2
172	07:00 08-05-2026	6,96	17,54	6,01	26,54	491,45	1,86	959,85
173	08:00 08-05-2026	1,93	13,79	6,83	21,04	436,68	1,74	298,77
174	09:00 08-05-2026	1,08	13,88	6,94	21,73	381,17	1,53	321,14
175	10:00 08-05-2026	2,45	16,27	0,43	24,22	321,04	1,9	704,69
176	11:00 08-05-2026	2,93	17,45	6,01	26,58	433,85	1,98	264,89
177	12:00 08-05-2026	1,88	19,34	6,61	29,06	293,22	2,37	478,37
178	13:00 08-05-2026	2,1	19,14	6,57	29,08	424,25	2,23	83,88
179	14:00 08-05-2026	1,5	18,5	6,61	29,16	355,04	2,05	291,62
180	15:00 08-05-2026	1,72	18,75	6,66	29,22	272,02	2,17	80,17
181	16:00 08-05-2026	5,35	20,61	6,58	29,36	242,84	2,69	983,14

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
182	17:00 08-05-2026	5,58	20,17	6,61	29,2	408,08	2,26	55,87
183	18:00 08-05-2026	5,4	20,16	6,66	29,18	590,81	2,2	1,24
184	19:00 08-05-2026	2,23	18,89	6,55	29,31	489,49	2,24	721,99
185	20:00 08-05-2026	0,57	17,31	6,04	26,8	545,15	2,35	346,19
186	21:00 08-05-2026	10,06	20,75	6,63	29,16	796,34	2,2	281,5
187	22:00 08-05-2026	4,34	20,64	6,55	29,26	596,2	2,68	690,64
188	23:00 08-05-2026	3,79	19,58	6,57	29,15	561,18	2,35	294,26
189	00:00 09-05-2026	2,39	19,52	6,58	29,09	418,88	2,32	710,28
190	01:00 09-05-2026	1,96	19,12	6,47	29,19	703,36	2,19	635,72
191	02:00 09-05-2026	5,4	20,51	6,55	29,12	454,75	2,11	555,88
192	03:00 09-05-2026	1,92	19,62	6,59	29,05	266,11	2,18	112,94
193	04:00 09-05-2026	2,79	19,86	6,54	29,04	312,29	2,52	1244,67
194	05:00 09-05-2026	1,55	19,66	6,51	29,01	339,67	2,19	318,05
195	06:00 09-05-2026	1,32	19,72	6,57	28,98	455,95	2,24	4,07
196	07:00 09-05-2026	9,07	21,88	6,57	28,91	267	2,2	558,95
197	08:00 09-05-2026	4,25	20,34	6,63	28,82	336,94	2,52	321,04
198	09:00 09-05-2026	3,94	20,59	6,53	28,91	603,82	2,22	484,15
199	10:00 09-05-2026	3,17	20,46	6,52	28,91	564,52	2,17	106,31
200	11:00 09-05-2026	4,47	20,66	6,58	28,89	530,03	2,21	222,36
201	12:00 09-05-2026	3,58	20,47	6,59	28,95	562,86	2,42	532,8
202	13:00 09-05-2026	3,06	19,31	6,61	28,91	458,71	2,19	312,76
203	14:00 09-05-2026	3,81	20,75	6,5	29	414,32	2,24	568,67
204	15:00 09-05-2026	3,58	20,09	6,56	28,99	292,96	2,29	103,04
205	16:00 09-05-2026	7,61	20,46	6,59	28,99	247,25	2,33	1065,27
206	17:00 09-05-2026	8,4	21,12	6,64	29	407,46	2,26	91,59
207	18:00 09-05-2026	6	20,81	6,69	28,97	730,44	2,23	1,95
208	19:00 09-05-2026	4,35	19,51	6,62	28,97	442,26	2,15	725,94
209	20:00 09-05-2026	2,87	18,75	6,64	28,91	451,05	2,52	398,5
210	21:00 09-05-2026	8,12	21,02	6,62	28,92	521,82	2,25	414,75
211	22:00 09-05-2026	6,98	21,12	6,58	28,94	417,61	2,08	723,91
212	23:00 09-05-2026	7,38	20,72	6,61	28,87	526,53	2,19	288,97
213	00:00 10-05-2026	6,04	20,61	6,59	28,88	426,21	2,37	719,56
214	01:00 10-05-2026	8,4	20,81	6,62	28,84	758,29	2,17	133
215	02:00 10-05-2026	8,55	20	6,06	26,44	629,02	1,97	400,11
216	03:00 10-05-2026	6,09	20,74	6,66	28,81	486,55	2,2	108,42
217	04:00 10-05-2026	9,98	18,86	6,7	26,39	268,62	2,11	1288,16
218	05:00 10-05-2026	5,36	19,13	6	26,41	416,13	1,99	340,07
219	06:00 10-05-2026	5,25	20,82	6,6	28,77	423,28	2,19	3,28
220	07:00 10-05-2026	12,45	21,09	6,6	28,76	244,45	2,1	865,44
221	08:00 10-05-2026	17,38	20,86	6,69	28,73	62,16	2,4	398,31
222	09:00 10-05-2026	7,79	20,5	6,74	28,76	197,04	2,18	3,06
223	10:00 10-05-2026	9,72	21,64	6,66	28,87	353,48	2,28	649,09
224	11:00 10-05-2026	8,31	20,26	6,66	28,8	320,81	2,18	193,45
225	12:00 10-05-2026	18,51	19,97	6,71	28,77	284,94	2,5	334,06
226	13:00 10-05-2026	11,33	21,36	6,7	28,78	523,94	2,25	58,67
227	14:00 10-05-2026	14,63	21,8	6,66	28,86	442	2,14	502,06

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
228	15:00 10-05-2026	13,96	20,91	6,69	28,85	262,08	2,24	109,92
229	16:00 10-05-2026	34,14	22,2	6,68	28,92	336,69	2,55	611,09
230	17:00 10-05-2026	13,57	21,5	6,68	28,91	666,74	2,18	197,5
231	18:00 10-05-2026	10,94	21,32	6,73	28,84	639,32	2,24	2,26
232	19:00 10-05-2026	10,51	21,26	6,64	28,91	482,24	2,21	676,36
233	20:00 10-05-2026	31,41	19,94	6,66	28,85	542,5	2,68	323,54
234	21:00 10-05-2026	9,81	22,03	6,68	28,86	787,61	2,18	421,46
235	22:00 10-05-2026	8,69	21,29	6,65	28,89	390,91	2,12	675,04
236	23:00 10-05-2026	8,54	21,44	6,69	28,81	0,13	2,18	257,91
237	00:00 11-05-2026	7,64	21,48	6,63	28,87	0,27	2,29	730,37
238	01:00 11-05-2026	7,71	20,24	6,61	28,84	46,63	2,11	612,71
239	02:00 11-05-2026	16,61	22,59	6,67	28,8	210,14	2,06	157,94
240	03:00 11-05-2026	15,61	21,82	6,74	28,76	345,16	2,17	87,56
241	04:00 11-05-2026	11,86	20,23	6,67	28,74	584,99	2,53	324,19
242	05:00 11-05-2026	8,54	15,3	6,65	21,52	669,49	1,75	6,57
243	06:00 11-05-2026	1	1,84	6,62	2,61	708,41	0,21	0,32
244	07:00 11-05-2026	6,81	15,15	6,77	20,95	262,08	1,57	732,6
245	08:00 11-05-2026	11,34	21,58	6,69	28,74	319,36	2,06	115,16
246	09:00 11-05-2026	9,9	21,76	6,7	28,79	240,7	2,02	473,44
247	10:00 11-05-2026	9,94	21,34	6,69	28,86	186,79	2,05	497,13
248	11:00 11-05-2026	10,08	21,91	6,7	28,83	561,45	2,08	216,26
249	12:00 11-05-2026	7,73	21,68	6,68	28,97	536,3	2,19	567,55
250	13:00 11-05-2026	6,92	21,53	6,74	29,08	770,76	2,09	1,14
251	14:00 11-05-2026	6,79	22,16	6,66	29,21	505,18	1,99	532,98
252	15:00 11-05-2026	6,24	21,65	6,68	29,15	538,66	2	14,64
253	16:00 11-05-2026	8,65	21,91	6,68	29,26	587,72	2,12	893,18
254	17:00 11-05-2026	2,88	19,04	6,7	29,29	436,66	1,98	226,66
255	18:00 11-05-2026	1,25	19,23	6,73	29,25	371,39	2,03	1,98
256	19:00 11-05-2026	1,69	19,08	6,63	29,35	247,5	2,01	1164,56
257	20:00 11-05-2026	3,74	18,44	6,64	29,29	222,23	2,17	412,26
258	21:00 11-05-2026	6,6	20,41	6,67	29,28	273,29	1,99	97,59
259	22:00 11-05-2026	5,26	20,36	6,68	29,32	317,6	2,52	668,65
260	23:00 11-05-2026	5,17	19,89	6,68	29,27	719,7	2,17	138,33
261	00:00 12-05-2026	23,29	20,26	6,78	29,16	520,86	2,45	330,85
262	01:00 12-05-2026	3,22	19,19	6,71	29,24	767,83	2,15	399,04
263	02:00 12-05-2026	7,36	21,15	6,7	29,18	666,88	2	466,36
264	03:00 12-05-2026	1,82	19,72	6,72	29,16	537,72	2,01	113,16
265	04:00 12-05-2026	6,83	16,69	5,58	24,3	558,4	2,08	947,84
266	05:00 12-05-2026	0,79	11,62	3,89	17,01	569,12	1,18	356,09
267	06:00 12-05-2026	0,26	9,84	3,35	14,56	766,92	1,04	3,44
268	07:00 12-05-2026	3,22	18,55	6,06	26,72	236,04	1,86	1015,9
269	08:00 12-05-2026	22,23	18,77	6,14	26,69	0,26	2,04	363,32
270	09:00 12-05-2026	1,64	20,24	6,66	29,15	115,38	1,95	431,47
271	10:00 12-05-2026	3,13	20,5	6,63	29,26	194,9	2,43	610,09
272	11:00 12-05-2026	3,26	20,1	6,66	29,26	300,64	2,04	165,89
273	12:00 12-05-2026	11,02	20,41	6,78	29,35	535,51	2,13	333,14

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
274	13:00 12-05-2026	5,14	20,71	6,8	29,38	755,08	2,01	1,31
275	14:00 12-05-2026	5,49	20,56	6,77	29,48	558,52	1,94	229,95
276	15:00 12-05-2026	4,04	20,5	6,78	29,58	267,97	2,01	72,96
277	16:00 12-05-2026	9,51	21,47	6,71	29,73	477,14	2,28	1094,04
278	17:00 12-05-2026	1,82	20,5	6,71	29,69	669,45	2,04	209,09
279	18:00 12-05-2026	1,4	20,41	6,73	29,69	743,92	2,08	0,66
280	19:00 12-05-2026	1,88	20,06	6,69	29,71	351,18	2,11	964,15
281	20:00 12-05-2026	2,78	19,99	6,8	29,66	544,08	2,36	325,43
282	21:00 12-05-2026	4,55	20,81	6,68	29,66	797,1	2,1	408,88
283	22:00 12-05-2026	2,98	20,69	6,63	29,69	648,71	2,43	730,63
284	23:00 12-05-2026	2,42	20,29	6,67	29,63	523,52	2,17	309,35
285	00:00 13-05-2026	2,29	20,78	6,62	29,6	391,23	2,24	742,47
286	01:00 13-05-2026	1,46	19,64	6,6	29,66	768,84	2,1	630,45
287	02:00 13-05-2026	3,98	20,89	6,62	29,57	640,29	2,06	561,21
288	03:00 13-05-2026	1,35	18,65	6,14	27,06	319,21	1,97	113,8
289	04:00 13-05-2026	2,71	13,74	6,45	19,7	261,59	1,57	864,02
290	05:00 13-05-2026	1,33	20,11	6,61	29,49	320,76	2,16	376,73
291	06:00 13-05-2026	0,71	20,02	6,65	29,47	383,64	2,17	4,16
292	07:00 13-05-2026	2,98	20,16	6,59	29,49	266,46	2,16	804,82
293	08:00 13-05-2026	6,24	23,47	6,76	29,49	337,86	2,76	388,34
294	09:00 13-05-2026	4,39	21,25	6,69	29,51	520,57	2,12	383,55
295	10:00 13-05-2026	4,8	20,6		29,58	382,88	2,05	136,13
296	11:00 13-05-2026	5,35	20,96	6,71	29,69	529,73	2,11	202,35
297	12:00 13-05-2026	1,73	20,85	6,71	29,85	562,78	2,32	557,29
298	13:00 13-05-2026	1,34	20,54	6,72	29,96	776,51	2,2	1,5
299	14:00 13-05-2026	1,26	20,53	6,59	30,05	465,75	2,2	534,89
300	15:00 13-05-2026	2,81	20,82	6,62	30,08	540,99	2,24	89,48
301	16:00 13-05-2026	5,66	21,76	6,64	30,34	586,26	2,3	1160,33
302	17:00 13-05-2026	2	20,74	6,62	30,27	424,32	2,21	164,6
303	18:00 13-05-2026	1,68	20,63	6,67	30,25	429,08	2,18	1,37
304	19:00 13-05-2026	1,61	20,32	6,58	30,32	251	2,14	1188,27
305	20:00 13-05-2026	0,68	20,27	6,69	30,26	224,9	2,35	427,34
306	21:00 13-05-2026	8,58	21,9	6,64	30,21	424,18	2,19	134,35
307	22:00 13-05-2026	2,01	17,31	6,52	25,21	153,08	2,15	633,81
308	23:00 13-05-2026	2,75	17,57	6,53	25,18	266,84	1,95	164,64
309	00:00 14-05-2026	4,68	20,25	6,12	27,36	458,14	2,26	313,54
310	01:00 14-05-2026	2,67	20,93	6,65	30,2	762,94	2,2	435,39
311	02:00 14-05-2026	6,4	21,69	6,68	30,08	629,77	2,18	298,59
312	03:00 14-05-2026	1,42	20,58	6,71	30,06	591,24	2,21	104,83
313	04:00 14-05-2026	2,48	21,12	6,62	30,06	590,53	2,39	1035,66
314	05:00 14-05-2026	1,17	20,86	6,54	30,03	545,88	2,19	311,92
315	06:00 14-05-2026	0,9	20,71	6,59	30,02	650,75	2,24	9,63
316	07:00 14-05-2026	4,24	21,69	6,51	30,02	348,84	2,14	1076,62
317	08:00 14-05-2026	4,32	21,88	6,64	30,03	335,61	2,43	431,04
318	09:00 14-05-2026	1,71	19,89	6	27,54	297,02	1,96	399,02
319	10:00 14-05-2026	1,74	21,28	6,49	30,18	242,55	2,08	584,58

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
320	11:00 14-05-2026	2,4	19,86	6	27,75	661,66	2	212,21
321	12:00 14-05-2026	4,96	21,38	6,65	30,43	557,2	2,38	556,35
322	13:00 14-05-2026	2,28	21,17	6,65	30,47	771,34	2,23	1,25
323	14:00 14-05-2026	12,46	20,06	6	27,98	452,75	1,98	487,13
324	15:00 14-05-2026	4,92	20,19	6,99	27,78	502,07	2,05	116,02
325	16:00 14-05-2026	13,17	22,37	6,6	30,74	456,19	2,46	1209,56
326	17:00 14-05-2026	0,24	21,67	6,61	30,65	404,77	2,22	212,86
327	18:00 14-05-2026	0	21,55	6,65	30,65	408,81	2,2	1,85
328	19:00 14-05-2026	1,13	21,5	6,58	30,7	245,96	2,14	1067,9
329	20:00 14-05-2026	2,96	21,32	6,68	30,68	226,86	2,44	436,24
330	21:00 14-05-2026	7,84	23,14	6,68	30,58	476,46	2,17	144,51
331	22:00 14-05-2026	1,27	22,41	6,6	30,6	483,42	2,37	667,95
332	23:00 14-05-2026	1,62	22,64	6,61	30,6	528,02	2,29	181,9
333	00:00 15-05-2026	4,89	23,62	6,71	30,61	549,62	2,56	335,04
334	01:00 15-05-2026	2,02	23,11	6,54	30,57	772,97	2,21	630,98
335	02:00 15-05-2026	4,41	23,3	6,61	30,45	652,85	2,12	522,08
336	03:00 15-05-2026	0,43	22,64	6,65	30,41	511,52	2,18	112,66
337	04:00 15-05-2026	1,58	22,53	6,63	30,44	552,79	2,65	1267,2
338	05:00 15-05-2026	0,14	17,11	6,94	22,78	518,22	1,78	400,48
339	06:00 15-05-2026	0	22,46	6,63	30,37	560,65	2,54	8,07
340	07:00 15-05-2026	3,52	23,65	6,54	30,37	266,64	2,29	1065,96
341	08:00 15-05-2026	2,58	23,27	6,64	30,45	336,52	2,45	426,32
342	09:00 15-05-2026	1,2	23,47	6,56	30,38	166,43	2,14	464,23
343	10:00 15-05-2026	1,25	23,03	6,53	30,44	388,09	2,15	412,08
344	11:00 15-05-2026	1,87	23,18	6,59	30,53	618,35	2,21	197,14
345	12:00 15-05-2026	0,76	22,39	6,68	30,66	363,94	2,38	564
346	13:00 15-05-2026	0	22,32	6,69	30,68	450,95	2,21	1,51
347	14:00 15-05-2026	0,83	22,31	6,65	30,71	359,67	2,15	450,36
348	15:00 15-05-2026	2,32	21,41	6,66	30,76	278,02	2,23	87,46
349	16:00 15-05-2026	3,77	20,72	6,64	30,98	475,99	2,54	936,28
350	17:00 15-05-2026	3,87	22,06	6,64	30,78	670,07	2,29	62,12
351	18:00 15-05-2026	4,45	22,51	6,7	30,76	699,81	2,22	0,03
352	19:00 15-05-2026	4,8	22,3	6,64	30,9	289	2,16	915,67
353	20:00 15-05-2026	0,14	18,71	6,15	28,32	336,88	2,27	418,7
354	21:00 15-05-2026	3,2	21,65	6,7	30,8	482,33	2,2	397,1
355	22:00 15-05-2026	1,29	19,46	6,06	28,29	437,48	2,25	679,28
356	23:00 15-05-2026	1,96	19,56	6,1	28,24	557,13	2,12	145,3
357	00:00 16-05-2026	3,3	18,8	6,54	25,66	403,95	1,94	732,61
358	01:00 16-05-2026	3,86	22,6	6,66	30,77	775,63	2,3	7,15
359	02:00 16-05-2026	4,86	22,37	6,64	30,71	530,15	2,2	449,82
360	03:00 16-05-2026	1,9	21,42	6,66	30,69	279,27	2,26	118,03
361	04:00 16-05-2026	3	21,16	6,67	30,73	274,2	2,76	1217,65
362	05:00 16-05-2026	1,93	21,81	6,64	30,66	416,48	2,43	307,55
363	06:00 16-05-2026	1,77	21,75	6,67	30,64	429,46	2,46	6,08
364	07:00 16-05-2026	3,46	21,59	6,63	30,67	248,54	2,28	798,02
365	08:00 16-05-2026	7,75	21,58	6,74	30,74	542,08	2,36	437,72

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
366	09:00 16-05-2026	5,09	21,22	6,78	30,67	522,83	2,18	7,88
367	10:00 16-05-2026	4,72	21,89	6,71	30,8	333,32	2,82	639,86
368	11:00 16-05-2026	6,01	22,2	6,72	30,87	402,14	2,58	309,88
369	12:00 16-05-2026	6,22	21,74	6,76	31,06	283,97	2,4	549,73
370	13:00 16-05-2026	3,69	21,41	6,78	31,09	522,95	2,46	200,93
371	14:00 16-05-2026	4,37	20,34	6,2	28,56	459,45	2,08	468,6
372	15:00 16-05-2026	6,92	22,14	6,82	31,24	512,13	2,24	100,99
373	16:00 16-05-2026	23,11	22,53	6,82	31,4	578,58	2,5	567,83
374	17:00 16-05-2026	7,97	21,16	6,75	31,2	678,58	2,18	208,75
375	18:00 16-05-2026	6,97	21	6,78	31,17	715,89	2,19	4,72
376	19:00 16-05-2026	10,7	21,82	6,68	31,25	354,87	2,18	1251,33
377	20:00 16-05-2026	9,57	21,91	6,71	31,25	516,79	2,56	422,68
378	21:00 16-05-2026	11,1	22,45	6,62	31,16	383,67	2,19	405,13
379	22:00 16-05-2026	8,61	21,38	6,62	31,22	360,27	2,25	730,49
380	23:00 16-05-2026	8,58	21,53	6,68	31,15	497,29	2,29	303,67
381	00:00 17-05-2026	12,34	22,7	6,65	31,14	289,74	2,36	783,82
382	01:00 17-05-2026	9,35	21,42	6,7	31,14	453,58	2,24	289,72
383	02:00 17-05-2026	12,74	22,03	6,65	31,02	369,71	2,15	405,28
384	03:00 17-05-2026	8,19	18,99	6,14	28,39	269,46	1,95	28,58
385	04:00 17-05-2026	10,71	21,26	6,67	31,02	267,66	2,38	647,51
386	05:00 17-05-2026	9,53	17,41	5,59	25,78	452,31	1,92	133,65
387	06:00 17-05-2026	11,51	21,01	6,76	30,84	645,74	2,26	3,87
388	07:00 17-05-2026	10,49	16,47	6,76	23,19	269,99	1,75	732,59
389	08:00 17-05-2026	12	22,86	6,8	30,93	336,98	4,25	452,68
390	09:00 17-05-2026	8,86	21,79	6,76	30,82	519,12	2,2	422,41
391	10:00 17-05-2026	10,72	21	6,72	30,91	387,84	2,08	511,35
392	11:00 17-05-2026	10,86	21,72	6,79	30,93	319,05	2,19	203,74
393	12:00 17-05-2026	20,42	21,15	6,79	31,04	307,9	2,4	582,73
394	13:00 17-05-2026	2,12	20,9	6,81	31,09	668,54	2,25	3,58
395	14:00 17-05-2026	2,22	20,99	6,76	31,1	309,46	2,04	551,83
396	15:00 17-05-2026	3,26	21,35	6,79	31,12	345,53	2,15	102,08
397	16:00 17-05-2026	7,83	19,18	6,7	26,11	267	2	629,48
398	17:00 17-05-2026	1,79	19,6	6,87	31,2	389,36	2,04	118,12
399	18:00 17-05-2026	0,05	3,57	6,26	5,67	433,14	0,38	0,45
400	19:00 17-05-2026	2,64	20,26	6,88	31,28	222,45	2,12	667,22
401	20:00 17-05-2026	12,4	20,4	6,89	31,25	230,49	2,52	454,66
402	21:00 17-05-2026	5,11	20,82	6,83	31,07	384,75	2,12	100,94
403	22:00 17-05-2026	5,28	20,79	6,77	31,14	283,64	2,01	618,14
404	23:00 17-05-2026	4,43	20,86	6,79	31,11	450,19	2,13	315,11
405	00:00 18-05-2026	7,98	21,04	6,79	30,98	240,86	2,31	677,01
406	01:00 18-05-2026	1,42	20,32	6,8	30,93	320,41	2,1	13,16
407	02:00 18-05-2026	3,66	18,74	6,18	28,05	259,9	1,78	334,85
408	03:00 18-05-2026	0,69	19,73	6,82	30,81	0,26	1,96	113,21
409	04:00 18-05-2026	1,58	20,65	6,92	30,84	0,42	2,45	467,83
410	05:00 18-05-2026	1,04	20,18	6,78	30,73	0,26	1,89	303,16
411	06:00 18-05-2026	0,32	20,11	6,84	30,71	0,53	1,98	9,73

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
412	07:00 18-05-2026	9,66	21,8	6,89	30,64	146,6	1,87	116,91
413	08:00 18-05-2026	4,21	20,23	7,03	30,65	0,43	1,88	8,68
414	09:00 18-05-2026	3,44	20,28	7,09	30,67	187,07	1,92	1,05
415	10:00 18-05-2026	3,46	20,4	7,14	30,66	477,67	1,93	0,86
416	11:00 18-05-2026	4,34	20,61	7,18	30,68	537,8	1,93	43,18
417	12:00 18-05-2026	9,26	20,27	6,5	28,06	559,26	1,8	66,74
418	13:00 18-05-2026	3,15	20,94	7,03	30,64	774,27	2,12	69,81
419	14:00 18-05-2026	2,17	21,14	6,98	30,82	511,46	1,98	536,67
420	15:00 18-05-2026	0,82	20,56	7,04	30,88	513,6	1,99	26,79
421	16:00 18-05-2026	3,05	20,72	6,93	31,04	592,05	2,01	815,46
422	17:00 18-05-2026	0,98	20,27	6,84	31,01	657,83	2,06	260,12
423	18:00 18-05-2026	0,37	20,1	6,89	30,93	642,62	2,08	4,87
424	19:00 18-05-2026	2,4	21,57	6,84	30,99	356,84	2,1	1240,13
425	20:00 18-05-2026	1,97	21,13	6,92	31,07	493,06	2,49	481,39
426	21:00 18-05-2026	1,91	21,17	6,84	30,89	795,85	2,11	385,23
427	22:00 18-05-2026	1,76	19,01	6,23	28,38	653,55	1,84	613,42
428	23:00 18-05-2026	4,33	21,39	6,84	30,92	504,52	2,07	311,07
429	00:00 19-05-2026	3,34	22,7	6,76	30,85	345,5	2,35	805,62
430	01:00 19-05-2026	3,65	23,46	6,78	30,9	469,22	2,05	575,73
431	02:00 19-05-2026	4,72	22,69	6,72	30,81	210,88	2,02	609,22
432	03:00 19-05-2026	0,91	21,76	6,77	30,77	486,53	2,19	124,75
433	04:00 19-05-2026	2,58	22,25	6,81	30,85	594,41	2,39	899,48
434	05:00 19-05-2026	1,01	22,25	6,82	30,76	372,62	2,39	142,32
435	06:00 19-05-2026	0,85	22,05	6,85	30,71	595,64	2,42	7,3
436	07:00 19-05-2026	5,31	24,33	6,74	30,71	610,81	2,11	1024,46
437	08:00 19-05-2026	3,09	23,35	6,78	30,74	235,72	2,36	348,79
438	09:00 19-05-2026	1,86	21,12	6,15	28,13	179,88	1,92	351,27
439	10:00 19-05-2026	2,7	23,56	6,74	30,8	178,11	2	752,26
440	11:00 19-05-2026	2,52	23,42	6,76	30,78	16,75	2	187,42
441	12:00 19-05-2026	2,75	22,21	6,78	30,83	295,51	1,99	229,51
442	13:00 19-05-2026	0,54	19,96	6,27	28,38	356,81	1,83	1,56
443	14:00 19-05-2026	0,73	20,04	6,31	28,46	613,62	1,87	0,03
444	15:00 19-05-2026	2,83	22,5	6,91	31,06	604,8	2,22	75,87
445	16:00 19-05-2026	8,39	23,96	6,85	31,18	607,73	2,55	900,17
446	17:00 19-05-2026	5,18	22,77	6,83	31,09	650,34	2,16	58,84
447	18:00 19-05-2026	2,89	22,08	6,88	31,04	741,19	2,13	7,39
448	19:00 19-05-2026	4,18	23,49	6,84	31,07	353,16	2,11	1219,4
449	20:00 19-05-2026	2,54	23,08	6,92	31,12	495,06	2,6	513,48
450	21:00 19-05-2026	3,75	22,61	6,83	30,99	798,73	2,1	379,28
451	22:00 19-05-2026	2,98	22,33	6,88	31,04	659,55	1,98	681,26
452	23:00 19-05-2026	3,88	22,75	6,93	30,98	502,71	2,11	314,14
453	00:00 20-05-2026	6,16	24,21	6,88	30,9	394,28	2,35	821,66
454	01:00 20-05-2026	5,63	24,58	6,85	30,94	794,72	2,04	562,88
455	02:00 20-05-2026	6,01	23,03	6,77	30,86	653,88	1,9	627,64
456	03:00 20-05-2026	2,4	22,37	6,81	30,8	534,37	2,01	121,38
457	04:00 20-05-2026	3,44	23,05	6,89	30,83	606,41	2,28	1165,73

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
458	05:00 20-05-2026	3,49	22,88	6,77	30,71	335,57	1,95	480,8
459	06:00 20-05-2026	3,15	22,68	6,82	30,67	465,03	1,95	1,95
460	07:00 20-05-2026	6,34	17,75	6,12	22,99	293,52	1,42	789,04
461	08:00 20-05-2026	4,36	17,64	6,19	23,02	310,07	1,67	263,87
462	09:00 20-05-2026	2,19	13,12	6,98	17,86	309,13	1,11	253,01
463	10:00 20-05-2026	2,09	11,26	3,37	15,28	265,2	0,89	163,62
464	11:00 20-05-2026	4,47	22,67	6,84	30,65	186,34	1,86	147,35
465	12:00 20-05-2026	4,63	22,59	6,89	30,81	292,91	2,06	563,36
466	13:00 20-05-2026	3,53	22,15	6,86	30,71	479,46	1,85	55,9
467	14:00 20-05-2026	3,31	22,36	6,92	30,8	470,6	1,85	0,07
468	15:00 20-05-2026	5,28	23,07	6,98	30,93	539,86	1,87	66,6
469	16:00 20-05-2026	8,35	23,28	6,91	31,1	610,18	2,04	933,26
470	17:00 20-05-2026	9,68	22,59	6,87	30,97	555,2	1,78	168,13
471	18:00 20-05-2026	7,16	22,21	6,91	30,93	800,59	1,79	1,49
472	19:00 20-05-2026	8,25	21,88	6,85	30,96	375,71	1,72	1162,73
473	20:00 20-05-2026	6,57	20,96	6,93	31,01	482,13	2,01	477,91
474	21:00 20-05-2026	6,99	21,44	6,84	30,9	572,47	1,77	371,89
475	22:00 20-05-2026	5,18	20,48	6,86	30,89	367,33	1,66	684,35
476	23:00 20-05-2026	6,21	19,2	6,92	30,85	451,31	1,77	195,4
477	00:00 21-05-2026	3,4	10,7	6,43	15,39	425,33	0,91	151,77
478	01:00 21-05-2026	3,05	10,56	3,45	15,39	797,51	0,88	117,21
479	02:00 21-05-2026	3,28	10,37	6,45	15,38	673,27	0,84	240,14
480	03:00 21-05-2026	2,23	10,17	6,45	15,36	539,4	0,83	23,56
481	04:00 21-05-2026	4,13	11,73	6,09	17,93	610,29	1,12	624,48
482	05:00 21-05-2026	4,74	20,65	6,86	30,68	497,34	1,7	416,89
483	06:00 21-05-2026	4,42	20,81	6,9	30,66	734	1,78	3,24
484	07:00 21-05-2026	9,36	21,32	6,91	30,66	427,03	1,75	994,91
485	08:00 21-05-2026	9,06	20,69	7	30,69	309,5	2,15	458,86
486	09:00 21-05-2026	6,28	20,95	6,92	30,67	285,68	1,81	413,9
487	10:00 21-05-2026	7,62	20,12	6,91	30,72	360,69	1,66	710,18
488	11:00 21-05-2026	7,33	20,8	6,91	30,73	414,34	1,68	180,59
489	12:00 21-05-2026	9,54	20,45	6,94	30,88	561,14	1,87	590,41
490	13:00 21-05-2026	5,94	20,58	6,93	30,91	797,51	1,68	1,73
491	14:00 21-05-2026	6,93	20,73	6,84	30,96	440,54	1,6	521,8
492	15:00 21-05-2026	9,34	21,35	6,86	30,95	514,55	1,67	108,02
493	16:00 21-05-2026	13,78	21,24	6,92	31,12	610,66	1,92	1053,29
494	17:00 21-05-2026	8,99	20,91	6,84	31,03	607,44	1,66	281,53
495	18:00 21-05-2026	11,53	21,55	6,89	31,02	731,21	1,68	2,87
496	19:00 21-05-2026	12,72	20,83	6,83	31,01	270,21	1,65	1199,72
497	20:00 21-05-2026	11,45	20,69	6,91	31,04	312,86	1,95	474,32
498	21:00 21-05-2026	11,58	21,41	6,81	30,95	516,69	1,63	371,17
499	22:00 21-05-2026	10,53	19,16	6,28	28,37	418,97	1,39	645,15
500	23:00 21-05-2026	13,49	19,78	6,3	28,34	315,41	1,5	201,16
501	00:00 22-05-2026	13,24	21,45	6,83	30,87	136,43	1,78	771,63
502	01:00 22-05-2026	11,5	21,73	6,86	30,85	780,57	1,69	9,19
503	02:00 22-05-2026	12,24	22,11	6,85	30,82	637,76	1,62	428,85

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
504	03:00 22-05-2026	10,99	21,95	6,87	30,8	541,63	1,67	115,71
505	04:00 22-05-2026	14,34	21,77	6,94	30,86	394,78	2,04	698,44
506	05:00 22-05-2026	10,34	22,05	6,81	30,75	390,19	1,67	355,72
507	06:00 22-05-2026	9,02	21,96	6,89	30,74	368,75	1,71	1,35
508	07:00 22-05-2026	16,48	23,42	6,87	30,76	44,61	1,76	901,9
509	08:00 22-05-2026	8,38	22,7	6,87	30,82	286,15	2,16	415,15
510	09:00 22-05-2026	5,42	22,94	6,88	30,79	631,15	2,05	1,69
511	10:00 22-05-2026	8,65	20,9	6,92	30,86	584,08	1,71	441,05
512	11:00 22-05-2026	12,2	21,09	6,95	30,96	504,98	1,7	134,4
513	12:00 22-05-2026	30,45	22,44	6,84	31,12	558,97	1,88	569,42
514	13:00 22-05-2026	3,64	21,13	6,86	31,2	800,65	1,62	391,48
515	14:00 22-05-2026	5,8	21,17	6,83	31,17	472,38	1,63	568,44
516	15:00 22-05-2026	13,03	21,82	6,86	31,26	512,7	1,72	119,24
517	16:00 22-05-2026	33,59	20,82	6,88	31,43	611,02	1,96	1076,63
518	17:00 22-05-2026	5,89	20,42	6,8	31,31	658,01	1,68	334,01
519	18:00 22-05-2026	2,35	21,05	6,84	31,28	746,58	1,68	2,38
520	19:00 22-05-2026	9,67	20,65	6,81	31,3	300,18	1,62	1102,94
521	21:00 22-05-2026	11,72	21,27	6,82	31,23	697,37	1,96	358,43
522	22:00 22-05-2026	6,57	20,76	6,78	31,22	581,51	1,83	680,85
523	23:00 22-05-2026	13,04	21,35	6,83	31,18	603,33	1,76	291,33
524	00:00 23-05-2026	22,4	20,55	6,81	31,17	397,49	1,79	843,65
525	01:00 23-05-2026	4,39	21,52	6,76	31,15	793,82	1,76	548,77
526	02:00 23-05-2026	8,49	21,52	6,76	31,09	655,3	1,63	619,49
527	03:00 23-05-2026	2,36	16,45	6,63	23,28	517,4	1,22	102,97
528	04:00 23-05-2026	27,88	20,45	6,86	31,08	611,19	1,89	1127,84
529	05:00 23-05-2026	3,76	19,37	6,19	28,43	470,42	1,53	534,28
530	06:00 23-05-2026	1,25	21,7	6,8	30,99	741,44	1,76	5,26
531	07:00 23-05-2026	6,94	23,3	6,74	30,97	360,03	1,73	976,44
532	08:00 23-05-2026	13	21,2	6,83	31,08	309,98	2,08	488,72
533	09:00 23-05-2026	2,47	22,69	6,73	31,03	341,96	1,72	388,89
534	10:00 23-05-2026	2,97	22,11	6,69	31,14	160,34	1,62	687,27
535	11:00 23-05-2026	3,58	22,54	6,76	31,25	685,9	1,72	156,63
536	12:00 23-05-2026	13,2	21,69	6,82	31,45	555,87	1,97	628,17
537	13:00 23-05-2026	1,33	22,17	6,82	31,55	787,19	1,85	1,09
538	14:00 23-05-2026	1,85	22,66	6,7	31,61	452,8	1,79	510,91
539	15:00 23-05-2026	4,52	22,64	6,73	31,63	486,81	1,76	97,26
540	16:00 23-05-2026	17,84	22,33	6,8	31,92	608,19	1,86	1027,47
541	17:00 23-05-2026	1,83	22,55	6,71	31,75	657,54	1,8	285,13
542	18:00 23-05-2026	1,76	20,84	6,19	29,09	747,06	1,58	0,19
543	19:00 23-05-2026	2,43	21,37	6,12	29,09	324,65	1,56	1062,07
544	20:00 23-05-2026	2,51	22,06	6,78	31,82	279,82	1,78	497,6
545	21:00 23-05-2026	5,05	23,25	6,69	31,67	271	1,83	282,84
546	22:00 23-05-2026	3,27	23,98	6,66	31,66	164,74	1,76	688,12
547	23:00 23-05-2026	4,44	24,41	6,73	31,65	146,03	1,8	270,88
548	00:00 24-05-2026	10,84	23,02	6,86	31,7	530,18	1,8	370,48
549	01:00 24-05-2026	3,46	24,03	6,77	31,62	783,36	1,78	254,15

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
550	02:00 24-05-2026	7,6	24,95	6,78	31,53	666,47	1,71	183,34
551	03:00 24-05-2026	2,07	23,77	6,84	31,51	515,97	1,65	77,79
552	04:00 24-05-2026	3,88	24,2	6,79	31,58	601,8	1,74	1061,77
553	05:00 24-05-2026	1,65	23,96	6,66	31,43	545,23	1,74	470,32
554	06:00 24-05-2026	1,33	24,46	6,72	31,41	469,86	1,73	5,67
555	07:00 24-05-2026	5,1	25,59	6,66	31,4	294,01	1,68	973,89
556	08:00 24-05-2026	2,96	22,23	6,21	28,94	310,27	1,62	500,24
557	09:00 24-05-2026	2,06	24,34	6,63	31,44	330,17	1,74	390,36
558	10:00 24-05-2026	2,18	24,9	6,61	31,52	160,38	1,67	395,92
559	11:00 24-05-2026	2,33	24,8	6,72	31,72	0	1,64	118,12
560	12:00 24-05-2026	5,4	23,88	6,74	31,91	183,02	1,74	617,29
561	13:00 24-05-2026	1,29	23,74	6,74	31,97	724,97	1,74	1,63
562	14:00 24-05-2026	1,33	24,53	6,82	32,09	346,55	1,73	0,09
563	15:00 24-05-2026	3,7	25	6,86	32,13	537,9	1,74	60,61
564	16:00 24-05-2026	14,2	25,14	6,78	32,36	608,34	1,84	784,99
565	17:00 24-05-2026	1,56	25,6	6,61	32,12	647,62	1,66	254,14
566	18:00 24-05-2026	1,51	25,29	6,69	32,16	730,97	1,73	0,28
567	19:00 24-05-2026	2,41	26,08	6,64	32,19	247,54	1,81	1160,5
568	20:00 24-05-2026	1,48	25,88	6,7	32,23	310,31	2,02	320,87
569	21:00 24-05-2026	4,79	26,59	6,64	32,1	515,61	1,75	349,59
570	22:00 24-05-2026	2,85	26,49	6,58	32,09	442,61	1,74	637,65
571	23:00 24-05-2026	5,2	27,25	6,65	32,06	342,51	1,9	171,22
572	00:00 25-05-2026	3,36	26,92	6,62	32,02	399,83	1,96	835,07
573	01:00 25-05-2026	2,89	26,93	6,63	32,01	778,97	1,88	3,98
574	02:00 25-05-2026	4,62	27,33	6,59	31,9	360,73	1,7	421,83
575	03:00 25-05-2026	2,27	26,85	6,62	31,87	271,57	1,8	118,61
576	04:00 25-05-2026	3,3	26,49	6,71	31,95	289,3	2,39	974,3
577	05:00 25-05-2026	1,96	26,87	6,66	31,85	342,83	1,88	188,49
578	06:00 25-05-2026	1,84	26,99	6,71	31,83	151,1	1,95	2,36
579	07:00 25-05-2026	4,43	28,62	6,68	31,8	26,98	2,31	692,78
580	08:00 25-05-2026	3,87	25,5	6,21	29,23	311,2	2,21	480,09
581	09:00 25-05-2026	2,18	17,65	6,52	21,2	516,65	1,4	2,55
582	10:00 25-05-2026	3,2	24,34	6,2	29,21	346,11	2,13	108,15
583	11:00 25-05-2026	0,93	9	6,69	8,01	483,33	0,58	1,42
584	12:00 25-05-2026	1,89	12,83	6,36	16,11	550,72	1,02	248,09
585	13:00 25-05-2026	0,82	25,84	6,73	32,32	788,74	1,96	1,42
586	14:00 25-05-2026	1,37	26,19	6,66	32,34	415,99	2,05	512,39
587	15:00 25-05-2026	3,03	26,36	6,68	32,36	485,89	2,12	98,12
588	16:00 25-05-2026	5,95	26	6,77	32,64	592,03	2,64	919,68
589	17:00 25-05-2026	1,59	26,78	6,64	32,42	502,92	2,22	315,93
590	18:00 25-05-2026	1,19	26,87	6,69	32,4	679,48	2,21	0,04
591	19:00 25-05-2026	2,61	28,06	6,68	32,39	532,73	2,65	1140,63
592	20:00 25-05-2026	0,82	27,66	6,73	32,47	495,12	2,74	406,74
593	21:00 25-05-2026	3,7	28,46	6,67	32,29	737,32	2,44	328,66
594	22:00 25-05-2026	2,98	29,75	6,68	32,26	668,3	3,01	645,4
595	23:00 25-05-2026	4,58	30,34	6,72	32,29	341,24	3,02	262,38

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
596	00:00 26-05-2026	2,59	29,92	6,7	32,2	123,64	3,08	758,56
597	01:00 26-05-2026	3,98	32,36	6,72	32,23	803,7	3,43	511,71
598	02:00 26-05-2026	6,77	31,68	6,64	32,12	657,4	2,6	598,38
599	03:00 26-05-2026	1,74	30,08	6,66	32,1	543,45	2,27	116,18
600	04:00 26-05-2026	2,18	30,4	6,73	32,26	583,41	2,78	736,74
601	05:00 26-05-2026	2,28	31,17	6,68	32,01	390,47	3,1	374,88
602	06:00 26-05-2026	1,96	31,59	6,73	32,04	420,88	3,04	0,11
603	07:00 26-05-2026	6,24	34,38	6,71	32	22,39	3,02	903,6
604	08:00 26-05-2026	3,98	33,31	6,74	32,21	17,62	2,68	483,86
605	09:00 26-05-2026	2,83	32,78	6,71	32,05	278,83	2,42	0,18
606	10:00 26-05-2026	4,27	33,91	6,73	32,15	384,41	2,9	414,49
607	11:00 26-05-2026	5,09	36,06	6,76	32,32	506,38	3,11	104,22
608	12:00 26-05-2026	7,13	33,45	6,77	32,65	560,82	2,27	398,04
609	13:00 26-05-2026	3,1	32,94	6,78	32,62	788,82	2,15	0,22
610	14:00 26-05-2026	2,88	32,65	6,68	32,61	521,11	2,01	462,58
611	15:00 26-05-2026	2,35	27,02	6,56	27,19	489,49	1,68	44,42
612	16:00 26-05-2026	10,41	34,76	6,79	32,99	613,46	2,9	854,58
613	17:00 26-05-2026	3,13	33,18	6,7	32,77	630,97	2,29	316,76
614	18:00 26-05-2026	2,26	33,01	6,74	32,76	720,64	2,18	0,09
615	19:00 26-05-2026	4,15	31,02	6,11	30	271,61	2,03	1010,7
616	20:00 26-05-2026	2,28	25,74	6,64	24,65	198,15	1,79	228,38
617	21:00 26-05-2026	2,77	27,7	6,56	27,23	263,12	1,68	193,94
618	22:00 26-05-2026	3,77	28,86	6,58	27,16	473,74	2,29	541,14
619	23:00 26-05-2026	3,06	20,95	6,36	16,29	336,08	1,49	175,55
620	00:00 27-05-2026	2,1	17,1	6,4	16,33	356,48	1,2	155,05
621	01:00 27-05-2026	4,63	34,99	6,75	32,56	796,93	2,41	190,17
622	02:00 27-05-2026	7,31	34,73	6,73	32,44	654,96	2,08	389,98
623	03:00 27-05-2026	3,68	33,53	6,76	32,43	511,05	1,96	99,05
624	04:00 27-05-2026	9	35,21	6,77	32,54	609,28	2,7	933,05
625	05:00 27-05-2026	4,73	33,65	6,69	32,28	469,85	2,04	396,78
626	06:00 27-05-2026	3,11	34,13	6,75	32,3	743,68	2,22	0,09
627	07:00 27-05-2026	7,18	35,81	6,7	32,26	563,04	2,13	902,55
628	08:00 27-05-2026	6,33	35,43	6,78	32,47	374,88	2,36	474,68
629	09:00 27-05-2026	3,79	34,05	6,7	32,28	256,09	1,9	349,1
630	10:00 27-05-2026	4,74	35,11	6,66	32,29	258,59	2,67	741,13
631	11:00 27-05-2026	5,23	35,84	6,73	32,47	662,75	2,61	272,39
632	12:00 27-05-2026	7	34,73	6,78	32,76	554,64	2,2	625,69
633	13:00 27-05-2026	4,81	35,65	6,75	32,66	788,72	2,58	46,12
634	14:00 27-05-2026	4,87	31,79	6,1	29,74	469,32	2,02	386,19
635	15:00 27-05-2026	6,57	34,84	6,74	32,85	490,96	1,99	86,27
636	16:00 27-05-2026	13,93	37	6,8	33,16	611,6	2,95	936,76
637	17:00 27-05-2026	5,11	35,22	6,74	32,88	634,34	2,36	314,72
638	18:00 27-05-2026	4,09	35,27	6,76	32,83	743,8	2,34	0,06
639	19:00 27-05-2026	6,04	36,03	6,68	32,81	296,82	2,17	1126,97
640	20:00 27-05-2026	5,72	36,29	6,75	32,98	368,04	2,28	540,3
641	21:00 27-05-2026	6,75	35,41	6,71	32,67	510,98	1,95	310,44

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	<u>Giới hạn cho phép</u>	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
642	22:00 27-05-2026	7,6	36,91	6,7	32,58	330,83	2,79	625,04
643	23:00 27-05-2026	9,67	37,95	6,74	32,58	422,82	2,71	276,35
644	00:00 28-05-2026	9,32	36,17	6,72	32,6	98,61	2,14	823,74
645	01:00 28-05-2026	8,32	37,61	6,72	32,48	524,91	2,65	90,42
646	02:00 28-05-2026	10,43	37,34	6,73	32,38	594,87	2,12	395,95
647	03:00 28-05-2026	5,33	36,22	6,78	32,36	538,45	1,97	102,79
648	04:00 28-05-2026	7,85	36,89	6,83	32,56	584,5	2,4	503,59
649	05:00 28-05-2026	6,73	35,64	6,67	32,18	445,72	1,89	361,9
650	06:00 28-05-2026	5,06	35,87	6,76	32,2	758,2	1,99	0,07
651	07:00 28-05-2026	9,88	37,24	6,7	32,17	315,82	1,97	854,11
652	08:00 28-05-2026	7,12	22,01	6,95	18,91	312,79	1,36	384,38
653	09:00 28-05-2026	7,56	34,99	6,69	32,18	360,73	1,93	336,94
654	10:00 28-05-2026	7,39	32,18	6,64	32,21	484,32	1,92	620,06
655	11:00 28-05-2026	7,14	32,77	6,71	32,33	547,96	2,02	113,54
656	12:00 28-05-2026	7,67	32,48	6,76	32,59	559,34	2,11	632,86
657	13:00 28-05-2026	7,27	32,26	6,76	32,57	794,13	1,99	162,04
658	14:00 28-05-2026	7,47	32,49	6,67	32,56	462,02	1,92	483,82
659	15:00 28-05-2026	9,67	33,02	6,71	32,69	484,2	1,98	96,76
660	16:00 28-05-2026	12,71	33,96	6,74	32,98	612,86	2,32	939,1
661	17:00 28-05-2026	8,31	32,19	6,69	32,7	637,88	1,99	334,06
662	18:00 28-05-2026	7,54	32,05	6,73	32,63	749,91	1,95	0,05
663	19:00 28-05-2026	8,57	30,44	6,08	29,86	297,58	1,76	982,89
664	20:00 28-05-2026	6,98	23,59	6,68	22,9	413,2	1,52	333,07
665	21:00 28-05-2026	9,96	32,94	6,64	32,5	788,1	1,91	293,9
666	22:00 28-05-2026	10,13	32,93	6,65	32,45	613,66	2,19	597,7
667	23:00 28-05-2026	12,3	33,82	6,7	32,44	319,84	2,22	274,43
668	00:00 29-05-2026	12,79	33,76	6,69	32,42	122,78	2,07	799,16
669	01:00 29-05-2026	12,36	32,63	6,1	29,66	732,6	1,93	411,6
670	02:00 29-05-2026	10,71	24,83	6,85	23,46	667,87	1,4	449,88
671	03:00 29-05-2026	12,13	33,4	6,73	32,22	538,18	1,94	82,43
672	04:00 29-05-2026	13,53	34,21	6,78	32,31	610,06	2,18	636,04
673	05:00 29-05-2026	13,7	33,5	6,65	32,07	443,42	1,87	395,51
674	06:00 29-05-2026	12,85	33,32	6,69	32,04	715,9	1,89	2,41
675	07:00 29-05-2026	20,18	37	6,66	32,02	554,17	2,02	903,67
676	08:00 29-05-2026	31,28	37,73	6,74	32,22	291,41	2,24	503,45
677	09:00 29-05-2026	3,21	36,05	6,67	32,06	160,52	1,94	341,89
678	10:00 29-05-2026	7,02	36,12	6,62	32,08	167,67	2,04	708,87
679	11:00 29-05-2026	3,1	36,58	6,69	32,14	660,47	2,15	235,07
680	12:00 29-05-2026	53,4	27,23	5,09	24,3	589,57	1,7	566,78
681	13:00 29-05-2026	1,24	29,07	6,6	26,79	623,73	1,63	114,1
682	14:00 29-05-2026	0,91	34,88	6,74	32,14	361,14	1,98	118,96
683	15:00 29-05-2026	2,78	23,2	6,41	21,36	275,21	1,24	462,83
684	16:00 29-05-2026	5,25	36,91	6,76	32,24	294,96	2,47	631,91
685	17:00 29-05-2026	8,1	36,66	6,74	32,04	553,52	2,09	337,8
686	18:00 29-05-2026	1,91	32,3	6,25	29,36	610,34	1,81	2,15
687	19:00 29-05-2026	3,7	33,56	6,17	29,37	709,48	1,89	708,27

STT	Thông số	TSS (mg/l}	COD (mg/l}	pH{}	Temp (oC}	Flow in (m3/h}	N-NH4+ (mg/L}	Flow-Out (m3/h}
	Giới hạn cho phép	40,5	60,75	6 - 9	40		4,05	
	Thời gian							
688	20:00 29-05-2026	4,12	36,19	6,73	32,1	323,4	2,14	512,24
689	21:00 29-05-2026	0,48	23,51	6,52	21,32	789,58	1,33	0,63
690	22:00 29-05-2026	5,27	35,93	6,69	31,87	706,05	2,17	887,05
691	23:00 29-05-2026	3,75	33,07	6,16	29,21	497,61	2,01	266,85
692	00:00 30-05-2026	2,88	26,84	6,64	23,93	454,49	1,53	631
693	01:00 30-05-2026	3,26	36,61	6,63	31,81	666,89	2,09	606,5
694	02:00 30-05-2026	5,68	36,86	6,65	31,76	651,8	2,13	333,29
695	03:00 30-05-2026	2,76	34,8	6,73	31,69	536,31	1,92	394,66
696	04:00 30-05-2026	2,54	36,51	6,69	31,77	607,75	2,48	826,9
697	05:00 30-05-2026	1,44	28,53	6,42	25,84	477,78	1,73	514,21
698	06:00 30-05-2026	0,78	34,91	6,65	31,56	743,61	2,05	15,93
699	07:00 30-05-2026	3,72	36,11	6,64	31,56	508,93	2,16	814,72
700	08:00 30-05-2026	4,61	34,01	6,11	28,84	262,19	2,55	543,43
701	09:00 30-05-2026	2,64	35,54	6,7	31,63	437,03	2,15	0,01
702	10:00 30-05-2026	2,28	34,77	6,59	31,61	150,8	1,94	1039,08
703	11:00 30-05-2026	2,28	35,21	6,63	31,72	412,21	2	178,68
704	12:00 30-05-2026	3,68	35,93	6,74	32,02	614,78	2,09	646,03
705	13:00 30-05-2026	0,45	34,29	6,72	31,91	746,21	1,89	45,23
706	14:00 30-05-2026	0,92	34,6	6,75	32	414,1	1,9	104,98
707	15:00 30-05-2026	3,84	35,29	6,65	32,05	271,89	1,84	491,91
708	16:00 30-05-2026	5,28	37,22	6,66	32,28	284,6	2,12	750,32
709	17:00 30-05-2026	6,9	35,69	6,72	32,05	354,99	1,83	334,65
710	18:00 30-05-2026	0,92	34,38	6,78	32,04	618,37	1,82	3,97
711	19:00 30-05-2026	1,67	35,23	6,71	32,1	580,83	1,83	539,9
712	20:00 30-05-2026	0,52	33,03	6,16	29,5	311,7	1,9	469,41
713	21:00 30-05-2026	0,43	35,24	6,73	32,06	584,75	1,92	0,38
714	22:00 30-05-2026	3,31	31,93	6,13	29,28	726,58	1,58	852,33
715	23:00 30-05-2026	2,99	32,23	6,17	29,23	577,13	1,66	171,22
716	00:00 31-05-2026	4,3	30,65	6,67	26,62	445,58	1,67	578,67
717	01:00 31-05-2026	2,04	32,69	6,05	28,98	569,68	1,61	542,86
718	02:00 31-05-2026	4,77	36,03	6,67	31,83	383,16	1,78	322,44
719	03:00 31-05-2026	2,06	34,9	6,78	31,77	313,72	1,76	391,07
720	04:00 31-05-2026	1,17	35,89	6,76	31,83	613,83	1,92	712,54
721	05:00 31-05-2026	0,89	34,62	6,71	31,68	541,05	1,75	691,44